

Data summary tables for Dŵr Cymru Welsh Water (DWR)

These tables contain a summary of results of monitoring undertaken by the water company in 2014 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2014*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 9 July 2015
Drinking Water Inspectorate
Area 7e
9 Millbank
c/o Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Viewing Site Summary Data for Dŵr Cymru Welsh Water

Report Date Range: For the whole year 2014

Table DWR 1: Quality of water leaving service treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO ₂ /l	344	0	< 0.013136	0.0313622	0
Totals:			344	0			

Table DWR 2: Quality of water leaving service treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	7,173	0	0	0	0
Cryptosporidium	C111	-(n/a)	3,469	0	0	0	0
E Coli	C002	0 number/100 ml	7,172	0	0	0	0
Totals:			17,814	0			

Table DWR 3: Quality of water leaving service treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	7,158	-n/a	0	2
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	7,170	-n/a	0	1
Residual Disinfectant - Free	C009	No abnormal change	7,199	-n/a	0.09	1.48
Residual Disinfectant - Total	C010	No abnormal change	7,195	-n/a	0.51	1.59
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(7194)	-n/a	0	0.561
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	7,710	0	< 0.06	0.39
Totals:			36,432	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table DWR 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	18,127	6	0	0	0
E Coli	C002	0 number/100 ml	18,127	0	0	0	0
Totals:			36,254	6			

Table DWR 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	18,048	-n/a	0	8
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	18,118	-n/a	0	1
Residual Disinfectant - Free	C009	No abnormal change	18,165	-n/a	0.07	1.04
Residual Disinfectant - Total	C010	No abnormal change	18,157	-n/a	0.3	1.14
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(18,156)	-n/a	0	0.68
Totals:			72,488	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table DWR 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	223	0	< 0.1	< 0.17	0
Benzene	F002	1 µg/l	223	0	< 0.028	< 0.05	0
Boron	D005A	1 mg B/l	222	0	< 0.011	0.0333077	0
Bromate	F003	10 µg BrO3/l	53	0	< 0.1	2.95	0
Cyanide	B003	50 µg CN/l	222	0	< 2	< 2	0
Fluoride	A027	1.5 mg F/l	222	0	0.012	0.08377	0
Mercury	B005	1 µg Hg/l	222	0	< 0.00003	< 0.04	0
Pesticides - Total Substances	B010	0.5 µg/l	224	0	0	0.047	0
Pesticides 2,4-D	P020	0.1 µg/l	230	0	< 0.004	0.029646	0
Pesticides Aldrin	P002	0.03 µg/l	241	0	< 0.0039	< 0.0039	0
Pesticides Alpha-HCH	P003	0.1 µg/l	1	0	< 0.0041	< 0.0041	0
Pesticides Asulam	P133	0.1 µg/l	227	0	< 0.005	0.01	0
Pesticides Chlortoluron	P014	0.1 µg/l	8	0	< 0.004	< 0.0068	0
Pesticides Dicamba	P025	0.1 µg/l	1	0	< 0.004	< 0.004	0
Pesticides Dieldrin	P028	0.03 µg/l	242	0	< 0.0039	< 0.0039	0
Pesticides Glyphosate	P042	0.1 µg/l	230	0	< 0.006	< 0.0066	0
Pesticides Heptachlor	P043	0.03 µg/l	241	0	< 0.0051	< 0.0051	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	242	0	< 0.0076	< 0.0076	0
Pesticides MCPA	P054	0.1 µg/l	229	1	< 0.004	0.051214	1
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	230	0	< 0.0045	< 0.006	0
Pesticides Metaldehyde	P226	0.1 µg/l	8	0	0.011	0.054	0
Pesticides Propetamphos	P069	0.1 µg/l	1	0	< 0.007	< 0.007	0
Pesticides Propyzamide	P071	0.1 µg/l	8	0	< 0.004	< 0.0073	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	223	0	0	0	0
Totals:			3,973	1			

Table DWR 7: Quality of water leaving bulk supply points - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane	D008	3 µg/l	223	0	< 0.08	< 0.24	0
Totals:			223	0			

Table DWR 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	222	0	4.969	28.0351
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	3,108	0	0	0
Conductivity (Indicator)	D001	2500 µS/cm	768	0	76.677	570
Gross Alpha Activity	F004	0.1 Bq/l	47	0	< 0.02	0.082
Gross Beta Activity	F005	1 Bq/l	47	0	< 0.04	0.059
Sulphate (Indicator)	A007	250 mg SO4/l	222	0	< 2.7	77.09
Total organic carbon (indicator)	A017	No abnormal change	221	-n/a	0.20066	2.034
Tritium (Indicator)	F006	100 Bq/l	46	0	< 10	13.8
Totals:			4,681	0		

Table DWR 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	420	0	< 0.1	< 0.17	0
Antimony	B008A	5 µg Sb/l	631	0	< 0.01	0.1268	0
Arsenic	B001A	10 µg As/l	631	0	< 0.06	0.6692	0
Benzene	F002	1 µg/l	418	0	< 0.028	< 0.05	0
Benzo (a) Pyrene	D007	0.01 µg/l	634	0	< 0.0004	0.0004565	0
Boron	D005A	1 mg B/l	418	0	< 0.011	0.0190694	0
Bromate	F003	10 µg BrO3/l	579	0	< 0.1	2.222	0
Cadmium	B002	5 µg Cd/l	631	0	< 0.01	0.0568	0
Chromium	B004	50 µg Cr/l	631	0	< 0.05	0.37	0
Copper	A024A	2 mg Cu/l	629	1	0.001003	0.259031	1
Cyanide	B003	50 µg CN/l	419	0	< 2	< 2	0
E Coli	C002	0 number/100 ml	8,534	0	0	0	0
Enterococci	C003	0 number/100 ml	627	0	0	0	0
Fluoride	A027	1.5 mg F/l	416	0	0.009	0.10262	0
Lead (>10 µg/l)	B007B	10 µg Pb/l	628	2	< 0.04	3.8825	2
Mercury	B005	1 µg Hg/l	418	0	< 0.00003	< 0.04	0
Nickel	B006A	20 µg Ni/l	631	0	< 0.13	< 5.2	0
Nitrate	A012	50 mg NO3/l	641	0	< 2.213	< 17.4924	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	630	0	< 0.049	< 0.35552	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	642	0	< 0.013136	0.0215759	0
Pesticides - Total Substances	B010	0.5 µg/l	408	0	0	0.0271365	0
Pesticides 2,4-D	P020	0.1 µg/l	409	0	< 0.004	0.015397	0
Pesticides Aldrin	P002	0.03 µg/l	405	0	< 0.0039	< 0.0039	0
Pesticides Asulam	P133	0.1 µg/l	408	0	< 0.005	< 0.007928	0
Pesticides Dichlorprop	P026	0.1 µg/l	1	0	< 0.003	< 0.003	0
Pesticides Dieldrin	P028	0.03 µg/l	405	0	< 0.0039	< 0.0039	0
Pesticides Glyphosate	P042	0.1 µg/l	409	0	< 0.006	< 0.008589	0
Pesticides Heptachlor	P043	0.03 µg/l	405	0	< 0.0051	< 0.0051	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	405	0	< 0.0076	< 0.0076	0
Pesticides Linuron	P051	0.1 µg/l	120	0	< 0.005	< 0.0084	0
Pesticides MCPA	P054	0.1 µg/l	409	0	< 0.004	0.020618	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	409	0	< 0.0045	< 0.007188	0
Pesticides Propyzamide	P071	0.1 µg/l	37	0	< 0.004	< 0.0073	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	641	0	0	0	0
Selenium	B009	10 µg Se/l	630	0	< 0.1	0.3438	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	422	0	0	0	0
Total Trihalomethanes	D011	100 µg/l	632	0	1	73	0
Totals:			25,763	3			

Table DWR 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	2,019	0	< 1.9	47.676	0
Colour	A001	20 mg/l Pt/Co scale	1,596	1	< 0.73	3.76006	1
Iron	A022	200 µg Fe/l	2,732	15	2.0132	152.444	12
Manganese	A023	50 µg Mn/l	1,978	4	< 0.21	12.8657	3
Organoleptic Odour	A003	0 Dilution number	2,090	3	0	0	3
Organoleptic Taste	A004	0 Dilution number	1,810	5	0	0	4
Sodium	A009	200 mg Na/l	631	0	3.88758	41.9373	0
Tetrachloromethane	D008	3 µg/l	419	0	< 0.08	< 0.24	0
Turbidity	A002	4 nephelometric turbidity units	1,688	1	< 0.06	0.5322	1
Totals:			14,963	29			

Table DWR 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH ₄ /l	1,715	0	< 0.003	0.14432
Chloride (Indicator)	D002A	250 mg Cl/l	416	0	4.817	55
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	8,535	9	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,693	-n/a	0	7
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,693	-n/a	0	5
Conductivity (Indicator)	D001	2500 µS/cm	1,189	0	72.39	477.2
Gross Alpha Activity	F004	0.1 Bq/l	120	1	< 0.02	0.09975
Gross Beta Activity	F005	1 Bq/l	119	0	< 0.04	0.0936
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	2,395	1	7.2	8.6
Residual Disinfectant - Free	C009	No abnormal change	8,527	-n/a	0.05	0.9572
Residual Disinfectant - Total	C010	No abnormal change	8,575	-n/a	0.12	1.03
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(8,516)	-n/a	0	0.24
Sulphate (Indicator)	A007	250 mg SO ₄ /l	416	0	< 2.7	70.9065
Total organic carbon (indicator)	A017	No abnormal change	418	-n/a	0.36838	2.23174
Tritium (Indicator)	F006	100 Bq/l	64	0	< 10	10
Totals:			35,875	11		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.