

## **Data summary tables for Wessex Water Services Ltd (WSX)**

These tables contain a summary of results of monitoring undertaken by the water company in 2014 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2014*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

### **Notes relating to the interpretation of the tables:**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 9 July 2015  
Drinking Water Inspectorate  
Area 7e  
9 Millbank  
c/o Nobel House  
17 Smith Square  
London  
SW1P 3JR

Enquiries: 0300 068 6400

## Viewing Site Summary Data for Wessex Water Services Ltd

Report Date Range: For the whole year 2014

**Table WSX 1: Quality of water leaving service treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	663	0	< 0.01	< 0.01	0
<b>Totals:</b>			<b>663</b>	<b>0</b>			

**Table WSX 2: Quality of water leaving service treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	9,294	9	0	0	7
Cryptosporidium	C111	-(n/a)	780	-n/a	0	0	0
E Coli	C002	0 number/100 ml	9,294	0	0	0	0
<b>Totals:</b>			<b>19,368</b>	<b>9</b>			

**Table WSX 3: Quality of water leaving service treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	9,243	-n/a	0	118
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	9,242	-n/a	0	14
Residual Disinfectant - Free	C009	No abnormal change	9,294	-n/a	0.25	0.77
Residual Disinfectant - Total	C010	No abnormal change	9,294	-n/a	0.3	0.81
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(9,275)	-n/a	0	0.16
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	9,210	4	< 0.1	0.26
<b>Totals:</b>			<b>46,283</b>	<b>4</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table WSX 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	15,679	12	0	0	0
E Coli	C002	0 number/100 ml	15,679	1	0	0	1
<b>Totals:</b>			<b>31,358</b>	<b>13</b>			

**Table WSX 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	15,701	-n/a	0	1192
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	15,700	-n/a	0	95
Residual Disinfectant - Free	C009	No abnormal change	15,737	-n/a	0.12	0.6
Residual Disinfectant - Total	C010	No abnormal change	15,736	-n/a	0.16	0.65
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(15,706)	-n/a	0	0.17
<b>Totals:</b>			<b>62,874</b>	<b>0</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table WSX 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	3,298	2	0	0
Gross Alpha Activity	F004	0.1 Bq/l	105	0	< 0.02	0.08882
Gross Beta Activity	F005	1 Bq/l	105	0	< 0.04	0.12752
Tritium (Indicator)	F006	100 Bq/l	2	0	< 10	< 10
<b>Totals:</b>			<b>3,510</b>	<b>2</b>		

Table WSX 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	570	0	< 0.12	< 0.12	0
Antimony	B008A	5 µg Sb/l	766	0	< 0.1	< 1	0
Arsenic	B001A	10 µg As/l	766	0	< 0.2	< 1	0
Benzene	F002	1 µg/l	570	0	< 0.11	< 0.11	0
Benzo (a) Pyrene	D007	0.01 µg/l	669	0	< 0.0004	0.00073	0
Boron	D005A	1 mg B/l	766	0	< 0.02	0.093733	0
Bromate	F003	10 µg BrO3/l	580	0	< 0.1	2.2	0
Cadmium	B002	5 µg Cd/l	1,332	0	< 0.1	< 0.1	0
Chromium	B004	50 µg Cr/l	766	0	< 1	< 1	0
Copper	A024A	2 mg Cu/l	626	0	< 0.01	0.793	0
Cyanide	B003	50 µg CN/l	566	0	< 2	< 2.033	0
E Coli	C002	0 number/100 ml	3,983	0	0	0	0
Enterococci	C003	0 number/100 ml	592	0	0	0	0
Fluoride	A027	1.5 mg F/l	568	0	< 0.05	0.7931	0
Lead (>10 µg/l)	B007B	10 µg Pb/l	613	4	< 0.1	7.7406	4
Mercury	B005	1 µg Hg/l	569	0	< 0.05	< 0.05	0
Nickel	B006A	20 µg Ni/l	2,913	5	< 2	5.172	5
Nitrate	A012	50 mg NO3/l	686	0	1.2965	46.9029	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	740	0	< 0.1	0.2	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	690	0	< 0.01	< 0.01	0
Pesticides - Total Substances	B010	0.5 µg/l	814	0	0	0.02485	0
Pesticides 2,4-D	P020	0.1 µg/l	192	0	< 0.003	0.01042	0
Pesticides Aldrin	P002	0.03 µg/l	4	0	< 0.006	< 0.006	0
Pesticides Atrazine	P004	0.1 µg/l	401	0	< 0.004	0.03996	0
Pesticides Chlorothalonil	P015	0.1 µg/l	18	0	< 0.006	< 0.008	0
Pesticides Chlortoluron	P014	0.1 µg/l	36	0	< 0.005	< 0.007	0
Pesticides Dicamba	P025	0.1 µg/l	126	0	< 0.006	< 0.006	0
Pesticides Dichlobenil	P098	0.1 µg/l	148	0	< 0.006	< 0.006	0
Pesticides Dieldrin	P028	0.03 µg/l	42	0	< 0.006	< 0.006	0
Pesticides Gamma-HCH (Lindane)	P041	0.1 µg/l	8	0	< 0.006	< 0.006	0
Pesticides Heptachlor	P043	0.03 µg/l	4	0	< 0.006	< 0.006	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	12	0	< 0.006	< 0.006	0
Pesticides Isoproturon	P048	0.1 µg/l	13	0	< 0.004	< 0.007	0
Pesticides MCPA	P054	0.1 µg/l	139	0	< 0.002	0.004	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	153	0	< 0.002	< 0.002	0
Pesticides Metaldehyde	P226	0.1 µg/l	36	0	< 0.01	0.069	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides pp-DDT	P125	0.1 µg/l	32	0	< 0.006	< 0.006	0
Pesticides Propazine	P066	0.1 µg/l	5	0	< 0.003	< 0.004	0
Pesticides Quintozene	P179	0.1 µg/l	37	0	< 0.006	< 0.009	0
Pesticides Simazine	P073	0.1 µg/l	122	0	< 0.004	0.02354	0
Pesticides Tri-allate	P079	0.1 µg/l	10	0	< 0.006	< 0.01	0
Pesticides Trichlopyr	P131	0.1 µg/l	43	0	< 0.005	< 0.005	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	669	0	0	0.00326	0
Selenium	B009	10 µg Se/l	569	0	< 0.5	0.974	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	607	0	< 0.5	0.712	0
Total Trihalomethanes	D011	100 µg/l	611	0	0.3048	34.144	0
<b>Totals:</b>			<b>24,182</b>	<b>9</b>			

**Table WSX 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	1,484	0	< 10	26.15	0
Colour	A001	20 mg/l Pt/Co scale	1,578	0	< 0.5	1.921	0
Iron	A022	200 µg Fe/l	1,397	5	< 10	90.32	3
Manganese	A023	50 µg Mn/l	1,396	0	< 1	5.9	0
Organoleptic Odour	A003	0 Dilution number	928	3	0	0	3
Organoleptic Taste	A004	0 Dilution number	925	3	0	0	3
Sodium	A009	200 mg Na/l	1,174	0	5.4	61.03	0
Tetrachloromethane	D008	3 µg/l	612	0	< 0.07	0.2887	0
Turbidity	A002	4 nephelometric turbidity units	1,765	0	< 0.1	0.36	0
<b>Totals:</b>			<b>11,259</b>	<b>11</b>			

**Table WSX 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	1,827	0	< 0.0256	0.0769
Chloride (Indicator)	D002A	250 mg Cl/l	589	0	8	46
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	19	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	3,813	2	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,662	-n/a	0	183
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,669	-n/a	0	81
Conductivity (Indicator)	D001	2500 µS/cm	1,810	0	122.207	706.315
Gross Alpha Activity	F004	0.1 Bq/l	26	0	< 0.02	0.046
Gross Beta Activity	F005	1 Bq/l	26	0	< 0.04	0.078
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	1,810	0	7.1	8.2
Residual Disinfectant - Free	C009	No abnormal change	3,896	-n/a	< 0.06	0.54
Residual Disinfectant - Total	C010	No abnormal change	3,896	-n/a	0.07	0.59
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(3,881)	-n/a	0	0.162
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	587	0	4	121.12
Total organic carbon (indicator)	A017	No abnormal change	570	-n/a	< 0.5	1.8316
Tritium (Indicator)	F006	100 Bq/l	12	0	< 10	< 10
<b>Totals:</b>			<b>22,212</b>	<b>2</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.