

## **Data summary tables for Cambridge Water Company Plc (CAM)**

These tables contain a summary of results of monitoring undertaken by the water company in 2013 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2013*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables:**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 10 July 2014  
Drinking Water Inspectorate  
Area 7e  
9 Millbank  
c/o Nobel House  
17 Smith Square  
London  
SW1P 3JR

Enquiries: 0300 068 6400

# Site Summary Data for Cambridge Water Company Plc Report

Date Range: For the whole year 2013

**Table CAM 1: Quality of water leaving treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	156	0	< 0.005	< 0.005	0
<b>Totals:</b>			<b>156</b>	<b>0</b>			

**Table CAM 2: Quality of water leaving treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	1,205	0	0	0	0
E Coli	C002	0 number/100 ml	1,205	0	0	0	0
<b>Totals:</b>			<b>2,410</b>	<b>0</b>			

**Table CAM 3: Quality of water leaving treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,475	-n/a	0	32
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,476	-n/a	0	8
Residual Disinfectant - Free	C009	No abnormal change	1,203	-n/a	0.09	0.34
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	1,392	1	< 0.06	0.15
<b>Totals:</b>			<b>5,546</b>	<b>1</b>		

**Table CAM 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	1,670	1	0	0	0
E Coli	C002	0 number/100 ml	1,670	0	0	0	0
<b>Totals:</b>			<b>3,340</b>	<b>1</b>			

**Table CAM 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,669	-n/a	0	15
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,670	-n/a	0	1
Residual Disinfectant - Free	C009	No abnormal change	1,667	-n/a	0.0268	0.18
<b>Totals:</b>			<b>5,006</b>	<b>0</b>		

**Table CAM 6: Quality of water leaving bulk supply points - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Bromate	F003	10 µg BrO <sub>3</sub> /l	158	0	< 0.15	< 0.15	0
<b>Totals:</b>			<b>158</b>	<b>0</b>			

**Table CAM 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	158	0	0	0
<b>Totals:</b>			<b>158</b>	<b>0</b>		

**Table CAM 9: Quality of water at consumer's tap (zones) - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	64	0	< 0.12	< 0.12	0
Antimony	B008A	5 µg Sb/l	66	0	< 0.33	< 0.33	0
Arsenic	B001A	10 µg As/l	66	0	< 0.144	0.39	0
Benzene	F002	1 µg/l	64	0	< 0.06	< 0.06	0
Benzo (a) Pyrene	D007	0.01 µg/l	65	0	< 0.001	< 0.001	0
Boron	D005A	1 mg B/l	66	0	< 0.037	0.0827	0
Cadmium	B002	5 µg Cd/l	66	0	< 0.007	0.02	0
Chromium	B004	50 µg Cr/l	66	0	< 1.5	< 1.5	0
Copper	A024A	2 mg Cu/l	65	0	0.0022	0.722	0
Cyanide	B003	50 µg CN/l	65	0	< 1	2.4	0
E Coli	C002	0 number/100 ml	848	0	0	0	0
Enterococci	C003	0 number/100 ml	65	0	0	0	0
Fluoride	A027	1.5 mg F/l	66	0	0.126	0.199	0
Lead	B007A	25 µg Pb/l	65	0	< 0.017	1.26	0
Mercury	B005	1 µg Hg/l	65	0	< 0.029	< 0.029	0
Nickel	B006A	20 µg Ni/l	65	0	< 0.146	8.63	0
Nitrate	A012	50 mg NO3/l	66	0	26.8	47	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	66	0	0.53	0.94	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	66	0	< 0.005	< 0.005	0
Pesticides - Total Substances	B010	0.5 µg/l	71	0	0	0.067	0
Pesticides 2,4-D	P020	0.1 µg/l	10	0	< 0.005	< 0.005	0
Pesticides Aldrin	P002	0.03 µg/l	65	0	< 0.001	< 0.001	0
Pesticides Atrazine	P004	0.1 µg/l	48	0	< 0.002	0.028	0
Pesticides Bentazone	P006	0.1 µg/l	2	0	< 0.004	< 0.004	0
Pesticides Bromacil	P086	0.1 µg/l	6	0	< 0.003	< 0.003	0
Pesticides Carbetamide	P010	0.1 µg/l	6	0	< 0.009	< 0.009	0
Pesticides Chlortoluron	P014	0.1 µg/l	48	0	< 0.002	< 0.004	0
Pesticides Clopyralid	P018	0.1 µg/l	6	0	< 0.004	< 0.004	0
Pesticides Cyanazine	P092	0.1 µg/l	6	0	< 0.004	< 0.004	0
Pesticides Dicamba	P025	0.1 µg/l	47	0	< 0.007	< 0.026	0
Pesticides Dichlorprop	P026	0.1 µg/l	6	0	< 0.002	< 0.002	0
Pesticides Dieldrin	P028	0.03 µg/l	65	0	< 0.001	0.002	0
Pesticides Diuron	P032	0.1 µg/l	48	0	< 0.005	< 0.006	0
Pesticides Fluroxypyr	P040	0.1 µg/l	4	0	< 0.003	0.009	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Heptachlor	P043	0.03 µg/l	65	0	< 0.001	< 0.001	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	65	0	< 0.001	< 0.001	0
Pesticides Ioxynil	P049	0.1 µg/l	4	0	< 0.004	< 0.004	0
Pesticides Isoproturon	P048	0.1 µg/l	61	0	< 0.003	< 0.005	0
Pesticides Linuron	P051	0.1 µg/l	44	0	< 0.003	< 0.005	0
Pesticides MCPA	P054	0.1 µg/l	65	0	< 0.003	< 0.004	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	2	0	< 0.003	0.004	0
Pesticides Metaldehyde	P226	0.1 µg/l	6	0	0.005	0.012	0
Pesticides Metazachlor	P203	0.1 µg/l	4	0	< 0.003	< 0.003	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	1	0	< 0.004	< 0.004	0
Pesticides Prometryn	P070	0.1 µg/l	6	0	< 0.003	< 0.003	0
Pesticides Propazine	P066	0.1 µg/l	6	0	< 0.002	< 0.003	0
Pesticides Propyzamide	P071	0.1 µg/l	2	0	< 0.002	< 0.004	0
Pesticides Simazine	P073	0.1 µg/l	65	0	< 0.004	0.031	0
Pesticides Terbutryn	P077	0.1 µg/l	6	0	< 0.002	< 0.002	0
Pesticides Trichlopyr	P131	0.1 µg/l	4	0	< 0.006	< 0.006	0
Pesticides Trietazine	P132	0.1 µg/l	65	0	< 0.002	0.013	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	65	0	0	0.002	0
Selenium	B009	10 µg Se/l	66	0	< 0.43	1.62	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	65	0	0	3.95	0
Total Trihalomethanes	D011	100 µg/l	65	0	0	15.1	0
<b>Totals:</b>			<b>3,195</b>	<b>0</b>			

**Table CAM 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	66	0	< 0.002	< 2	0
Colour	A001	20 mg/l Pt/Co scale	166	0	< 0.34	0.733	0
Iron	A022	200 µg Fe/l	66	0	< 0.006	< 6	0
Manganese	A023	50 µg Mn/l	66	0	< 0.001	< 1	0
Organoleptic Odour	A003	0 Dilution number	179	0	0	0	0
Organoleptic Taste	A004	0 Dilution number	178	0	0	0	0
Sodium	A009	200 mg Na/l	66	0	7.89	149	0
Tetrachloromethane	D008	3 µg/l	64	0	< 0.08	< 0.08	0
Turbidity	A002	4 nephelometric turbidity units	204	0	< 0.06	0.1495	0
<b>Totals:</b>			<b>1,055</b>	<b>0</b>			

**Table CAM 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	166	0	< 0.009	0.00933
Chloride (Indicator)	D002A	250 mg Cl/l	66	0	18.8	66.1
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	848	3	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	314	-n/a	0	136
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	314	-n/a	0	48
Conductivity (Indicator)	D001	2500 µS/cm	166	0	505.34	698.28
Gross Alpha Activity	F004	0.1 Bq/l	65	0	< 0.023	0.066
Gross Beta Activity	F005	1 Bq/l	65	0	0.025	0.15
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	166	0	7.1268	7.7531
Residual Disinfectant - Free	C009	No abnormal change	849	-n/a	0.02	0.17
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	66	0	24.4	57.2
Total organic carbon (indicator)	A017	No abnormal change	65	-n/a	0.57	1.28
Tritium (Indicator)	F006	100 Bq/l	65	0	< 2	54
<b>Totals:</b>			<b>3,215</b>	<b>3</b>		