

## **Data summary tables for Dwr Cymru Welsh Water (DWR)**

These tables contain a summary of results of monitoring undertaken by the water company in 2013 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2013*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables:**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 10 July 2014  
Drinking Water Inspectorate  
Area 7e  
9 Millbank  
c/o Nobel House  
17 Smith Square  
London  
SW1P 3JR

Enquiries: 0300 068 6400

## Site Summary Data for Dŵr Cymru Welsh Water

Report Date Range: For the whole year 2013

**Table DWR 1: Quality of water leaving treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	872	0	< 0.013136	0.01642	0
<b>Totals:</b>			<b>872</b>	<b>0</b>			

**Table DWR 2: Quality of water leaving treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	6,634	1	0	0	1
Cryptosporidium	C111	-(n/a)	3,605	0	0	0	0
E Coli	C002	0 number/100 ml	6,634	0	0	0	0
<b>Totals:</b>			<b>16,873</b>	<b>1</b>			

**Table DWR 3: Quality of water leaving treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	6,630	-n/a	0	2
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	6,645	-n/a	0	2
Residual Disinfectant - Free	C009	No abnormal change	6,677	-n/a	0.06	1.5
Residual Disinfectant - Total	C010	No abnormal change	6,676	-n/a	0.42	1.65
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(6,676)	-(n/a)	0	1.19
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	7,368	0	< 0.1	0.33
<b>Totals:</b>			<b>33,996</b>	<b>0</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table DWR 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	18,629	16	0	0	0
E Coli	C002	0 number/100 ml	18,629	1	0	0	1
<b>Totals:</b>			<b>37,258</b>	<b>17</b>			

**Table DWR 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	18,614	-n/a	0	6
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	18,631	-n/a	0	1
Residual Disinfectant - Free	C009	No abnormal change	18,739	-n/a	0.06	1.03
Residual Disinfectant - Total	C010	No abnormal change	18,736	-n/a	0.2	1.15
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(18,730)	-(n/a)	0	0.9
<b>Totals:</b>			<b>74,720</b>	<b>0</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table DWR 6: Quality of water leaving bulk supply points - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	227	0	< 0.17	< 0.17	0
Benzene	F002	1 µg/l	226	0	< 0.028	< 0.028	0
Boron	D005A	1 mg B/l	225	0	< 0.014	0.036432	0
Bromate	F003	10 µg BrO3/l	53	0	< 0.0001	3.3	0
Cyanide	B003	50 µg CN/l	216	0	< 2	< 2.166	0
Fluoride	A027	1.5 mg F/l	224	0	0.00625	0.38025	0
Mercury	B005	1 µg Hg/l	228	0	0	< 0.00004	0
Pesticides - Total Substances	B010	0.5 µg/l	237	0	0	0.136694	0
Pesticides 2,4,5-T	P076	0.1 µg/l	164	0	< 0.0069	< 0.0069	0
Pesticides 2,4,-Db	P082	0.1 µg/l	163	0	< 0.0084	< 0.0084	0
Pesticides 2,4-D	P020	0.1 µg/l	163	0	< 0.0064	0.019526	0
Pesticides Aldrin	P002	0.03 µg/l	233	0	< 0.0039	< 0.0056	0
Pesticides Alpha-HCH	P003	0.1 µg/l	6	0	< 0.0041	< 0.0041	0
Pesticides Asulam	P133	0.1 µg/l	169	0	< 0.0072	< 0.0072	0
Pesticides Atrazine	P004	0.1 µg/l	224	0	< 0.007	< 0.0075	0
Pesticides Benazolin	P138	0.1 µg/l	163	0	< 0.0071	< 0.0071	0
Pesticides Beta-HCH	P007	0.1 µg/l	6	0	< 0.0047	< 0.0047	0
Pesticides Bromoxynil	P008	0.1 µg/l	163	0	< 0.0056	< 0.0056	0
Pesticides Captan	P192	0.1 µg/l	16	0	< 0.0016	< 0.0061	0
Pesticides Carbendazim	P150	0.1 µg/l	98	0	< 0.0075	< 0.0075	0
Pesticides Chlorfenvinphos	P013	0.1 µg/l	233	0	< 0.0074	< 0.0074	0
Pesticides Chlorothalonil	P015	0.1 µg/l	16	0	< 0.0054	< 0.013	0
Pesticides Chlorpyrifos	P017	0.1 µg/l	232	0	< 0.0033	< 0.0041	0
Pesticides Chlortoluron	P014	0.1 µg/l	98	0	< 0.0068	< 0.0068	0
Pesticides Diazinon	P024	0.1 µg/l	233	0	< 0.0068	< 0.0068	0
Pesticides Dicamba	P025	0.1 µg/l	163	0	< 0.011	< 0.011	0
Pesticides Dichlorprop	P026	0.1 µg/l	163	0	< 0.006	< 0.006	0
Pesticides Dieldrin	P028	0.03 µg/l	233	0	< 0.0039	< 0.0048	0
Pesticides Diuron	P032	0.1 µg/l	106	0	< 0.0072	< 0.0072	0
Pesticides Endosulfan A (alpha-Endosulfan)	P101	0.1 µg/l	16	0	< 0.0032	< 0.0037	0
Pesticides Endosulfan B (beta-Endosulfan)	P102	0.1 µg/l	16	0	< 0.0036	< 0.0042	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Endrin	P034	0.1 µg/l	16	0	< 0.0038	< 0.0077	0
Pesticides Ethofumersate	P221	0.1 µg/l	224	0	< 0.01	< 0.01	0
Pesticides Fenpropidin	P168	0.1 µg/l	224	0	< 0.0084	< 0.0084	0
Pesticides Fenpropimorph	P037	0.1 µg/l	227	0	< 0.015	< 0.015	0
Pesticides Glyphosate	P042	0.1 µg/l	30	0	< 0.0066	< 0.0066	0
Pesticides Heptachlor	P043	0.03 µg/l	233	0	< 0.0051	< 0.0064	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	233	0	< 0.0075	< 0.01	0
Pesticides Hexachlorobenzene	P045	0.1 µg/l	16	0	< 0.0037	< 0.005	0
Pesticides Ioxynil	P049	0.1 µg/l	163	0	< 0.0055	< 0.0055	0
Pesticides Isoproturon	P048	0.1 µg/l	98	0	< 0.0068	< 0.0068	0
Pesticides Linuron	P051	0.1 µg/l	98	0	< 0.0084	< 0.0084	0
Pesticides MCPA	P054	0.1 µg/l	166	3	< 0.0067	0.177593	2
Pesticides MCPB	P055	0.1 µg/l	163	0	< 0.0061	< 0.0061	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	163	0	< 0.0045	0.0342944	0
Pesticides Metaldehyde	P226	0.1 µg/l	4	1	< 0.012	0.133	1
Pesticides Metamitron	P194	0.1 µg/l	98	0	< 0.0066	< 0.0066	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	98	0	< 0.0066	< 0.0066	0
Pesticides op-DDD (TDE)	P114	0.1 µg/l	16	0	< 0.0031	< 0.0062	0
Pesticides op-DDE	P115	0.1 µg/l	16	0	< 0.0036	< 0.0053	0
Pesticides op-DDT	P116	0.1 µg/l	16	0	< 0.0033	< 0.0045	0
Pesticides Parathion (Parathion ethyl)	P059	0.1 µg/l	233	0	< 0.0029	< 0.0049	0
Pesticides Pentachlorophenol	P060	0.1 µg/l	163	0	< 0.0063	< 0.0072252	0
Pesticides Permethrin	P119	0.1 µg/l	16	0	< 0.0127	< 0.016	0
Pesticides pp-DDD (TDE)	P123	0.1 µg/l	16	0	< 0.0039	< 0.0074	0
Pesticides pp-DDE	P124	0.1 µg/l	16	0	< 0.0039	< 0.0043	0
Pesticides pp-DDT	P125	0.1 µg/l	16	0	< 0.0046	< 0.0054	0
Pesticides Propachlor	P126	0.1 µg/l	224	0	< 0.0079	< 0.0079	0
Pesticides Propazine	P066	0.1 µg/l	224	0	< 0.0084	< 0.0084	0
Pesticides Propetamphos	P069	0.1 µg/l	232	0	< 0.012	< 0.012	0
Pesticides Propyzamide	P071	0.1 µg/l	16	0	< 0.0073	< 0.0073	0
Pesticides Simazine	P073	0.1 µg/l	224	0	< 0.0057	< 0.0057	0
Pesticides Terbutryn	P077	0.1 µg/l	224	0	< 0.0072	< 0.0072	0
Pesticides Trietazine	P132	0.1 µg/l	224	0	< 0.007	< 0.007	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Trifluralin	P081	0.1 µg/l	16	0	< 0.0031	< 0.0046	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	230	0	0	< 0.509	0
<b>Totals:</b>			<b>9,089</b>	<b>4</b>			

**Table DWR 7: Quality of water leaving bulk supply points - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane	D008	3 µg/l	226	0	< 0.24	< 0.27	0
<b>Totals:</b>			<b>226</b>	<b>0</b>			

**Table DWR 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	226	0	< 4	28.9705
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	3,031	0	0	0
Conductivity (Indicator)	D001	2500 µS/cm	787	0	51.308	592.08
Gross Alpha Activity	F004	0.1 Bq/l	227	1	< 0.02	0.081
Gross Beta Activity	F005	1 Bq/l	227	0	< 0.04	0.09132
Sulphate (Indicator)	A007	250 mg SO4/l	226	0	< 3	66.7857
Total organic carbon (indicator)	A017	No abnormal change	227	-n/a	0.1456	1.6844
Tritium (Indicator)	F006	100 Bq/l	228	0	< 10	< 10
<b>Totals:</b>			<b>5,179</b>	<b>1</b>		

**Table DWR 9: Quality of water at consumer's tap (zones) - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	368	0	< 0.17	< 0.17	0
Antimony	B008A	5 µg Sb/l	592	0	< 0.01	0.1214	0
Arsenic	B001A	10 µg As/l	591	0	< 0.07	0.6924	0
Benzene	F002	1 µg/l	365	0	< 0.028	< 0.028	0
Benzo (a) Pyrene	D007	0.01 µg/l	597	1	< 0.0004	0.001102	1
Boron	D005A	1 mg B/l	366	0	< 0.014	0.023926	0
Bromate	F003	10 µg BrO3/l	430	0	< 0.0001	1.8	0
Cadmium	B002	5 µg Cd/l	592	0	< 0.03	0.0614	0
Chromium	B004	50 µg Cr/l	592	0	< 0.12	1.1	0
Copper	A024A	2 mg Cu/l	591	0	0.0050964	0.263122	0
Cyanide	B003	50 µg CN/l	342	0	< 2	2.114	0
E Coli	C002	0 number/100 ml	7,879	0	0	0	0
Enterococci	C003	0 number/100 ml	591	0	0	0	0
Fluoride	A027	1.5 mg F/l	364	0	0.00365	0.18175	0
Lead	B007A	25 µg Pb/l	591	0	0.0492	5.978	0
Mercury	B005	1 µg Hg/l	366	0	0	< 0.00004	0
Nickel	B006A	20 µg Ni/l	592	0	< 0.14	4.8446	0
Nitrate	A012	50 mg NO3/l	894	0	< 2.213	< 17.4916	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	886	0	< 0.04561	< 0.36004	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	894	0	< 0.013136	0.0198682	0
Pesticides - Total Substances	B010	0.5 µg/l	385	0	0	0.0165124	0
Pesticides 2,4,5-T	P076	0.1 µg/l	332	0	< 0.0069	< 0.0069	0
Pesticides 2,4,-Db	P082	0.1 µg/l	333	0	< 0.0084	< 0.0084	0
Pesticides 2,4-D	P020	0.1 µg/l	332	0	< 0.0064	0.0131956	0
Pesticides Aldrin	P002	0.03 µg/l	367	0	< 0.0039	< 0.0056	0
Pesticides Asulam	P133	0.1 µg/l	366	0	< 0.0072	< 0.0072	0
Pesticides Atrazine	P004	0.1 µg/l	364	0	< 0.007	< 0.0075	0
Pesticides Benazolin	P138	0.1 µg/l	332	0	< 0.0071	< 0.0071	0
Pesticides Bromoxynil	P008	0.1 µg/l	332	0	< 0.0056	< 0.0056	0
Pesticides Captan	P192	0.1 µg/l	107	0	< 0.0016	< 0.0061	0
Pesticides Carbendazim	P150	0.1 µg/l	266	0	< 0.0075	< 0.0075	0
Pesticides Chlorfenvinphos	P013	0.1 µg/l	365	0	< 0.0074	< 0.0074	0
Pesticides Chlorothalonil	P015	0.1 µg/l	107	0	< 0.0054	< 0.013	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Chlorpyrifos	P017	0.1 µg/l	366	0	< 0.0033	< 0.0041	0
Pesticides Chlortoluron	P014	0.1 µg/l	266	0	< 0.0068	< 0.0068	0
Pesticides Diazinon	P024	0.1 µg/l	364	0	< 0.0068	< 0.0068	0
Pesticides Dicamba	P025	0.1 µg/l	332	0	< 0.011	< 0.011	0
Pesticides Dichlorprop	P026	0.1 µg/l	332	0	< 0.006	< 0.006	0
Pesticides Dieldrin	P028	0.03 µg/l	366	0	< 0.0039	< 0.0048	0
Pesticides Diuron	P032	0.1 µg/l	266	0	< 0.0072	< 0.0072	0
Pesticides Endosulfan A (alpha-Endosulfan)	P101	0.1 µg/l	107	0	< 0.0032	< 0.0037	0
Pesticides Endosulfan B (beta-Endosulfan)	P102	0.1 µg/l	107	0	< 0.0036	< 0.0042	0
Pesticides Endrin	P034	0.1 µg/l	107	0	< 0.0038	< 0.0077	0
Pesticides Ethofumersate	P221	0.1 µg/l	364	0	< 0.01	< 0.01	0
Pesticides Fenpropidin	P168	0.1 µg/l	364	0	< 0.0084	< 0.0084	0
Pesticides Fenpropimorph	P037	0.1 µg/l	366	0	< 0.015	< 0.015	0
Pesticides Glyphosate	P042	0.1 µg/l	161	0	< 0.0066	< 0.0067292	0
Pesticides Heptachlor	P043	0.03 µg/l	365	0	< 0.0051	< 0.0064	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	365	0	< 0.0075	< 0.01	0
Pesticides Hexachlorobenzene	P045	0.1 µg/l	107	0	< 0.0037	< 0.005	0
Pesticides Ioxynil	P049	0.1 µg/l	332	0	< 0.0055	< 0.0055	0
Pesticides Isoproturon	P048	0.1 µg/l	266	0	< 0.0068	< 0.0068	0
Pesticides Linuron	P051	0.1 µg/l	266	0	< 0.0084	< 0.0084	0
Pesticides MCPA	P054	0.1 µg/l	333	0	< 0.0067	0.0110212	0
Pesticides MCPB	P055	0.1 µg/l	332	0	< 0.0061	< 0.0061	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	334	0	< 0.0045	0.007711	0
Pesticides Metamitron	P194	0.1 µg/l	266	0	< 0.0066	< 0.0066	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	266	0	< 0.0066	< 0.0066	0
Pesticides op-DDD (TDE)	P114	0.1 µg/l	107	0	< 0.003108	< 0.0062	0
Pesticides op-DDE	P115	0.1 µg/l	107	0	< 0.0036	< 0.0053	0
Pesticides op-DDT	P116	0.1 µg/l	107	0	< 0.0033	< 0.0045	0
Pesticides Parathion (Parathion ethyl)	P059	0.1 µg/l	366	0	< 0.0029	< 0.0049	0
Pesticides Pentachlorophenol	P060	0.1 µg/l	333	0	< 0.0063	0.0079846	0
Pesticides Permethrin	P119	0.1 µg/l	107	0	< 0.0127	< 0.016	0
Pesticides pp-DDD (TDE)	P123	0.1 µg/l	107	0	< 0.0039	< 0.0074	0
Pesticides pp-DDE	P124	0.1 µg/l	108	0	< 0.0039	< 0.0043	0
Pesticides pp-DDT	P125	0.1 µg/l	107	0	< 0.0046	< 0.0054	0
Pesticides Propachlor	P126	0.1 µg/l	364	0	< 0.0079	< 0.0079	0



Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Propazine	P066	0.1 µg/l	364	0	< 0.0084	< 0.0084	0
Pesticides Propetamphos	P069	0.1 µg/l	364	0	< 0.012	< 0.012	0
Pesticides Propyzamide	P071	0.1 µg/l	106	0	< 0.0073	< 0.0073	0
Pesticides Simazine	P073	0.1 µg/l	364	0	< 0.0057	< 0.0057	0
Pesticides Terbutryn	P077	0.1 µg/l	364	0	< 0.0072	< 0.0072	0
Pesticides Trietazine	P132	0.1 µg/l	364	0	< 0.007	< 0.007	0
Pesticides Trifluralin	P081	0.1 µg/l	107	0	< 0.0031	< 0.0046	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	593	0	0	< 0.0094	0
Selenium	B009	10 µg Se/l	592	0	< 0.1	0.4014	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	366	0	0	< 0.509	0
Total Trihalomethanes	D011	100 µg/l	595	0	1	72	0
<b>Totals:</b>			<b>35,563</b>	<b>1</b>			

**Table DWR 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	1,793	1	2.6888	63.859	1
Colour	A001	20 mg/l Pt/Co scale	1,420	0	< 2	3.22	0
Iron	A022	200 µg Fe/l	2,471	15	< 2	155.746	12
Manganese	A023	50 µg Mn/l	1,768	3	0.2538	10.5094	3
Organoleptic Odour	A003	0 Dilution number	1,883	1	0	0	1
Organoleptic Taste	A004	0 Dilution number	1,578	2	0	0	2
Sodium	A009	200 mg Na/l	592	0	2.64436	45.0661	0
Tetrachloromethane	D008	3 µg/l	366	0	< 0.24	< 0.27	0
Turbidity	A002	4 nephelometric turbidity units	1,461	2	< 0.1	0.51	2
<b>Totals:</b>			<b>13,332</b>	<b>24</b>			

**Table DWR 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	1,530	0	< 0.003	0.27321
Chloride (Indicator)	D002A	250 mg Cl/l	367	0	3.9424	52.888
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	1	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	7,878	17	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,474	-n/a	0	9
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,477	-n/a	0	9
Conductivity (Indicator)	D001	2500 µS/cm	988	0	62.545	488.22
Gross Alpha Activity	F004	0.1 Bq/l	580	0	< 0.02	0.05919
Gross Beta Activity	F005	1 Bq/l	580	0	< 0.04	0.08
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	2,230	1	6.8	8.6
Residual Disinfectant - Free	C009	No abnormal change	7,839	-n/a	< 0.02	0.91
Residual Disinfectant - Total	C010	No abnormal change	7,934	-n/a	0.09	1.02
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(7,837)	-(n/a)	0	0.4462
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	367	0	< 2.7	71.8216
Total organic carbon (indicator)	A017	No abnormal change	365	-n/a	0.3132	2.2952
Tritium (Indicator)	F006	100 Bq/l	359	0	< 10	< 10
<b>Totals:</b>			<b>33,969</b>	<b>18</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters

'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.