

Data summary tables for Sembcorp Bournemouth Water (SBW)

These tables contain a summary of results of monitoring undertaken by the water company in 2013 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2013*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 10 July 2014
Drinking Water Inspectorate
Area 7e
9 Millbank
c/o Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Site Summary Data for Sembcorp Bournemouth Water Ltd

Report Date Range: For the whole year 2013

Table SBW 1: Quality of water leaving treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO ₂ /l	1,757	0	< 0.003	0.01342	0
Totals:			1,757	0			

Table SBW 2: Quality of water leaving treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	1,757	0	0	0	0
Cryptosporidium	C111	-(n/a)	1,122		0	0	0
E Coli	C002	0 number/100 ml	1,757	0	0	0	0
Totals:			4,636	0			

Table SBW 3: Quality of water leaving treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,757	-n/a	0	5
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,757	-n/a	0	22
Residual Disinfectant - Free	C009	No abnormal change	1,751	-n/a	< 0.02	0.52
Residual Disinfectant - Total	C010	No abnormal change	1,749	-n/a	0.245	0.655
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(1,748)	-(n/a)	0.0349	0.57
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	1,756	2	< 0.1	0.36472
Totals:			8,770	2		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table SBW 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	1,046	0	0	0	0
E Coli	C002	0 number/100 ml	1,046	0	0	0	0
Totals:			2,092	0			

Table SBW 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,046	-n/a	0	74
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,046	-n/a	0	19
Residual Disinfectant - Free	C009	No abnormal change	1,045	-n/a	< 0.02	0.4254
Residual Disinfectant - Total	C010	No abnormal change	1,045	-n/a	0.11	0.56
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(1,043)	-(n/a)	0.0244	0.47
Totals:			4,182	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table SBW 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	480	0	0	0
Totals:			480	0		

Table SBW 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	99	0	< 0.03	< 0.1	0
Antimony	B008A	5 µg Sb/l	99	0	< 0.08	0.52	0
Arsenic	B001A	10 µg As/l	99	0	0.26	0.8	0
Benzene	F002	1 µg/l	99	0	< 0.02	< 0.03	0
Benzo (a) Pyrene	D007	0.01 µg/l	99	0	< 0.001	< 0.001	0
Boron	D005A	1 mg B/l	121	0	< 0.005	0.30152	0
Bromate	F003	10 µg BrO3/l	99	0	< 0.2	4.8	0
Cadmium	B002	5 µg Cd/l	99	0	< 0.08	0.28	0
Chromium	B004	50 µg Cr/l	99	0	< 0.5	< 1	0
Copper	A024A	2 mg Cu/l	99	0	< 0.005	0.285	0
Cyanide	B003	50 µg CN/l	99	0	< 2	< 2	0
E Coli	C002	0 number/100 ml	1,119	1	0	0	1
Enterococci	C003	0 number/100 ml	99	0	0	0	0
Fluoride	A027	1.5 mg F/l	99	0	0.077	0.244	0
Lead	B007A	25 µg Pb/l	95	0	< 0.2	7.7	0
Mercury	B005	1 µg Hg/l	99	0	< 0.02	0.22	0
Nickel	B006A	20 µg Ni/l	99	1	< 0.3	68.4	1
Nitrate	A012	50 mg NO3/l	400	0	4.303	35.696	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	400	0	0.09501	0.72598	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	400	0	< 0.003	0.17798	0
Pesticides - Total Substances	B010	0.5 µg/l	99	0	0	0.024	0
Pesticides 2,4,-Db	P082	0.1 µg/l	89	0	< 0.005	< 0.01	0
Pesticides 2,4-D	P020	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Atrazine	P004	0.1 µg/l	99	0	< 0.008	< 0.01	0
Pesticides Azoxystrobin	P227	0.1 µg/l	98	0	< 0.006	< 0.006	0
Pesticides Benazolin	P138	0.1 µg/l	98	0	< 0.009	< 0.009	0
Pesticides Bentazone	P006	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Boscalid	P231	0.1 µg/l	98	0	< 0.009	< 0.009	0
Pesticides Bromoxynil	P008	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Carbendazim	P150	0.1 µg/l	99	0	< 0.007	< 0.01	0
Pesticides Chlorfenvinphos	P013	0.1 µg/l	98	0	< 0.003	< 0.004	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Chlorothalonil	P015	0.1 µg/l	98	0	< 0.006	< 0.008	0
Pesticides Chlorpyrifos	P017	0.1 µg/l	98	0	< 0.003	< 0.004	0
Pesticides Chlortoluron	P014	0.1 µg/l	99	0	< 0.006	< 0.01	0
Pesticides Clopyralid	P018	0.1 µg/l	98	0	< 0.009	< 0.009	0
Pesticides Cypermethrin	P094	0.1 µg/l	98	0	< 0.015	< 0.05	0
Pesticides Cyprodinil	P228	0.1 µg/l	98	0	< 0.003	< 0.004	0
Pesticides Cyromazine	P223	0.1 µg/l	98	0	< 0.008	< 0.008	0
Pesticides Desthioprothioconazole	P237	0.1 µg/l	98	0	< 0.008	< 0.008	0
Pesticides Diazinon	P024	0.1 µg/l	98	0	< 0.003	< 0.004	0
Pesticides Dicamba	P025	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Dichlobenil	P098	0.1 µg/l	99	0	< 0.004	< 0.004	0
Pesticides Dichlorprop	P026	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Dieldrin	P028	0.03 µg/l	99	0	< 0.004	0.006	0
Pesticides Diflufenican	P157	0.1 µg/l	98	0	< 0.003	< 0.004	0
Pesticides Diuron	P032	0.1 µg/l	99	0	< 0.01	< 0.011	0
Pesticides Epoxyconazole	P217	0.1 µg/l	99	0	< 0.004	< 0.005	0
Pesticides Fenpropimorph	P037	0.1 µg/l	99	0	< 0.005	< 0.008	0
Pesticides Flusilazole	P159	0.1 µg/l	99	0	< 0.004	< 0.005	0
Pesticides Gamma-HCH (Lindane)	P041	0.1 µg/l	99	0	< 0.004	< 0.004	0
Pesticides Heptachlor	P043	0.03 µg/l	99	0	< 0.006	0.007	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	99	0	< 0.008	0.009	0
Pesticides Ioxynil	P049	0.1 µg/l	98	0	< 0.006	< 0.01	0
Pesticides Isoproturon	P048	0.1 µg/l	99	0	< 0.007	< 0.01	0
Pesticides Kresoxym-Methyl	P218	0.1 µg/l	98	0	< 0.003	< 0.006	0
Pesticides Linuron	P051	0.1 µg/l	99	0	< 0.006	< 0.01	0
Pesticides MCPA	P054	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides MCPB	P055	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Metaldehyde	P226	0.1 µg/l	99	0	< 0.005	0.024	0
Pesticides Metamitron	P194	0.1 µg/l	98	0	< 0.009	< 0.009	0
Pesticides Methiocarb	P056	0.1 µg/l	98	0	< 0.006	< 0.006	0
Pesticides Pendimethalin	P118	0.1 µg/l	99	0	< 0.004	< 0.006	0
Pesticides Pentachlorophenol	P060	0.1 µg/l	98	0	< 0.005	< 0.005	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Permethrin	P119	0.1 µg/l	98	0	< 0.006	0.01	0
Pesticides Picloram	P122	0.1 µg/l	98	0	< 0.011	< 0.011	0
Pesticides Propachlor	P126	0.1 µg/l	98	0	< 0.003	< 0.003	0
Pesticides Propamocarb	P238	0.1 µg/l	98	0	< 0.005	< 0.005	0
Pesticides Propetamphos	P069	0.1 µg/l	98	0	< 0.004	< 0.006	0
Pesticides Propyzamide	P071	0.1 µg/l	100	0	< 0.009	< 0.009	0
Pesticides Simazine	P073	0.1 µg/l	99	0	< 0.01	< 0.014	0
Pesticides Tebuconazole	P177	0.1 µg/l	99	0	< 0.004	< 0.006	0
Pesticides Tri-allate	P079	0.1 µg/l	99	0	< 0.006	< 0.006	0
Pesticides Trichlopyr	P131	0.1 µg/l	99	0	< 0.005	< 0.01	0
Pesticides Trifloxystrobin	P229	0.1 µg/l	98	0	< 0.003	< 0.006	0
Pesticides Trifluralin	P081	0.1 µg/l	39	0	< 0.003	< 0.003	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	99	0	0	0.004	0
Selenium	B009	10 µg Se/l	99	0	< 0.3	1.497	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	99	0	0	0.12	0
Total Trihalomethanes	D011	100 µg/l	99	0	5.4	38.8	0
Totals:			9,768	2			

Table SBW 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	329	0	3.3	47.76	0
Colour	A001	20 mg/l Pt/Co scale	400	0	< 1	4.8791	0
Iron	A022	200 µg Fe/l	329	0	< 4	87.29	0
Manganese	A023	50 µg Mn/l	329	0	< 0.2	6.13	0
Organoleptic Odour	A003	0 Dilution number	400	1	0	0	1
Organoleptic Taste	A004	0 Dilution number	399	0	0	0	0
Sodium	A009	200 mg Na/l	121	0	5.582	110.306	0
Tetrachloromethane	D008	3 µg/l	99	0	< 0.04	< 0.06	0
Turbidity	A002	4 nephelometric turbidity units	400	0	< 0.1	0.77337	0
Totals:			2,806	1			

Table SBW 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH ₄ /l	400	0	< 0.01	0.13798
Chloride (Indicator)	D002A	250 mg Cl/l	121	0	15.7654	30.0196
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	399	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	1,120	1	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	400	-n/a	0	14
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	399	-n/a	0	30
Conductivity (Indicator)	D001	2500 µS/cm	401	0	368.31	560.92
Gross Alpha Activity	F004	0.1 Bq/l	100	0	< 0.015	0.0739
Gross Beta Activity	F005	1 Bq/l	100	0	< 0.033	0.21987
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	401	0	7.2	8.098
Residual Disinfectant - Free	C009	No abnormal change	1,119	-n/a	< 0.02	0.408
Residual Disinfectant - Total	C010	No abnormal change	1,119	-n/a	0.102	0.54
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(1,117)	-(n/a)	0.02	0.47
Sulphate (Indicator)	A007	250 mg SO ₄ /l	121	0	10.05	88.832
Total organic carbon (indicator)	A017	No abnormal change	99	-n/a	< 0.5	12.7
Tritium (Indicator)	F006	100 Bq/l	99	0	< 5	< 6
Totals:			6,398	1		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters

'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.