

Data Summary Tables for Anglian Water Services (ANG)

These tables contain a summary of results of monitoring undertaken by the water company in 2012 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2012*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 11 July 2013
Drinking Water Inspectorate
Area 7e
9 Millbank
c/o Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries : 0300 068 6400

Site Summary Data for Anglian Water Services Ltd

Report Date Range: For the whole year 2012

Table ANG 1: Quality of water leaving treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO ₂ /l	1,808	0	< 0.005	0.006	0
Totals:			1,808	0			

Table ANG 2: Quality of water leaving treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	17,068	4	0	0	4
<i>Cryptosporidium</i>	C111	-(n/a)	1,273	-n/a			
<i>E.coli</i>	C002	0 number/100 ml	17,068	0	0	0	0
Totals:			35,409	4			

Table ANG 3: Quality of water leaving treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	17,069	-n/a	0	10
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	17,076	-n/a	0	3
Residual Disinfectant - Free	C009	No abnormal change	17,093	-n/a	0.05	1.1
Residual Disinfectant - Total	C010	No abnormal change	17,093	-n/a	0.31	1.39
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(17,093)	-(n/a)	0.01	1.11
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	13,574	1	< 0.06	0.17
Totals:			81,905	1		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table ANG 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	16,344	7	0	0	0
<i>E.coli</i>	C002	0 number/100 ml	16,344	1	0	0	1
Totals:			32,688	8			

Table ANG 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	16,346	-n/a	0	158
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	16,351	-n/a	0	45
Residual Disinfectant - Free	C009	No abnormal change	16,361	-n/a	0.01	0.66
Residual Disinfectant - Total	C010	No abnormal change	16,361	-n/a	0.11	1.0038
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(16,361)	-(n/a)	0.02	0.864
Totals:			65,419	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table ANG 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	1,084	0	< 0.024	< 0.12	0
Benzene	F002	1 µg/l	1,084	0	< 0.048	< 0.06	0
Boron	D005A	1 mg B/l	1,082	0	< 0.037	0.24334	0
Bromate	F003	10 µg BrO3/l	1,038	0	< 0.15	2.5661	0
Cyanide	B003	50 µg CN/l	1,085	0	< 1	1.2242	0
Fluoride	A027	1.5 mg F/l	1,107	0	0.07516	1.08728	0
Mercury	B005	1 µg Hg/l	1,081	0	< 0.029	< 0.029	0
Pesticides - Total Substances	B010	0.5 µg/l	1,073	1	0	0.2841	1
Pesticides 2,4-D	P020	0.1 µg/l	452	0	< 0.005	< 0.005	0
Pesticides Atrazine	P004	0.1 µg/l	1,069	0	< 0.002	0.019	0
Pesticides Benazolin	P138	0.1 µg/l	17	0	< 0.005	< 0.005	0
Pesticides Bentazone	P006	0.1 µg/l	636	0	< 0.004	0.009	0
Pesticides Bromacil	P086	0.1 µg/l	623	0	< 0.003	< 0.003	0
Pesticides Carbetamide	P010	0.1 µg/l	432	0	< 0.009	0.02534	0
Pesticides Chloridazon	P162	0.1 µg/l	9	0	< 0.004	< 0.004	0
Pesticides Chlortoluron	P014	0.1 µg/l	1,043	0	< 0.003	< 0.004	0
Pesticides Clopyralid	P018	0.1 µg/l	469	0	< 0.004	0.0716	0
Pesticides Cyanazine	P092	0.1 µg/l	450	0	< 0.004	< 0.004	0
Pesticides Dichlorprop	P026	0.1 µg/l	579	0	< 0.002	0.003	0
Pesticides Diuron	P032	0.1 µg/l	1,000	0	< 0.006	< 0.006	0
Pesticides Flufenacet	P230	0.1 µg/l	9	0	< 0.004	0.007	0
Pesticides Fluroxypyr	P040	0.1 µg/l	9	0	< 0.003	< 0.003	0
Pesticides Glyphosate	P042	0.1 µg/l	65	0	< 0.002	< 0.005	0
Pesticides Isoproturon	P048	0.1 µg/l	1,043	0	< 0.003	0.005	0
Pesticides Linuron	P051	0.1 µg/l	981	0	< 0.003	0.00718	0
Pesticides MCPA	P054	0.1 µg/l	606	0	< 0.004	< 0.00586	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	632	0	< 0.003	0.01267	0
Pesticides Metaldehyde	P226	0.1 µg/l	264	31	< 0.003	0.3746	13
Pesticides Metazachlor	P203	0.1 µg/l	17	0	< 0.003	0.015	0
Pesticides Monuron	P113	0.1 µg/l	971	0	< 0.005	< 0.005	0
Pesticides Prometryn	P070	0.1 µg/l	894	0	< 0.003	< 0.003	0
Pesticides Propazine	P066	0.1 µg/l	937	0	< 0.002	0.004	0
Pesticides Propyzamide	P071	0.1 µg/l	469	0	< 0.002	0.0266	0
Pesticides Quinmerac	P244	0.1 µg/l	107	0	< 0.00608	0.06208	0
Pesticides Simazine	P073	0.1 µg/l	1,069	0	< 0.004	0.0173	0
Pesticides Terbutylazine	P173	0.1 µg/l	9	0	< 0.003	0.005	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Terbutryn	P077	0.1 µg/l	1,027	0	< 0.002	0.003	0
Pesticides Trietazine	P132	0.1 µg/l	1,008	0	< 0.002	0.01282	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	1,084	0	0	0.9775	0
Totals:			26,614	32			

Table ANG 7: Quality of water leaving bulk supply points - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane	D008	3 µg/l	1,084	0	< 0.042	0.36345	0
Totals:			1,084	0			

Table ANG 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	1,083	0	14.24	119
<i>Clostridium perfringens</i> (indicator)	C004A	0 number/100 ml	4,708	1	0	0
Conductivity (Indicator)	D001	2500 µS/cm	4,053	0	348.54	929.46
Gross Alpha Activity	F004	0.1 Bq/l	54	0	< 0.022	0.096
Gross Beta Activity	F005	1 Bq/l	54	0	0.029	0.307
Sulphate (Indicator)	A007	250 mg SO ₄ /l	1,082	0	10.9	196.51
Total organic carbon (indicator)	A017	No abnormal change	1,083	-n/a	0.4584	4.04
Tritium (Indicator)	F006	100 Bq/l	41	0	< 2	< 4
Totals:			12,158	1		

Table ANG 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1,2 Dichloroethane	F001	3 µg/l	22	0	< 0.12	< 0.12	0
Antimony	B008A	5 µg Sb/l	1,228	0	< 0.01	0.9342	0
Arsenic	B001A	10 µg As/l	1,228	0	< 0.144	4.0333	0
Benzene	F002	1 µg/l	22	0	< 0.06	< 0.06	0
Benzo (a) Pyrene	D007	0.01 µg/l	1,230	0	< 0.001	< 0.001	0
Boron	D005A	1 mg B/l	22	0	< 0.037	0.561	0
Bromate	F003	10 µg BrO3/l	22	0	< 0.15	1.64	0
Cadmium	B002	5 µg Cd/l	1,228	0	< 0.007	0.0771	0
Chromium	B004	50 µg Cr/l	1,228	0	< 1.5	2.7	0
Copper	A024A	2 mg Cu/l	1,229	2	0.0023	0.4948	2
Cyanide	B003	50 µg CN/l	22	0	< 1	1.41	0
<i>E.coli</i>	C002	0 number/100 ml	11,582	1	0	0	1
Enterococci	C003	0 number/100 ml	1,229	0	0	0	0
Fluoride	A027	1.5 mg F/l	22	0	0.049	0.327	0
Lead	B007A	25 µg Pb/l	1,229	0	< 0.017	9.178	0
Mercury	B005	1 µg Hg/l	22	0	< 0.029	< 0.029	0
Nickel	B006A	20 µg Ni/l	1,229	2	< 0.146	15.67	2
Nitrate	A012	50 mg NO3/l	2,380	0	0.44981	39.319	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	2,381	0	0.009	0.78636	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	2,381	0	< 0.005	0.347	0
Pesticides - Total Substances	B010	0.5 µg/l	23	0	0	0.314	0
Pesticides 2,4-D	P020	0.1 µg/l	4	0	< 0.005	< 0.005	0
Pesticides Aldrin	P002	0.03 µg/l	22	0	< 0.001	< 0.003	0
Pesticides Atrazine	P004	0.1 µg/l	22	0	< 0.002	0.014	0
Pesticides Bentazone	P006	0.1 µg/l	4	0	< 0.004	< 0.004	0
Pesticides Bromacil	P086	0.1 µg/l	4	0	< 0.003	< 0.003	0
Pesticides Carbetamide	P010	0.1 µg/l	4	0	< 0.009	0.009	0
Pesticides Chlortoluron	P014	0.1 µg/l	22	0	< 0.003	< 0.003	0
Pesticides Clopyralid	P018	0.1 µg/l	4	0	< 0.004	< 0.007	0
Pesticides Cyanazine	P092	0.1 µg/l	4	0	< 0.004	< 0.004	0
Pesticides Dichlorprop	P026	0.1 µg/l	4	0	< 0.002	< 0.002	0
Pesticides Dieldrin	P028	0.03 µg/l	22	0	< 0.001	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	22	0	< 0.006	< 0.006	0
Pesticides Heptachlor	P043	0.03 µg/l	22	0	< 0.001	< 0.003	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	22	0	< 0.001	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	22	0	< 0.003	< 0.003	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Pesticides Linuron	P051	0.1 µg/l	22	0	< 0.003	0.004	0
Pesticides MCPA	P054	0.1 µg/l	4	0	< 0.004	< 0.004	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	4	0	< 0.003	< 0.003	0
Pesticides Metaldehyde	P226	0.1 µg/l	8	1	0.026	0.314	1
Pesticides Monuron	P113	0.1 µg/l	22	0	< 0.005	< 0.005	0
Pesticides Prometryn	P070	0.1 µg/l	22	0	< 0.002	< 0.003	0
Pesticides Propazine	P066	0.1 µg/l	22	0	< 0.002	0.003	0
Pesticides Propyzamide	P071	0.1 µg/l	4	0	< 0.004	0.015	0
Pesticides Simazine	P073	0.1 µg/l	22	0	< 0.004	0.006	0
Pesticides Terbutryn	P077	0.1 µg/l	22	0	< 0.002	< 0.002	0
Pesticides Trietazine	P132	0.1 µg/l	22	0	< 0.002	< 0.002	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	1,230	0	0	0.004	0
Selenium	B009	10 µg Se/l	1,230	0	< 0.193	4.3476	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	22	0	0	3.3	0
Total Trihalomethanes	D011	100 µg/l	1,239	0	1.88	53.98	0
Totals:			34,058	6			

Table ANG 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium	A021	200 µg Al/l	2,586	0	< 2	6.026	0
Colour	A001	20 mg/l Pt/Co scale	2,711	0	< 0.34	1.6	0
Iron	A022	200 µg Fe/l	3,464	11	< 6	106.05	11
Manganese	A023	50 µg Mn/l	2,718	0	< 1	7.224	0
Organoleptic Odour	A003	0 Dilution number	3,050	13	0	0	12
Organoleptic Taste	A004	0 Dilution number	3,025	8	0	0	7
Sodium	A009	200 mg Na/l	1,228	1	8.9703	88.868	1
Tetrachloromethane	D008	3 µg/l	22	0	< 0.08	< 0.08	0
Turbidity	A002	4 nephelometric turbidity units	2,998	0	< 0.06	0.4801	0
Totals:			21,802	33			

Table ANG 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH ₄ /l	3,323	0	< 0.009	0.24576
Chloride (Indicator)	D002A	250 mg Cl/l	22	0	13.9	101
<i>Clostridium perfringens</i> (indicator)	C004A	0 number/100 ml	39	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	11,582	14	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	4,516	-n/a	0	38
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	4,516	-n/a	0	36
Conductivity (Indicator)	D001	2500 µS/cm	43	0	262	855
Gross Alpha Activity	F004	0.1 Bq/l	5	0	< 0.038	< 0.051
Gross Beta Activity	F005	1 Bq/l	5	0	0.038	0.389
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	2,706	0	7.09	7.84
Residual Disinfectant - Free	C009	No abnormal change	11,622	-n/a	0.01	0.6
Residual Disinfectant - Total	C010	No abnormal change	11,622	-n/a	0.1	0.97
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(11,622)	-(n/a)	0.01	0.87
Sulphate (Indicator)	A007	250 mg SO ₄ /l	22	0	8.29	141
Total organic carbon (indicator)	A017	No abnormal change	22	-n/a	0.3	3.95
Tritium (Indicator)	F006	100 Bq/l	22	0	< 2	< 5
Totals:			50,067	14		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.