

Data Summary Tables for South East Water (SEW)

These tables contain a summary of results of monitoring undertaken by the water company in 2012 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2012*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 11 July 2013
Drinking Water Inspectorate
Area 7e
9 Millbank
c/o Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries : 0300 068 6400

Site Summary Data for South East Water Plc

Report Date Range: For the whole year 2012

Table SEW 1: Quality of water leaving treatment works - European Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of works with failures |
|-----------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Nitrite (Works) | A013B | 0.1 mg NO ₂ /l | 625 | 0 | < 0.003 | 0.017 | 0 |
| Totals: | | | 625 | 0 | | | |

Table SEW 2: Quality of water leaving treatment works - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of works with failures |
|------------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Coliform Bacteria | C001 | 0 number/100 ml | 8,771 | 6 | 0 | 0 | 6 |
| <i>Cryptosporidium</i> | C111 | -(n/a) | 15 | -n/a | | | |
| <i>E.coli</i> | C002 | 0 number/100 ml | 8,771 | 0 | 0 | 0 | 0 |
| Totals: | | | 17,557 | 6 | | | |

Table SEW 3: Quality of water leaving treatment works - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|---|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 8,774 | -n/a | 0 | 25 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 8,774 | -n/a | 0 | 30 |
| Residual Disinfectant - Free | C009 | No abnormal change | 8,747 | -n/a | 0.06 | 1.1 |
| Residual Disinfectant - Total | C010 | No abnormal change | 8,747 | -n/a | 0.11 | 1.28 |
| Combined Chlorine/Residual Disinfectant Combined* | -(n/a) | -(n/a) | (8,747) | -(n/a) | 0.01 | 0.41 |
| Turbidity (Indicator) | A002A | 1 nephelometric turbidity units | 10,417 | 14 | < 0.1 | 0.45882 |
| Totals: | | | 45,459 | 14 | | |

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table SEW 4: Quality of water leaving service reservoirs - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of reservoirs failing standard |
|-------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|------------------------------------|
| Coliform Bacteria | C001 | 0 number/100 ml | 11,383 | 16 | 0 | 0 | 1 |
| <i>E.coli</i> | C002 | 0 number/100 ml | 11,382 | 1 | 0 | 0 | 1 |
| Totals: | | | 22,765 | 17 | | | |

Table SEW 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|---|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 11,387 | -n/a | 0 | > 300 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 11,387 | -n/a | 0 | 36 |
| Residual Disinfectant - Free | C009 | No abnormal change | 11,385 | -n/a | < 0.02 | 0.61 |
| Residual Disinfectant - Total | C010 | No abnormal change | 11,385 | -n/a | 0.05 | 0.74 |
| Combined Chlorine/Residual Disinfectant Combined* | -(n/a) | -(n/a) | (11,385) | -(n/a) | 0.01 | 0.29 |
| Totals: | | | 45,544 | 0 | | |

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table SEW 9: Quality of water at consumer's tap (zones) - European Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones failing standard |
|-------------------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|-------------------------------|
| 1,2 Dichloroethane | F001 | 3 µg/l | 573 | 0 | < 0.1 | < 0.1 | 0 |
| Antimony | B008A | 5 µg Sb/l | 574 | 0 | < 0.1 | 0.3 | 0 |
| Arsenic | B001A | 10 µg As/l | 574 | 0 | < 0.3 | 5.825 | 0 |
| Benzene | F002 | 1 µg/l | 573 | 0 | < 0.03 | < 0.03 | 0 |
| Benzo (a) Pyrene | D007 | 0.01 µg/l | 574 | 0 | < 0.001 | < 0.001 | 0 |
| Boron | D005A | 1 mg B/l | 573 | 0 | < 0.005 | 0.19226 | 0 |
| Bromate | F003 | 10 µg BrO3/l | 574 | 0 | < 0.2 | 3.525 | 0 |
| Cadmium | B002 | 5 µg Cd/l | 574 | 0 | < 0.08 | < 0.1 | 0 |
| Chromium | B004 | 50 µg Cr/l | 574 | 0 | < 0.5 | 1.75 | 0 |
| Copper | A024A | 2 mg Cu/l | 574 | 0 | < 0.005 | 0.6605 | 0 |
| Cyanide | B003 | 50 µg CN/l | 574 | 0 | < 2 | < 2 | 0 |
| <i>E. coli</i> | C002 | 0 number/100 ml | 5,270 | 0 | 0 | 0 | 0 |
| Enterococci | C003 | 0 number/100 ml | 576 | 0 | 0 | 0 | 0 |
| Fluoride | A027 | 1.5 mg F/l | 568 | 0 | 0.049 | 0.28631 | 0 |
| Lead | B007A | 25 µg Pb/l | 574 | 1 | < 0.2 | 8.4 | 1 |
| Mercury | B005 | 1 µg Hg/l | 574 | 0 | < 0.04 | 0.0825 | 0 |
| Nickel | B006A | 20 µg Ni/l | 574 | 1 | < 0.2 | 11.25 | 1 |
| Nitrate | A012 | 50 mg NO3/l | 575 | 0 | < 1 | 37 | 0 |
| Nitrate/Nitrite Formula | A013C | 1 mg NO2/l | 575 | 0 | 0 | 0.74 | 0 |
| Nitrite (Consumers tap) | A013A | 0.5 mg NO2/l | 575 | 0 | < 0.003 | 0.01548 | 0 |
| Pesticides - Total Substances | B010 | 0.5 µg/l | 636 | 1 | 0 | 0.39301 | 1 |
| Pesticides 2,4,5-T | P076 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides 2,4-D | P020 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.016 | 0 |
| Pesticides Aldrin | P002 | 0.03 µg/l | 574 | 0 | < 0.007 | 0.009 | 0 |
| Pesticides Atrazine | P004 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.0355 | 0 |
| Pesticides Bentazone | P006 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Bromoxynil | P008 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Carbendazim | P150 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Carbetamide | P010 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.01125 | 0 |
| Pesticides Chlortoluron | P014 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.0155 | 0 |
| Pesticides Dicamba | P025 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Dichlobenil | P098 | 0.1 µg/l | 574 | 0 | < 0.004 | < 0.00625 | 0 |
| Pesticides Dichlorprop | P026 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Dieldrin | P028 | 0.03 µg/l | 574 | 0 | < 0.004 | 0.00525 | 0 |
| Pesticides Diuron | P032 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.01325 | 0 |
| Pesticides Epoxyconazole | P217 | 0.1 µg/l | 574 | 0 | < 0.004 | < 0.004 | 0 |

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones failing standard |
|---|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|-------------------------------|
| Pesticides Fluroxypyr | P040 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.011 | 0 |
| Pesticides Flutriafol | P039 | 0.1 µg/l | 574 | 0 | < 0.004 | 0.008 | 0 |
| Pesticides Gamma-HCH (Lindane) | P041 | 0.1 µg/l | 574 | 0 | < 0.003 | 0.00525 | 0 |
| Pesticides Heptachlor | P043 | 0.03 µg/l | 574 | 0 | < 0.006 | 0.00725 | 0 |
| Pesticides Heptachlor epoxide | P044 | 0.03 µg/l | 574 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides Isoproturon | P048 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Linuron | P051 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides MCPA | P054 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.01625 | 0 |
| Pesticides MCPB | P055 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides MCPP(Mecoprop) | P053 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.01275 | 0 |
| Pesticides Metaldehyde | P226 | 0.1 µg/l | 169 | 15 | < 0.005 | 0.529 | 10 |
| Pesticides Oxadixyl | P154 | 0.1 µg/l | 574 | 0 | < 0.004 | 0.00925 | 0 |
| Pesticides Pendimethalin | P118 | 0.1 µg/l | 574 | 0 | < 0.004 | < 0.004 | 0 |
| Pesticides Prometryn | P070 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Propazine | P066 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Propyzamide | P071 | 0.1 µg/l | 574 | 0 | < 0.006 | < 0.009 | 0 |
| Pesticides Simazine | P073 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.017 | 0 |
| Pesticides Terbutryn | P077 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Tri-allate | P079 | 0.1 µg/l | 574 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Trichlopyr | P131 | 0.1 µg/l | 574 | 0 | < 0.01 | 0.013 | 0 |
| Pesticides Trietazine | P132 | 0.1 µg/l | 574 | 0 | < 0.01 | < 0.01 | 0 |
| Polycyclic aromatic hydrocarbons | B011F | 0.1 µg/l | 574 | 0 | 0 | 0.00325 | 0 |
| Selenium | B009 | 10 µg Se/l | 574 | 0 | < 0.3 | 2.04125 | 0 |
| Tetrachloroethene/Trichloroethene - sum of two substances | D009B | 10 µg/l | 571 | 0 | 0 | 2.7412 | 0 |
| Total Trihalomethanes | D011 | 100 µg/l | 574 | 0 | 0.3 | 85.325 | 0 |
| Totals: | | | 39,360 | 18 | | | |

Table SEW 10: Quality of water at consumer's tap (zones) - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones failing standard |
|--------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|-------------------------------|
| Aluminium | A021 | 200 µg Al/l | 907 | 0 | < 1 | 39.692 | 0 |
| Colour | A001 | 20 mg/l Pt/Co scale | 1,118 | 0 | < 1 | 3.15648 | 0 |
| Iron | A022 | 200 µg Fe/l | 1,325 | 6 | < 3 | 164.776 | 5 |
| Manganese | A023 | 50 µg Mn/l | 1,209 | 2 | < 0.2 | 16.08 | 2 |
| Organoleptic Odour | A003 | 0 Dilution number | 1,400 | 6 | 0 | 0 | 6 |
| Organoleptic Taste | A004 | 0 Dilution number | 1,399 | 3 | 0 | 0 | 3 |
| Sodium | A009 | 200 mg Na/l | 573 | 0 | 6.874 | 69.734 | 0 |
| Tetrachloromethane | D008 | 3 µg/l | 573 | 0 | < 0.04 | 0.1826 | 0 |
| Turbidity | A002 | 4 nephelometric turbidity units | 1,221 | 0 | < 0.1 | 0.85546 | 0 |
| Totals: | | | 9,725 | 17 | | | |

Table SEW 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|---|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Ammonium (Indicator) | A014 | 0.5 mg NH ₄ /l | 1,165 | 0 | < 0.01 | 0.04602 |
| Chloride (Indicator) | D002A | 250 mg Cl/l | 575 | 0 | 10.4556 | 93.782 |
| <i>Clostridium perfringens</i> (indicator) | C004A | 0 number/100 ml | 1,001 | 3 | 0 | 0 |
| Coliform Bacteria (Indicator) | C001A | 0 number/100 ml | 5,270 | 31 | 0 | 0 |
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 2,070 | -n/a | 0 | 99 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 2,064 | -n/a | 0 | 70 |
| Conductivity (Indicator) | D001 | 2500 µS/cm | 1,140 | 0 | 228.707 | 758.9 |
| Gross Alpha Activity | F004 | 0.1 Bq/l | 539 | 0 | < 0.015 | 0.0358 |
| Gross Beta Activity | F005 | 1 Bq/l | 537 | 0 | < 0.033 | 0.19234 |
| Hydrogen ion (pH) | A006 | 6.5 - 9.5 pH Value | 1,138 | 0 | 7.1 | 8.3 |
| Residual Disinfectant - Free | C009 | No abnormal change | 5,286 | -n/a | < 0.02 | 0.5613 |
| Residual Disinfectant - Total | C010 | No abnormal change | 5,285 | -n/a | 0.03 | 0.72 |
| Combined Chlorine/Residual Disinfectant Combined* | -(n/a) | -(n/a) | (5,285) | -(n/a) | 0.01 | 0.32 |
| Sulphate (Indicator) | A007 | 250 mg SO ₄ /l | 575 | 0 | 5.152 | 82.02 |
| Total organic carbon (indicator) | A017 | No abnormal change | 574 | -n/a | < 0.3 | 3.775 |
| Tritium (Indicator) | F006 | 100 Bq/l | 537 | 0 | < 5 | < 5.2 |
| Totals: | | | 27,756 | 34 | | |

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.