

Data Summary Tables for Hartlepool Water (HPL)

These tables contain a summary of results of monitoring undertaken by the water company in 2011 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2011'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables : -

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 12 July 2012
Drinking Water Inspectorate
Area 4a
Ergon House
Horseferry Road
London
SW1P 2AL

Enquiries : 0300 068 6400

Viewing Site Summary Data for Hartlepool Water Plc

Report Date Range: For the whole year 2011

Table HPL 1: Quality of water leaving service treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO ₂ /l	20	0	< 0.0014	< 0.0014	0
Totals:			20	0			

Table HPL 2: Quality of water leaving service treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	481	0	0	0	0
<i>E. coli</i>	C002	0 number/100 ml	220	0	0	0	0
Totals:			701	0			

Table HPL 3: Quality of water leaving service treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	220	-(n/a)	0	3
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	220	-(n/a)	0	8
Residual Disinfectant - Free	C009	No abnormal change	481	-(n/a)	0.32	0.5936
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	242	1	< 0.08	0.7113
Totals:			1,163	1		

Table HPL 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	298	0	0	0	0
<i>E. coli</i>	C002	0 number/100 ml	298	0	0	0	0
Totals:			596	0			

Table HPL 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	298	-(n/a)	0	1
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	298	-(n/a)	0	4
Residual Disinfectant - Free	C009	No abnormal change	298	-(n/a)	0.28	0.5201
Totals:			894	0		

Table HPL 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	20	0	< 0.049	< 0.049	0
Benzene	F002	1 µg/l	20	0	< 0.03	< 0.03	0
Boron	D005A	1 mg B/l	20	0	0.047	0.098	0
Bromate	F003	10 µg BrO3/l	20	0	< 0.97	1.5	0
Cyanide	B003	50 µg CN/l	20	0	< 0.3	4.1	0
Fluoride	A027	1.5 mg F/l	20	0	0.67	1.1	0
Mercury	B005	1 µg Hg/l	20	0	< 0.037	< 0.037	0
Pesticides - Total Substances	B010	0.5 µg/l	20	0	0	0	0
Pesticides Clopyralid	P018	0.1 µg/l	20	0	< 0.016	< 0.016	0
Pesticides Diflufenican	P157	0.1 µg/l	20	0	< 0.0089	< 0.0089	0
Pesticides Fenpropimorph	P037	0.1 µg/l	17	0	< 0.0056	< 0.0056	0
Pesticides Heptachlor	P043	0.03 µg/l	20	0	< 0.0016	< 0.0016	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	20	0	0	0	0
Pesticides Metaldehyde	P226	0.1 µg/l	20	0	< 0.0056	< 0.0056	0
Pesticides Metazachlor	P203	0.1 µg/l	20	0	< 0.0084	< 0.0084	0
Pesticides Pendimethalin	P118	0.1 µg/l	20	0	< 0.0054	< 0.0054	0
Tetrachloroethene/Trichloroethene - sum	D009B	10 µg/l	20	0	0	0	0
Totals:			337	0			

Table HPL 7: Quality of water leaving bulk supply points - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane	D008	3 µg/l	20	0	< 0.074	< 0.074	0
Totals:			20	0			

Table HPL 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	20	0	33	88
<i>Clostridium perfringens</i> (Indicator)	C004A	0 number/100 ml	20	0	0	0
Gross Alpha Activity	F004	0.1 Bq/l	20	0	0.022	0.067
Gross Beta Activity	F005	1 Bq/l	20	0	0.016	0.257
Sulphate (Indicator)	A007	250 mg SO ₄ /l	20	0	100	230
Total organic carbon (indicator)	A017	No abnormal change	20	-(n/a)	0.51	0.83
Totals:			120	0		

Table HPL 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Antimony	B008A	5 µg Sb/l	20	0	< 0.28	< 0.28	0
Arsenic	B001A	10 µg As/l	20	0	0.28	0.73	0
Benzo (a) Pyrene	D007	0.01 µg/l	20	0	< 0.00053	< 0.00053	0
Cadmium	B002	5 µg Cd/l	20	0	< 0.0081	0.023	0
Chromium	B004	50 µg Cr/l	20	0	< 0.2	1.8	0
Copper	A024A	2 mg Cu/l	20	0	0.00074	0.21	0
<i>E. coli</i>	C002	0 number/100 ml	228	0	0	0	0
Enterococci	C003	0 number/100 ml	20	0	0	0	0
Lead	B007A	25 µg Pb/l	20	0	< 0.025	2	0
Nickel	B006A	20 µg Ni/l	20	0	0.27	2.5	0
Nitrate	A012	50 mg NO ₃ /l	20	0	3.9	10	0
Nitrate/Nitrite Formula	A013C	1 mg NO ₂ /l	20	0	< 0.078	< 0.2	0
Nitrite (Consumers tap)	A013A	0.5 mg NO ₂ /l	20	0	< 0.0014	< 0.0014	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	20	0	0	0.0021	0
Selenium	B009	10 µg Se/l	20	0	< 0.31	1.1	0
Total Trihalomethanes	D011	100 µg/l	20	0	3.3	9.9	0
Totals:			528	0			

Table HPL 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Aluminium	A021	200 µg Al/l	20	0	< 2.9	< 7.3	0
Colour	A001	20 mg/l Pt/Co scale	40	0	< 1	2.5	0
Iron	A022	200 µg Fe/l	20	0	< 2.3	15	0
Manganese	A023	50 µg Mn/l	20	0	< 0.06	9.6	0
Organoleptic Odour	A003	0 Dilution number	40	0	0	0	0
Organoleptic Taste	A004	0 Dilution number	40	0	0	0	0
Sodium	A009	200 mg Na/l	20	0	37	59	0
Turbidity	A002	4 nephelometric turbidity units	40	0	< 0.08	0.3	0
Totals:			240	0			

Table HPL 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH ₄ /l	40	0	< 0.012	0.013
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	228	0	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	80	-(n/a)	0	> 300
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	80	-(n/a)	0	56
Conductivity (Indicator)	D001	2500 µS/cm	40	0	820	1100
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	40	0	7.2	8.1
Residual Disinfectant - Free	C009	No abnormal change	228	-(n/a)	0.1129	0.5342
Totals:			736	0		