

## **Data Summary Tables for Severn Trent Water Ltd (SVT)**

These tables contain a summary of results of monitoring undertaken by the water company in 2011 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2011'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables : -**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 12 July 2012  
Drinking Water Inspectorate  
Area 4a  
Ergon House  
Horseferry Road  
London  
SW1P 2AL

Enquiries : 0300 068 6400

## Viewing Site Summary Data for Severn Trent Water Ltd

Report Date Range: For the whole year 2011

**Table SVT 1: Quality of water leaving service treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	1,905	0	< 0.005	0.009	0
<b>Totals:</b>			<b>1,905</b>	<b>0</b>			

**Table SVT 2: Quality of water leaving service treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	14,559	10	0	0	10
<i>Cryptosporidium</i>	C111	-(n/a)	3,439	-(n/a)			
<i>E. coli</i>	C002	0 number/100 ml	14,559	0	0	0	0
<b>Totals:</b>			<b>32,557</b>	<b>10</b>			

**Table SVT 3: Quality of water leaving service treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	13,729	-(n/a)	0	10
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	13,729	-(n/a)	0	3
Residual Disinfectant - Free	C009	No abnormal change	14,564	-(n/a)	0.05	1.05
Residual Disinfectant - Total	C010	No abnormal change	14,564	-(n/a)	0.16	1.24
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(14,564)	-(n/a)	0.01	0.56
Turbidity (Indicator)	A002A	1 nephelometric turbidity units	14,544	9	< 0.07	0.28
<b>Totals:</b>			<b>71,130</b>	<b>9</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table SVT 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	28,123	25	0	0	0
<i>E. coli</i>	C002	0 number/100 ml	28,123	0	0	0	0
<b>Totals:</b>			<b>56,246</b>	<b>25</b>			

**Table SVT 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	28,123	-(n/a)	0	163
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	28,123	-(n/a)	0	7
Residual Disinfectant - Free	C009	No abnormal change	28,122	-(n/a)	0.03	0.58
Residual Disinfectant - Total	C010	No abnormal change	28,122	-(n/a)	0.08	0.72
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(28,122)	-(n/a)	0.01	0.49
<b>Totals:</b>			<b>112,490</b>	<b>0</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

**Table SVT 6: Quality of water leaving bulk supply points - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	1,074	0	< 0.08	< 0.08	0
Benzene	F002	1 µg/l	1,074	0	< 0.06	< 0.06	0
Boron	D005A	1 mg B/l	1,074	0	< 0.017	0.14	0
Cyanide	B003	50 µg CN/l	1,074	0	< 0.3	< 5	0
Mercury	B005	1 µg Hg/l	1,074	0	< 0.012	< 0.012	0
Pesticides - Total Substances	B010	0.5 µg/l	673	0	0	0.15126	0
Pesticides 2,3,6-Tba	P074	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides 2,4,5-T	P076	0.1 µg/l	357	0	< 0.002	< 0.005	0
Pesticides 2,4,-Db	P082	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides 2,4-D	P020	0.1 µg/l	357	0	< 0.002	0.01278	0
Pesticides Aldrin	P002	0.03 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Alpha-HCH	P003	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Ametryn	P222	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Asulam	P133	0.1 µg/l	62	0	< 0.003	< 0.007	0
Pesticides Atrazine	P004	0.1 µg/l	620	0	< 0.003	0.03179	0
Pesticides Azinphos methyl	P005	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides Benazolin	P138	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides Bentazone	P006	0.1 µg/l	357	0	< 0.002	0.03162	0
Pesticides Beta-HCH	P007	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Bromacil	P086	0.1 µg/l	620	0	< 0.004	< 0.00795	0
Pesticides Bromoxynil	P008	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides Captan	P192	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Carbendazim	P150	0.1 µg/l	620	0	< 0.002	< 0.002	0
Pesticides Carbetamide	P010	0.1 µg/l	620	0	< 0.006	< 0.006	0
Pesticides Carbophenothion	P011	0.1 µg/l	620	0	< 0.012	< 0.012	0
Pesticides Chlordane-Alpha	P089	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Chlorfenvinphos	P013	0.1 µg/l	620	0	< 0.005	< 0.005	0
Pesticides Chloromequat	P163	0.1 µg/l	149	0	< 0.004	< 0.004	0
Pesticides Chlorothalonil	P015	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Chlorpyrifos	P017	0.1 µg/l	620	0	< 0.01	< 0.01	0
Pesticides Chlorpyrifos Methyl	P019	0.1 µg/l	620	0	< 0.015	< 0.015	0
Pesticides Chlortoluron	P014	0.1 µg/l	620	0	< 0.004	0.00579	0
Pesticides Clopyralid	P018	0.1 µg/l	357	0	< 0.001	0.03526	0
Pesticides Cyanazine	P092	0.1 µg/l	620	0	< 0.005	< 0.005	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Cyfluthrin	P093	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Cypermethrin	P094	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Delta-HCH	P022	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Deltamethrin	P095	0.1 µg/l	320	0	< 0.004	< 0.004	0
Pesticides Demeton-S-Methyl	P023	0.1 µg/l	621	0	< 0.006	< 0.006	0
Pesticides Diazinon	P024	0.1 µg/l	620	0	< 0.006	< 0.006	0
Pesticides Dicamba	P025	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides Dichlobenil	P098	0.1 µg/l	320	0	< 0.001	< 0.001	0
Pesticides Dichlorprop	P026	0.1 µg/l	357	0	< 0.002	< 0.003	0
Pesticides Dichlorvos	P027	0.1 µg/l	620	0	< 0.008	< 0.008	0
Pesticides Dieldrin	P028	0.03 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Diflufenican	P157	0.1 µg/l	621	0	< 0.005	< 0.005	0
Pesticides Dimethoate	P029	0.1 µg/l	620	0	< 0.005	< 0.02	0
Pesticides Disulfoton	P031	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	620	0	< 0.003	0.008	0
Pesticides Endosulfan A (alpha-Endosulfan)	P101	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Endosulfan B (beta-Endosulfan)	P102	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Endrin	P034	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides EPTC	P035	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Ethofumersate	P221	0.1 µg/l	620	0	< 0.006	< 0.006	0
Pesticides Fenitrothion	P036	0.1 µg/l	320	0	< 0.004	< 0.004	0
Pesticides Fenoprop	P105	0.1 µg/l	357	0	< 0.002	< 0.004	0
Pesticides Fenpropidin	P168	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides Fenpropimorph	P037	0.1 µg/l	620	0	< 0.002	< 0.002	0
Pesticides Fenvalerate	P158	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Fluroxypyr	P040	0.1 µg/l	357	0	< 0.002	< 0.006	0
Pesticides Flutriafol	P039	0.1 µg/l	620	0	< 0.007	< 0.007	0
Pesticides Gamma-HCH (Lindane)	P041	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Glyphosate	P042	0.1 µg/l	16	0	< 0.006	< 0.006	0
Pesticides Heptachlor	P043	0.03 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	320	0	0	0	0
Pesticides Heptenophos	P176	0.1 µg/l	620	0	< 0.005	< 0.005	0
Pesticides Hexachlorobenzene	P045	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Hexachlorobutadiene	P108	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Ioxynil	P049	0.1 µg/l	355	0	< 0.001	< 0.003	0
Pesticides Isodrin	P047	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	620	0	< 0.002	0.00779	0
Pesticides Linuron	P051	0.1 µg/l	620	0	< 0.005	< 0.005	0
Pesticides Malathion	P052	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides MCPA	P054	0.1 µg/l	357	0	< 0.002	0.00784	0
Pesticides MCPB	P055	0.1 µg/l	357	0	< 0.002	< 0.004	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	357	0	< 0.002	0.02542	0
Pesticides Metaldehyde	P226	0.1 µg/l	362	6	< 0.003	0.13033	1
Pesticides Metamitron	P194	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Metazachlor	P203	0.1 µg/l	620	0	< 0.003	0.004	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Methoxychlor	P057	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Mevinphos	P112	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides Monuron	P113	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides op-DDD (TDE)	P114	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides op-DDE	P115	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides op-DDT	P116	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Parathion (Parathion ethyl)	P059	0.1 µg/l	620	0	< 0.006	< 0.05	0
Pesticides PCB Congener 101	P195	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides PCB Congener 118	P196	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides PCB Congener 138	P197	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides PCB Congener 153	P198	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides PCB Congener 180	P199	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides PCB Congener 28	P201	0.1 µg/l	320	0	< 0.001	< 0.001	0
Pesticides PCB Congener 52	P202	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Pendimethalin	P118	0.1 µg/l	620	0	< 0.005	0.006	0
Pesticides Permethrin-cis	P120	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides Permethrin-trans	P121	0.1 µg/l	320	0	< 0.004	< 0.004	0
Pesticides Phorate	P061	0.1 µg/l	620	0	< 0.009	< 0.02	0
Pesticides Phosalone	P062	0.1 µg/l	620	0	< 0.007	< 0.007	0
Pesticides Pirimicarb	P064	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Pirimiphos Methyl	P072	0.1 µg/l	620	0	< 0.009	< 0.009	0
Pesticides pp-DDD (TDE)	P123	0.1 µg/l	320	0	< 0.003	< 0.003	0
Pesticides pp-DDE	P124	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides pp-DDT	P125	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Prometryn	P070	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Propachlor	P126	0.1 µg/l	620	0	< 0.005	< 0.005	0
Pesticides Propazine	P066	0.1 µg/l	620	0	< 0.004	< 0.004	0
Pesticides Propetamphos	P069	0.1 µg/l	620	0	< 0.007	< 0.007	0
Pesticides Propiconazole	P068	0.1 µg/l	620	0	< 0.01	< 0.01	0
Pesticides Propyzamide	P071	0.1 µg/l	620	0	< 0.004	0.021	0
Pesticides Simazine	P073	0.1 µg/l	620	0	< 0.007	0.011	0
Pesticides Tecnazene	P130	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Terbutryn	P077	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Triadimefon	P078	0.1 µg/l	620	0	< 0.009	< 0.009	0
Pesticides Triazophos	P080	0.1 µg/l	620	0	< 0.003	< 0.003	0
Pesticides Trichlopyr	P131	0.1 µg/l	357	0	< 0.003	< 0.003	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Trichlorobenzene	P172	0.1 µg/l	320	0	< 0.002	< 0.002	0
Pesticides Trietazine	P132	0.1 µg/l	620	0	< 0.006	< 0.006	0
Pesticides Trifluralin	P081	0.1 µg/l	320	0	< 0.002	< 0.002	0
<b>Totals:</b>			<b>56,541</b>	<b>6</b>			

**Table SVT 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	1,066	0	8.8635	158
Gross Alpha Activity	F004	0.1 Bq/l	948	194	< 0.014	0.38
Gross Beta Activity	F005	1 Bq/l	948	0	0.023	0.212
Sulphate (Indicator)	A007	250 mg SO4/l	1,074	0	4.665	159.25
Total organic carbon (indicator)	A017	No abnormal change	1,074	-(n/a)	0.175	3.84
Tritium (Indicator)	F006	100 Bq/l	20	0	< 5	< 5
<b>Totals:</b>			<b>5,130</b>	<b>194</b>		

**Table SVT 9: Quality of water at consumer's tap (zones) - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
1,2 Dichloroethane	F001	3 µg/l	89	0	< 0.08	< 0.08	0
Antimony	B008A	5 µg Sb/l	1,529	0	< 0.12	0.887	0
Arsenic	B001A	10 µg As/l	1,529	0	< 0.37	6.6	0
Benzene	F002	1 µg/l	89	0	< 0.06	< 0.06	0
Benzo (a) Pyrene	D007	0.01 µg/l	1,528	2	< 0.001	< 0.001	2
Boron	D005A	1 mg B/l	90	0	< 0.017	0.097	0
Bromate	F003	10 µg BrO3/l	1,527	0	< 0.6	2.872	0
Cadmium	B002	5 µg Cd/l	1,529	0	< 0.06	0.647	0
Chromium	B004	50 µg Cr/l	1,529	0	< 0.7	1.3	0
Copper	A024A	2 mg Cu/l	1,528	0	< 0.0027	0.3813	0
Cyanide	B003	50 µg CN/l	88	0	0.69	11.4	0
<i>E. coli</i>	C002	0 number/100 ml	19,929	2	0	0	2
Enterococci	C003	0 number/100 ml	1,529	0	0	0	0
Fluoride	A027	1.5 mg F/l	1,528	0	0.04	1.04	0
Lead	B007A	25 µg Pb/l	1,531	2	< 0.5	11	2
Mercury	B005	1 µg Hg/l	88	0	< 0.012	< 0.012	0
Nickel	B006A	20 µg Ni/l	1,528	0	< 0.9	5.942	0
Nitrate	A012	50 mg NO3/l	1,824	0	1.0925	42.475	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	1,824	0	0.02	0.85	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	1,824	0	< 0.005	0.10475	0
Pesticides - Total Substances	B010	0.5 µg/l	78	0	0	0.147	0
Pesticides 2,3,6-Tba	P074	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides 2,4,5-T	P076	0.1 µg/l	74	0	< 0.002	< 0.005	0
Pesticides 2,4,-Db	P082	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides 2,4-D	P020	0.1 µg/l	74	0	< 0.002	0.01	0
Pesticides Aldrin	P002	0.03 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Alpha-HCH	P003	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Ametryn	P222	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Asulam	P133	0.1 µg/l	73	0	< 0.003	< 0.007	0
Pesticides Atrazine	P004	0.1 µg/l	78	0	< 0.003	0.024	0
Pesticides Azinphos methyl	P005	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Benazolin	P138	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides Bentazone	P006	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides Beta-HCH	P007	0.1 µg/l	78	0	< 0.002	< 0.002	0



Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Pesticides Bromacil	P086	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Bromoxynil	P008	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides Captan	P192	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Carbendazim	P150	0.1 µg/l	78	0	< 0.002	0.003	0
Pesticides Carbetamide	P010	0.1 µg/l	78	0	< 0.006	0.013	0
Pesticides Carbophenothion	P011	0.1 µg/l	78	0	< 0.012	< 0.012	0
Pesticides Chlordane-Alpha	P089	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Chlorfenvinphos	P013	0.1 µg/l	78	0	< 0.005	< 0.005	0
Pesticides Chlormequat	P163	0.1 µg/l	73	0	< 0.004	< 0.004	0
Pesticides Chlorothalonil	P015	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Chlorpyrifos	P017	0.1 µg/l	78	0	< 0.01	< 0.01	0
Pesticides Chlorpyriphos Methyl	P019	0.1 µg/l	78	0	< 0.015	< 0.015	0
Pesticides Chlortoluron	P014	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Clopyralid	P018	0.1 µg/l	74	0	< 0.001	0.046	0
Pesticides Cyanazine	P092	0.1 µg/l	78	0	< 0.005	< 0.005	0
Pesticides Cyfluthrin	P093	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Cypermethrin	P094	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Delta-HCH	P022	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Deltamethrin	P095	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Demeton-S-Methyl	P023	0.1 µg/l	78	0	< 0.006	< 0.006	0
Pesticides Diazinon	P024	0.1 µg/l	78	0	< 0.006	< 0.006	0
Pesticides Dicamba	P025	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides Dichlobenil	P098	0.1 µg/l	78	0	< 0.001	< 0.001	0
Pesticides Dichlorprop	P026	0.1 µg/l	74	0	< 0.002	< 0.003	0
Pesticides Dichlorvos	P027	0.1 µg/l	78	0	< 0.008	< 0.008	0
Pesticides Dieldrin	P028	0.03 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Diflufenican	P157	0.1 µg/l	78	0	< 0.005	< 0.005	0
Pesticides Dimethoate	P029	0.1 µg/l	78	0	< 0.005	< 0.02	0
Pesticides Disulfoton	P031	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Endosulfan A (alpha-Endosulfan)	P101	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Endosulfan B (beta-Endosulfan)	P102	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Endrin	P034	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides EPTC	P035	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Ethofumersate	P221	0.1 µg/l	78	0	< 0.006	< 0.006	0
Pesticides Fenitrothion	P036	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Fenoprop	P105	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides Fenpropidin	P168	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Fenpropimorph	P037	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Fenvalerate	P158	0.1 µg/l	78	0	< 0.003	< 0.003	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Pesticides Fluroxypyr	P040	0.1 µg/l	74	0	< 0.002	< 0.006	0
Pesticides Flutriafol	P039	0.1 µg/l	78	0	< 0.007	< 0.007	0
Pesticides Gamma-HCH (Lindane)	P041	0.1 µg/l	78	0	< 0.002	0.008	0
Pesticides Heptachlor	P043	0.03 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	78	0	0	0	0
Pesticides Heptenophos	P176	0.1 µg/l	78	0	< 0.005	0.006	0
Pesticides Hexachlorobenzene	P045	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Hexachlorobutadiene	P108	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Ioxynil	P049	0.1 µg/l	74	0	< 0.001	< 0.003	0
Pesticides Isodrin	P047	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Linuron	P051	0.1 µg/l	78	0	< 0.005	< 0.005	0
Pesticides Malathion	P052	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides MCPA	P054	0.1 µg/l	74	0	< 0.002	0.018	0
Pesticides MCPB	P055	0.1 µg/l	74	0	< 0.002	< 0.004	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	74	0	< 0.002	0.024	0
Pesticides Metaldehyde	P226	0.1 µg/l	73	1	< 0.003	0.128	1
Pesticides Metamitron	P194	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Metazachlor	P203	0.1 µg/l	78	0	< 0.003	0.004	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Methoxychlor	P057	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Mevinphos	P112	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Monuron	P113	0.1 µg/l	78	0	< 0.004	0.008	0
Pesticides op-DDD (TDE)	P114	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides op-DDE	P115	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides op-DDT	P116	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Parathion (Parathion ethyl)	P059	0.1 µg/l	78	0	< 0.006	< 0.05	0
Pesticides PCB Congener 101	P195	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides PCB Congener 118	P196	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides PCB Congener 138	P197	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides PCB Congener 153	P198	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides PCB Congener 180	P199	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides PCB Congener 28	P201	0.1 µg/l	78	0	< 0.001	< 0.001	0
Pesticides PCB Congener 52	P202	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Pendimethalin	P118	0.1 µg/l	78	0	< 0.005	0.01	0
Pesticides Permethrin-cis	P120	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Permethrin-trans	P121	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Phorate	P061	0.1 µg/l	78	0	< 0.009	< 0.02	0
Pesticides Phosalone	P062	0.1 µg/l	78	0	< 0.007	< 0.007	0
Pesticides Pirimicarb	P064	0.1 µg/l	78	0	< 0.003	< 0.003	0

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Pesticides Pirimiphos Methyl	P072	0.1 µg/l	78	0	< 0.009	< 0.009	0
Pesticides pp-DDD (TDE)	P123	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides pp-DDE	P124	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides pp-DDT	P125	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Prometryn	P070	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Propachlor	P126	0.1 µg/l	78	0	< 0.005	< 0.005	0
Pesticides Propazine	P066	0.1 µg/l	78	0	< 0.004	< 0.004	0
Pesticides Propetamphos	P069	0.1 µg/l	78	0	< 0.007	< 0.007	0
Pesticides Propiconazole	P068	0.1 µg/l	78	0	< 0.01	< 0.01	0
Pesticides Propyzamide	P071	0.1 µg/l	78	0	< 0.004	0.009	0
Pesticides Simazine	P073	0.1 µg/l	78	0	< 0.007	< 0.007	0
Pesticides Tecnazene	P130	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Terbutryn	P077	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Triadimefon	P078	0.1 µg/l	78	0	< 0.009	< 0.009	0
Pesticides Triazophos	P080	0.1 µg/l	78	0	< 0.003	< 0.003	0
Pesticides Trichlopyr	P131	0.1 µg/l	74	0	< 0.003	< 0.003	0
Pesticides Trichlorobenzene	P172	0.1 µg/l	78	0	< 0.002	< 0.002	0
Pesticides Trietazine	P132	0.1 µg/l	78	0	< 0.006	< 0.006	0
Pesticides Trifluralin	P081	0.1 µg/l	78	0	< 0.002	< 0.002	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	1,528	0	0	0	0
Selenium	B009	10 µg Se/l	1,529	0	< 0.22	1.87	0
Tetrachloroethene/Trichloroethene - sum	D009B	10 µg/l	1,528	0	0	1.6726	0
Total Trihalomethanes	D011	100 µg/l	1,527	0	0.12	60.0844	0
<b>Totals:</b>			<b>57,503</b>	<b>7</b>			

**Table SVT 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Aluminium	A021	200 µg Al/l	5,354	2	< 5	41	2
Colour	A001	20 mg/l Pt/Co scale	4,452	0	< 0.5	3.1	0
Iron	A022	200 µg Fe/l	5,894	16	< 10	96.05	16
Manganese	A023	50 µg Mn/l	4,934	5	< 1.8	8.03	5
Organoleptic Odour	A003	0 Dilution number	5,358	12	0	0	12
Organoleptic Taste	A004	0 Dilution number	5,356	3	0	0	3
Sodium	A009	200 mg Na/l	1,529	0	5.93	107.4	0
Tetrachloromethane	D008	3 µg/l	1,528	0	< 0.018	< 0.03	0
Turbidity	A002	4 nephelometric turbidity units	5,210	1	< 0.07	0.41	1
<b>Totals:</b>			<b>39,615</b>	<b>39</b>			

**Table SVT 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	4,579	0	< 0.015	0.0928
Chloride (Indicator)	D002A	250 mg Cl/l	104	0	7.2715	125
<i>Clostridium perfringens</i> (Indicator)	C004A	0 number/100 ml	4,206	1	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	19,930	37	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	7,064	-(n/a)	0	71
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	7,064	-(n/a)	0	39
Conductivity (Indicator)	D001	2500 µS/cm	4,314	0	115	817
Gross Alpha Activity	F004	0.1 Bq/l	72	11	< 0.014	0.193
Gross Beta Activity	F005	1 Bq/l	72	0	0.012	0.24
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	6,280	6	6.86	8.92
Residual Disinfectant - Free	C009	No abnormal change	19,933	-(n/a)	0.02	0.5
Residual Disinfectant - Total	C010	No abnormal change	19,933	-(n/a)	0.06	0.62
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(19,933)	-(n/a)	0.01	0.32
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	89	0	3.46	132
Total organic carbon (indicator)	A017	No abnormal change	88	-(n/a)	0.31	3.85
Tritium (Indicator)	F006	100 Bq/l	45	0	< 5	< 5
<b>Totals:</b>			<b>93,773</b>	<b>55</b>		

\*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.