

Data Summary Tables for Veolia Water Central (VCE)

These tables contain a summary of results of monitoring undertaken by the water company in 2011 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2011'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables : -

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 12 July 2012
Drinking Water Inspectorate
Area 4a
Ergon House
Horseferry Road
London
SW1P 2AL

Enquiries : 0300 068 6400

Viewing Site Summary Data for Veolia Water Central

Report Date Range: For the whole year 2011

Table VCE 1: Quality of water leaving service treatment works - European Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of works with failures |
|-----------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Nitrite (Works) | A013B | 0.1 mg NO ₂ /l | 1,008 | 1 | < 0.008 | < 0.008 | 1 |
| Totals: | | | 1,008 | 1 | | | |

Table VCE 2: Quality of water leaving service treatment works - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of works with failures |
|------------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Coliform Bacteria | C001 | 0 number/100 ml | 13,013 | 3 | 0 | 0 | 3 |
| <i>Cryptosporidium</i> | C111 | -(n/a) | 730 | -(n/a) | | | |
| <i>E. coli</i> | C002 | 0 number/100 ml | 13,013 | 0 | 0 | 0 | 0 |
| Totals: | | | 26,756 | 3 | | | |

Table VCE 3: Quality of water leaving service treatment works - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|--|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 13,012 | -(n/a) | 0 | 6 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 13,012 | -(n/a) | 0 | 6 |
| Residual Disinfectant - Total | C010 | No abnormal change | 13,013 | -(n/a) | 0.1 | 0.96 |
| Turbidity (Indicator) | A002A | 1 nephelometric turbidity units | 13,013 | 1 | 0.05 | 0.37 |
| Totals: | | | 52,050 | 1 | | |

Table VCE 4: Quality of water leaving service reservoirs - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of reservoirs failing standard |
|-------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|------------------------------------|
| Coliform Bacteria | C001 | 0 number/100 ml | 6,785 | 2 | 0 | 0 | 0 |
| <i>E. coli</i> | C002 | 0 number/100 ml | 6,785 | 1 | 0 | 0 | 1 |
| Totals: | | | 13,570 | 3 | | | |

Table VCE 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|--|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 6,785 | -(n/a) | 0 | 299 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 6,785 | -(n/a) | 0 | 6 |
| Residual Disinfectant - Total | C010 | No abnormal change | 6,785 | -(n/a) | 0.02 | 0.58 |
| Totals: | | | 20,355 | 0 | | |

Table VCE 9: Quality of water at consumer's tap (zones) - European Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones with failures |
|-------------------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| 1,2 Dichloroethane | F001 | 3 µg/l | 528 | 0 | < 0.09 | < 0.1 | 0 |
| Antimony | B008A | 5 µg Sb/l | 529 | 0 | < 0.2 | 0.439 | 0 |
| Arsenic | B001A | 10 µg As/l | 529 | 0 | < 1 | 1.358 | 0 |
| Benzene | F002 | 1 µg/l | 528 | 0 | < 0.01 | 0.02 | 0 |
| Benzo (a) Pyrene | D007 | 0.01 µg/l | 529 | 0 | < 0.0005 | 0.00161 | 0 |
| Boron | D005A | 1 mg B/l | 531 | 0 | < 0.1 | 0.4468 | 0 |
| Bromate | F003 | 10 µg BrO3/l | 545 | 0 | < 0.5 | 2.954 | 0 |
| Cadmium | B002 | 5 µg Cd/l | 529 | 0 | < 0.2 | < 0.2 | 0 |
| Chromium | B004 | 50 µg Cr/l | 529 | 0 | < 2 | 3.613 | 0 |
| Copper | A024A | 2 mg Cu/l | 529 | 0 | < 0.01 | 0.5748 | 0 |
| Cyanide | B003 | 50 µg CN/l | 529 | 0 | < 3 | 6.42 | 0 |
| <i>E. coli</i> | C002 | 0 number/100 ml | 7,829 | 1 | 0 | 0 | 1 |
| Enterococci | C003 | 0 number/100 ml | 529 | 0 | 0 | 0 | 0 |
| Fluoride | A027 | 1.5 mg F/l | 529 | 0 | 0.075 | 0.7113 | 0 |
| Lead | B007A | 25 µg Pb/l | 529 | 1 | < 1 | 8.875 | 1 |
| Mercury | B005 | 1 µg Hg/l | 528 | 0 | < 0.1 | < 0.1 | 0 |
| Nickel | B006A | 20 µg Ni/l | 529 | 0 | < 2 | 5.215 | 0 |
| Nitrate | A012 | 50 mg NO3/l | 832 | 0 | < 2 | 42.667 | 0 |
| Nitrate/Nitrite Formula | A013C | 1 mg NO2/l | 829 | 0 | 0 | < 0.8534 | 0 |
| Nitrite (Consumers tap) | A013A | 0.5 mg NO2/l | 831 | 0 | < 0.008 | 0.0668 | 0 |
| Pesticides - Total Substances | B010 | 0.5 µg/l | 543 | 0 | 0 | 0.16972 | 0 |
| Pesticides 2,4-D | P020 | 0.1 µg/l | 530 | 0 | < 0.008 | 0.02038 | 0 |
| Pesticides Aldrin | P002 | 0.03 µg/l | 1 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Atrazine | P004 | 0.1 µg/l | 530 | 0 | < 0.007 | 0.042 | 0 |
| Pesticides Bentazone | P006 | 0.1 µg/l | 530 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides Bromacil | P086 | 0.1 µg/l | 40 | 0 | < 0.01 | < 0.01 | 0 |
| Pesticides Carbendazim | P150 | 0.1 µg/l | 204 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Carbetamide | P010 | 0.1 µg/l | 506 | 0 | < 0.008 | 0.04265 | 0 |
| Pesticides Chlortoluron | P014 | 0.1 µg/l | 529 | 0 | < 0.007 | 0.0117 | 0 |
| Pesticides Clopyralid | P018 | 0.1 µg/l | 530 | 0 | < 0.008 | 0.031 | 0 |
| Pesticides Cyanazine | P092 | 0.1 µg/l | 530 | 0 | < 0.007 | < 0.007 | 0 |
| Pesticides Dicamba | P025 | 0.1 µg/l | 530 | 0 | < 0.007 | < 0.007 | 0 |
| Pesticides Dichlobenil | P098 | 0.1 µg/l | 268 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Dichlorprop | P026 | 0.1 µg/l | 530 | 0 | < 0.008 | < 0.008 | 0 |

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones with failures |
|---|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Pesticides Dieldrin | P028 | 0.03 µg/l | 1 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Diuron | P032 | 0.1 µg/l | 530 | 0 | < 0.006 | 0.01038 | 0 |
| Pesticides Fenpropimorph | P037 | 0.1 µg/l | 63 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Fluroxypyr | P040 | 0.1 µg/l | 530 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides Flutriafol | P039 | 0.1 µg/l | 40 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Glyphosate | P042 | 0.1 µg/l | 205 | 0 | < 0.006 | 0.04262 | 0 |
| Pesticides Heptachlor | P043 | 0.03 µg/l | 1 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Heptachlor epoxide | P044 | 0.03 µg/l | 1 | 0 | < 0.007 | < 0.007 | 0 |
| Pesticides Isoproturon | P048 | 0.1 µg/l | 530 | 0 | < 0.006 | < 0.006 | 0 |
| Pesticides Linuron | P051 | 0.1 µg/l | 531 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides MCPA | P054 | 0.1 µg/l | 529 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides MCPB | P055 | 0.1 µg/l | 530 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides MCPP(Mecoprop) | P053 | 0.1 µg/l | 530 | 0 | < 0.008 | 0.01469 | 0 |
| Pesticides Metaldehyde | P226 | 0.1 µg/l | 245 | 3 | < 0.012 | 0.12926 | 1 |
| Pesticides Metazachlor | P203 | 0.1 µg/l | 204 | 0 | < 0.008 | 0.00895 | 0 |
| Pesticides Methabenzthiazuron | P167 | 0.1 µg/l | 465 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Prometryn | P070 | 0.1 µg/l | 204 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides Propazine | P066 | 0.1 µg/l | 261 | 0 | < 0.007 | 0.009 | 0 |
| Pesticides Propyzamide | P071 | 0.1 µg/l | 244 | 1 | < 0.006 | 0.08845 | 1 |
| Pesticides Simazine | P073 | 0.1 µg/l | 530 | 0 | < 0.008 | 0.02469 | 0 |
| Pesticides Tecnazene | P130 | 0.1 µg/l | 24 | 0 | < 0.007 | < 0.007 | 0 |
| Pesticides Terbutryn | P077 | 0.1 µg/l | 505 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Tri-allate | P079 | 0.1 µg/l | 244 | 0 | < 0.009 | < 0.009 | 0 |
| Pesticides Trietazine | P132 | 0.1 µg/l | 530 | 0 | < 0.008 | < 0.008 | 0 |
| Pesticides Trifluralin | P081 | 0.1 µg/l | 24 | 0 | < 0.007 | < 0.007 | 0 |
| Polycyclic aromatic hydrocarbons | B011F | 0.1 µg/l | 529 | 0 | 0 | 0.00604 | 0 |
| Selenium | B009 | 10 µg Se/l | 529 | 0 | < 1 | 1.955 | 0 |
| Tetrachloroethene/Trichloroethene - sum | D009B | 10 µg/l | 528 | 0 | 0 | 4.9868 | 0 |
| Total Trihalomethanes | D011 | 100 µg/l | 528 | 0 | 0 | 49.013 | 0 |
| Totals: | | | 34,216 | 6 | | | |

Table VCE 10: Quality of water at consumer's tap (zones) - National Standards

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests Failed | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) | No. of zones with failures |
|--------------------|----------------|-----------------------------------|-----------------------|--------------|---------------------------------------|--|----------------------------|
| Aluminium | A021 | 200 µg Al/l | 1,635 | 3 | < 5 | 108.28 | 2 |
| Colour | A001 | 20 mg/l Pt/Co scale | 1,448 | 0 | 1 | 2.2 | 0 |
| Iron | A022 | 200 µg Fe/l | 1,987 | 3 | < 15 | 107.12 | 3 |
| Manganese | A023 | 50 µg Mn/l | 1,462 | 0 | < 2 | 5.594 | 0 |
| Organoleptic Odour | A003 | 0 Dilution number | 1,412 | 1 | 0 | 0 | 1 |
| Organoleptic Taste | A004 | 0 Dilution number | 1,410 | 0 | 0 | 0 | 0 |
| Sodium | A009 | 200 mg Na/l | 529 | 0 | 7.421 | 50.94 | 0 |
| Tetrachloromethane | D008 | 3 µg/l | 528 | 0 | < 0.11 | < 0.12 | 0 |
| Turbidity | A002 | 4 nephelometric turbidity units | 2,758 | 1 | 0.06 | 0.4441 | 1 |
| Totals: | | | 13,169 | 8 | | | |

Table VCE 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

| Parameter Name | Parameter Code | Prescribed Concentration or Value | Total Number of Tests | Tests exceeding specification | 1 percentile (representing a minimum) | 99 percentile (representing a maximum) |
|--|----------------|-----------------------------------|-----------------------|-------------------------------|---------------------------------------|--|
| Ammonium (Indicator) | A014 | 0.5 mg NH ₄ /l | 1,487 | 0 | < 0.04 | 0.08 |
| Chloride (Indicator) | D002A | 250 mg Cl/l | 529 | 0 | 16 | 73.7 |
| <i>Clostridium perfringens</i> (Indicator) | C004A | 0 number/100 ml | 2,018 | 2 | 0 | 0 |
| Coliform Bacteria (Indicator) | C001A | 0 number/100 ml | 7,829 | 12 | 0 | 0 |
| Colony Counts After 3 Days At 22°C (Indicator) | C007 | No abnormal change | 2,758 | -(n/a) | 0 | 117 |
| Colony Counts After 48 Hours At 37°C (Indicator) | C013 | No abnormal change | 2,758 | -(n/a) | 0 | 130 |
| Conductivity (Indicator) | D001 | 2500 µS/cm | 2,758 | 0 | 479.18 | 771 |
| Gross Alpha Activity | F004 | 0.1 Bq/l | 1 | 0 | < 0.014 | < 0.014 |
| Gross Beta Activity | F005 | 1 Bq/l | 1 | 0 | 0.161 | 0.161 |
| Hydrogen ion (pH) | A006 | 6.5 - 9.5 pH Value | 2,758 | 0 | 7 | 7.8 |
| Residual Disinfectant - Total | C010 | No abnormal change | 7,829 | -(n/a) | 0.05 | 0.78 |
| Sulphate (Indicator) | A007 | 250 mg SO ₄ /l | 529 | 0 | 6 | 112.1 |
| Total organic carbon (indicator) | A017 | No abnormal change | 529 | -(n/a) | 0.33 | 3.8 |
| Tritium (Indicator) | F006 | 100 Bq/l | 1 | 0 | < 5 | < 5 |
| Totals: | | | 31,785 | 14 | | |