

Data Summary Tables for Independent Water Networks Limited (IWN)

These tables contain a summary of results of monitoring undertaken by the water company in 2010 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2010'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

Notes relating to the interpretation of the tables : -

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 7 July 2011
Drinking Water Inspectorate
Area 4a
Ergon House
Horseferry Road
London
SW1P 2AL

Enquiries : 030 0068 6400

Viewing Site Summary Data for Independent Water Networks

Report Date Range: For the whole year 2010

Table IWN 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides 2,4-D	P020	0.1 µg/l	69	0	0.005	0.014	0
Pesticides Atrazine	P004	0.1 µg/l	69	0	0.002	0.006	0
Pesticides Bentazone	P006	0.1 µg/l	69	0	< 0.004	< 0.009	0
Pesticides Bromacil	P086	0.1 µg/l	69	0	< 0.003	< 0.006	0
Pesticides Carbetamide	P010	0.1 µg/l	69	0	< 0.009	< 0.013	0
Pesticides Chlortoluron	P014	0.1 µg/l	69	0	< 0.003	< 0.004	0
Pesticides Clopyralid	P018	0.1 µg/l	69	0	0.007	0.048	0
Pesticides Cyanazine	P092	0.1 µg/l	69	0	< 0.004	< 0.004	0
Pesticides Dichlorprop	P026	0.1 µg/l	69	0	< 0.002	< 0.002	0
Pesticides Diuron	P032	0.1 µg/l	69	0	< 0.006	< 0.006	0
Pesticides Glyphosate	P042	0.1 µg/l	26	0	< 0.002	< 0.009	0
Pesticides Isoproturon	P048	0.1 µg/l	69	0	< 0.003	< 0.034	0
Pesticides Linuron	P051	0.1 µg/l	69	0	< 0.003	< 0.003	0
Pesticides MCPA	P054	0.1 µg/l	69	0	< 0.004	< 0.004	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	69	0	0.003	0.02	0
Pesticides Monuron	P113	0.1 µg/l	69	0	< 0.005	< 0.005	0
Pesticides Prometryn	P070	0.1 µg/l	69	0	< 0.003	< 0.003	0
Pesticides Propazine	P066	0.1 µg/l	69	0	< 0.002	< 0.003	0
Pesticides Propyzamide	P071	0.1 µg/l	69	0	0.004	0.032	0
Pesticides Quinmerac	P244	0.1 µg/l	69	0	0.006	0.036	0
Pesticides Simazine	P073	0.1 µg/l	69	0	0.004	0.011	0
Pesticides Terbutryn	P077	0.1 µg/l	69	0	< 0.002	< 0.002	0
Pesticides Trietazine	P132	0.1 µg/l	69	0	< 0.002	< 0.002	0
Totals:			1,544	0			

Table IWN 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
1,2 Dichloroethane	F001	3 µg/l	16	0	< 0.08	< 0.08	0
Antimony	B008A	5 µg Sb/l	16	0	< 0.12	< 0.56	0
Arsenic	B001A	10 µg As/l	16	0	< 0.37	< 1.3	0
Benzene	F002	1 µg/l	16	0	< 0.06	< 0.06	0
Benzo (a) Pyrene	D007	0.01 µg/l	16	0	< 0.001	< 0.004	0
Boron	D005A	1 mg B/l	16	0	0.03	0.098	0
Bromate	F003	10 µg BrO3/l	16	0	< 0.3	< 0.6	0
Cadmium	B002	5 µg Cd/l	16	0	< 0.006	< 0.06	0
Chromium	B004	50 µg Cr/l	16	0	< 0.7	< 0.7	0
Copper	A024A	2 mg Cu/l	16	0	< 0.003	< 0.026	0
Cyanide	B003	50 µg CN/l	16	0	0.4	3.1	0
E Coli	C002	0 number/100 ml	50	0	0	0	0
Enterococci	C003	0 number/100 ml	24	0	0	0	0
Fluoride	A027	1.5 mg F/l	16	0	0.12	0.288	0
Lead	B007A	25 µg Pb/l	16	0	< 0.5	< 4.9	0
Mercury	B005	1 µg Hg/l	16	0	< 0.012	< 0.012	0
Nickel	B006A	20 µg Ni/l	16	0	1.5	11	0
Nitrate	A012	50 mg NO3/l	32	0	9.26	34.8	0
Nitrate/Nitrite Formula	A013C	1 mg NO2/l	32	0	0.23	0.7	0
Nitrite (Consumers tap)	A013A	0.5 mg NO2/l	32	0	0.003	0.293	0
Pesticides - Total Substances	B010	0.5 µg/l	16	0	0.007	0.105	0
Pesticides 2,3,6-Tba	P074	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides 2,4,5-T	P076	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides 2,4,-Db	P082	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides 2,4-D	P020	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Aldrin	P002	0.03 µg/l	16	0	< 0.003	< 0.003	0
Pesticides Ametryn	P222	0.1 µg/l	2	0	< 0.003	< 0.003	0
Pesticides Atrazine	P004	0.1 µg/l	2	0	< 0.003	< 0.004	0
Pesticides Bentazone	P006	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Bromoxynil	P008	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Carbendazim	P150	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Carbetamide	P010	0.1 µg/l	2	0	< 0.006	< 0.006	0
Pesticides Chlortoluron	P014	0.1 µg/l	2	0	< 0.004	< 0.004	0
Pesticides Clopyralid	P018	0.1 µg/l	2	0	< 0.001	< 0.001	0
Pesticides Dicamba	P025	0.1 µg/l	2	0	< 0.002	< 0.002	0

Pesticides Dichlobenil	P098	0.1 µg/l	2	0	< 0.001	< 0.001	0
Pesticides Dichlorprop	P026	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Dieldrin	P028	0.03 µg/l	16	0	< 0.002	< 0.002	0
Pesticides Diflufenican	P157	0.1 µg/l	2	0	< 0.005	< 0.005	0
Pesticides Diuron	P032	0.1 µg/l	2	0	< 0.003	< 0.003	0
Pesticides Fenoprop	P105	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Fluroxypyr	P040	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Heptachlor	P043	0.03 µg/l	16	0	< 0.002	< 0.002	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	16	0	< 0.002	< 0.002	0
Pesticides Ioxynil	P049	0.1 µg/l	2	0	< 0.001	< 0.001	0
Pesticides Isoproturon	P048	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Linuron	P051	0.1 µg/l	2	0	< 0.005	< 0.005	0
Pesticides MCPA	P054	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides MCPB	P055	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Metaldehyde	P226	0.1 µg/l	16	1	0.003	0.105	1
Pesticides Metazachlor	P203	0.1 µg/l	2	0	< 0.003	< 0.003	0
Pesticides Monuron	P113	0.1 µg/l	2	0	< 0.004	< 0.004	0
Pesticides Pentachlorophenol	P060	0.1 µg/l	2	0	< 0.002	< 0.002	0
Pesticides Picloram	P122	0.1 µg/l	2	0	< 0.02	< 0.02	0
Pesticides Prometryn	P070	0.1 µg/l	2	0	< 0.003	< 0.003	0
Pesticides Propazine	P066	0.1 µg/l	2	0	< 0.004	< 0.004	0
Pesticides Propyzamide	P071	0.1 µg/l	2	0	< 0.004	< 0.004	0
Pesticides Simazine	P073	0.1 µg/l	2	0	< 0.007	< 0.007	0
Pesticides Terbutryn	P077	0.1 µg/l	2	0	< 0.003	< 0.003	0
Pesticides Trichlopyr	P131	0.1 µg/l	2	0	< 0.003	< 0.003	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	16	0	0	0.021	0
Selenium	B009	10 µg Se/l	16	0	0.22	0.91	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	16	0	< 0.1	< 0.16	0
Total Trihalomethanes	D011	100 µg/l	16	0	6.26	28.8	0
Totals:			640	1			

Table IWN 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Aluminium	A021	200 µg Al/l	31	0	< 5	< 6	0
Colour	A001	20 mg/l Pt/Co scale	32	0	< 0.4	< 1.5	0
Iron	A022	200 µg Fe/l	31	0	10	16	0
Manganese	A023	50 µg Mn/l	31	0	< 1.8	< 1.8	0
Organoleptic Odour	A003	0 Dilution number	32	0	0	0	0
Organoleptic Taste	A004	0 Dilution number	32	0	0	0	0
Sodium	A009	200 mg Na/l	16	0	23	50	0
Tetrachloromethane	D008	3 µg/l	16	0	< 0.03	< 0.03	0
Turbidity	A002	4 nephelometric turbidity units	32	0	0.003	0.13	0
Totals:			253	0			

Table IWN 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH ₄ /l	32	0	0.011	0.186
Chloride (Indicator)	D002A	250 mg Cl/l	16	0	44.9	76.8
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	32	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	50	1	0	1
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	32	n/a	1	1000
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	32	n/a	0	624
Conductivity (Indicator)	D001	2500 µS/cm	28	0	532	728
Gross Alpha Activity	F004	0.1 Bq/l	16	0	< 0.005	< 0.027
Gross Beta Activity	F005	1 Bq/l	16	0	0.047	0.287
Hydrogen ion (pH)	A006	6.5 - 9.5 pH Value	32	0	7.15	7.91
Residual Disinfectant - Total	C010	No abnormal change	50	n/a	0.02	1.01
Sulphate (Indicator)	A007	250 mg SO ₄ /l	16	0	31.2	133
Total organic carbon (indicator)	A017	No abnormal change	16	n/a	0.5	3.86
Tritium (Indicator)	F006	100 Bq/l	16	0	< 5	< 5
Totals:			384	1		