

# LIST OF APPROVED PRODUCTS FOR USE IN PUBLIC WATER SUPPLY IN THE UNITED KINGDOM

All approved products must be used in accordance with the specific conditions of approval, listed against the product names in Parts A-E. In addition, the following general conditions of approval apply to all approved products:

1. That use is in accordance with an Instructions for Use document. Approval holders must provide drinking water suppliers with copies of the Instructions for Use Document that was considered by the Drinking Water Inspectorate (DWI) when approval was recommended.
2. That the approval of the Authorities is obtained on condition that there shall be:
  - no change in the formulation of the approved product, including change in the source or identity of raw materials
  - no change in the manufacturing process, including location of manufacture
  - no change in designation of the approved product
  - no change in name or ownership of the organisation holding the approval
3. That the producer shall ensure that the product is tested for conformity with its formulation, and the source or identity of its raw materials, at such intervals and by such persons, as may be determined by the Authorities. The results of such testing shall be sent to the Authorities.
4. If there is suspicion that any of the above is not being followed or has been changed then notify DWI Regulation 31 team who will investigate ([reg31.enquiries@defra.gov.uk](mailto:reg31.enquiries@defra.gov.uk))
5. That the approval is still valid

# Contents

<b>Part A</b>	<b>Chemicals and Filter Media</b>	<b>4</b>
A.1	Flocculants and Coagulants	4
A.1.1	Products based on tannin	4
A.1.2	Products based on polyacrylamide	4
A.1.3	Products based on iron	5
A.2	Adsorbents	5
A.3	Ion Exchange Resins Systems	5
A.3.1	Ion exchange resins	5
A.3.2	Ion exchange resin based processes	6
A.5	Disinfection or Cleaning Agents of Membranes	7
A.6	Disinfectants for Emergency Use	11
A.7	Products Based on Traditional Chemicals	11
A.7.1	Traditional Chemicals	11
A.7.2	On-site electrolytic generation of chlorine	12
A.7.3	On-site generation of chlorine dioxide	14
A.9	Other Chemicals	14
A.10	Filter Media	16
<b>Part B</b>	<b>Products for Conveyance of Water</b>	<b>17</b>
B.1	Pipes	17
B.1.1	Polyethylene (PE) pipes	17
B.1.2	Polyethylene Barrier pipes	22
B.1.3	Polyvinylchloride (PVC) pipes	23
B.1.4	Acrylonitrile-butadiene-styrene copolymer (ABS)	25
B.1.5	Polyethylene terephthalate (PET)	26
B.1.6	Glass reinforced plastic (GRP) pipes	26
B.1.7	Cement mortar lined pipes	26
B.1.7.1	Cement mortar lined pipes without seal coat	26
B.1.7.2	Cement mortar lined pipes with seal coat	28
B.1.8	Pipes coated with factory applied nylon resins	29
B.1.9	Pipes coated with factory applied epoxy resin	29
B.1.10	Stainless steel pipes	31
B.1.11	Coated pipes suitable for total immersion in water	35
B.1.12	Pipes coated with a factory applied polyolefin	36
B.2	Well Casings, Screens and Rising Mains	36
B.3	Products for Conveyance of Water -Emergency Use	38
B.3.1	Hoses	38
B.3.2	Bowsers/tanks	39
B.3.3	Liner bags	39
<b>Part C</b>	<b>Lining, Coatings, Sealant and Repair Materials</b>	<b>40</b>
C.1	In-situ Installed (tubular) pipe linings	40
C.2	In-situ applied Pipe Coatings	40
C.2.1	Coatings based on epoxy resins	40

List of approved products for use in public water supply in the United Kingdom

---

C.2.2	Coatings based on polyurethane.....	41
C.2.3	Coatings for small diameter pipes .....	41
C.3	Site applied coatings for water retaining structures.....	42
C.3.1	Coatings based on epoxy resins .....	42
C.3.2	Coatings based on polyurethane.....	43
C.4	Flexible covers and linings for water retaining structures .....	44
C.5	Cementitious coatings .....	45
C.6	Sealant & Repair Materials.....	48
<b>Part D</b>	<b>Membrane and Filtration Systems.....</b>	<b>54</b>
D.1	Membrane and Filtration Elements/Systems.....	54
D.2	Vessels and Containers for Membrane and Filtration Elements.....	59
D.3	Electrodialysis Water Treatment Units.....	61
D.4	Filter Media Containing Systems .....	61
<b>Part E</b>	<b>Other Water Treatment Works Installations.....</b>	<b>62</b>
E.1	Tanks.....	62
E.2	Underdrains .....	66
E.3	Pressure vessels .....	68
E.4	Other Products used for the treatment of water.....	69
	<b>Index by Product Name .....</b>	<b>75</b>

## PART A CHEMICALS AND FILTER MEDIA

It is the responsibility of the drinking water suppliers to ensure that

(a) the method and manner of use; and

(b) the purity of these chemicals and products are such that the water treated meets the requirements of the relevant regulations. Where appropriate, additional specific conditions of approval are listed against the chemical or product.

Approval holders and water companies should be aware that products or substances that claim to have a biocidal effect or are used as biocides may require authorisation under the Biocidal Products Regulation. HSE is the UK competent authority for the Biocidal Products Regulation and so any queries about whether that legislation applies to a specific product or substance should be addressed to [biocidesenquiries@hse.gov.uk](mailto:biocidesenquiries@hse.gov.uk)

### A.1 Flocculants and Coagulants

#### A.1.1 Products based on tannin

This section contains no products

#### A.1.2 Products based on polyacrylamide

For the products listed below the following conditions apply:

- (i) no batch must contain more than 0.020% of free acrylamide monomer based on the active polymer content;
- (ii) the dose must average no more than 0.25 mg/l and never exceed 0.50 mg/l of the active polymer;
- (iii) an upper limit for the content of free acrylamide monomer must be stated by the supplier for every batch; and
- (iv) the method used for the analysis for free acrylamide monomer is that published in the series "Methods for the Examination of Waters and Associated Materials" entitled "Determination of Acrylamide Monomer in Waters and Polymers 1987" (HMSO 1988) Method number 115. ISBN 01175 2039X.

#### Solenis UK Industries Ltd

##### **Magnafloc LT20**

DWI 56/4/885

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - Magnafloc 22S-DWI, LT20, LT25, LT27.

IFU 001 Issue No.13 Issue Date 02/01/19

Approval expiry date: 13 February 2022

##### **Magnafloc LT22S-DWI**

DWI 56/4/884

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - Magnafloc 22S-DWI, LT20, LT25, LT27.

IFU 001 Issue No.13 Issue Date 02/01/19

Approval expiry date: 13 February 2022

**Magnafloc LT25**

DWI 56/4/886

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - Magnafloc 22S-DWI, LT20, LT25, LT27.

IFU 001 Issue No.13 Issue Date 02/01/19

Approval expiry date: 13 February 2022

**Magnafloc LT27**

DWI 56/4/887

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use - Magnafloc 22S-DWI, LT20, LT25, LT27.

IFU 001 Issue No.13 Issue Date 02/01/19

Approval expiry date: 13 February 2022

## A.1.3 Products based on iron

### Northern Ireland Water

**Sirofloc Magnetite TM M-10**

DWI 56/4/1338

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Date: 3.12.2018; Issue No: V001

Concentration of iron leaving the works does not exceed 100µg/l

Approval expiry date: 11 August 2024

## A.2 Adsorbents

This section contains no products

## A.3 Ion Exchange Resins Systems

### A.3.1 Ion exchange resins

#### Barr + Wray Ltd

**Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 141204**

DWI 56/4/1238

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Colour/Organics Removal Ion Exchange Resin Rev1 - Oct 2016

Approval expiry date: 12 December 2021

**Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 200613**

DWI 56/4/1239

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Colour/Organics Removal Ion Exchange Resin Rev1 - Oct 2016

Approval expiry date: 12 December 2021

**Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 341817**

DWI 56/4/1237

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Barr + Wray Colour/Organics Removal Ion Exchange Resin Rev1 - Oct 2016

Approval expiry date: 12 December 2021

**Ixom Operations Pty Ltd**

**MIEX DOC Resin**

DWI 56/4/550

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MIEX DOC Resin. Instructions For Use. Version V5. Date of Issue: 26/08/2015

Approval expiry date: 1 September 2021

**MIEX Gold**

DWI 56/4/1140

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Revision 5, Date of Issue 03 September 2020

Approval expiry date: 18 October 2025

**Jacobi Carbons**

**Resinex KW-H**

DWI 56/4/1151

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 1-1016-14

Approval expiry date: 18 June 2022

**Lanxess Deutschland GmbH**

**Lewatit S 5128**

DWI 56/4/1193

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) Lewatit® S 5128,

Issue date: 11/02/2016 Issue No: Version 01

Approval expiry date: 5 March 2022

**Purolite International Ltd**

**Purolite A520E nitrate selective anion exchange resin**

DWI 56/4/11

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Purolite Instructions for Use for A520E resin for Nitrate removal from municipal potable water supplies Issue No: 3. Issue Date: March 2017

Approval expiry date: 27 June 2022

## **A.3.2 Ion exchange resin based processes**

**Barr + Wray Ltd**

**Ion exchange colour removal system**

DWI 56/4/1176

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1 - 17th March 2015

Approval expiry date: 13 September 2021

**Ionex SG Ltd**

**IXL Process**

DWI 56/4/467

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU: Ionex SG IFU IXL Process (IXN Application), Issue No 6

Approval expiry date: 9 July 2022

## A.5 Disinfection or Cleaning Agents of Membranes

During the approval process there is no evaluation of a product's effectiveness, only of its safety in use. An approval given in this section does not certify that the Authorities are satisfied that the product is effective, but only that it is safe for use in accordance with the Instructions for Use supplied.

The fact that a product is approved does not justify any claim about its effectiveness.

### **Avista Technologies (UK) Ltd**

#### **Avista 505**

DWI 56/4/1321

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use – Avista 505, Issue date: 11 May 2018

Approval expiry date: 18 February 2024

#### **AvistaClean MF 1000a**

DWI 56/4/1327

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: AvistaClean MF1000a Instructions for Use

Issue No: 1; Issue date 7 June 2018

Approval expiry date: 16 April 2024

#### **RoCide DB20**

DWI 56/4/964

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoCide DB20 Instructions for Use, IFU003. Issue 4 Date: 17th April 2015

Approval expiry date: 17 January 2021

#### **RoClean L403**

DWI 56/4/855

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean L403 Instructions for Use. Issue Reference – 5. Date of Issue – September 2016

Approval expiry date: 21 November 2021

#### **RoClean P111**

DWI 56/4/737

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean P111 Instruction for Use- Issue 2 – 9 August 2017

Approval expiry date: 15 January 2023

#### **RoClean P303**

DWI 56/4/746

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: RoClean P303 – IFU002. Instructions For Use. Issue 2

Approval expiry date: 27 October 2024

#### **Vitec 3000**

DWI 56/4/457

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 3000 Instructions for Use. Issue 4 – 10 August 2017

Approval expiry date: 27 February 2023

#### **Vitec 4000**

DWI 56/4/582

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 4000. Instructions for Use. Date of Issue – 02/04/2018, Revision Reference - 3

Approval expiry date: 22 October 2023

**Vitec 5000** DWI 56/4/458

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Vitec 5000. Instructions for Use. Issue 4 – 25 October 2017

Approval expiry date: 15 January 2023

**Vitec 7000** DWI 56/4/801

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 5, Dated 30 Jan 2015

Approval expiry date: 11 April 2025

**Vitec 7000a** DWI 56/4/869

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 5, dated 4 May 2015

Approval expiry date: 14 July 2025

**Brenntag UK & Ireland**

**Citric Acid 50% Solution** DWI 56/4/1333

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Citric Acid 50% Solution IFU: Issue date 13/09/2018; Version 1

Approval expiry date: 20 November 2023

**BWA Water Additives UK Ltd**

**Flocon 135** DWI 56/4/839

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document: Flocon 135. Issue: 8

Approval expiry date: 8 August 2021

**Genesys International Ltd**

**Genesol 38** DWI 56/4/664

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: DWI-38-IFU/3 Issue date: 01/08/2019

Approval expiry date: 5 October 2024

**Genesol 40** DWI 56/4/665

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: DWI-40-IFU/3; Issue Date: 1st August 2019

Approval expiry date: 5 October 2024

**Genesol 61** DWI 56/4/1205

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: DWI – 61 – IFU /2, Issue: 2, Date of Issue: 15th Sept 2020

Approval expiry date: 18 November 2025

**Genesol 704** DWI 56/4/1319

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Genesol 704 Issue date: 30 April 2018, Issue 1

Approval expiry date: 29 August 2023

**Genesys CAS** DWI 56/4/1253

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use for Genesys CAS, Jan 17

Approval expiry date: 7 May 2022



**Genesys LF** DWI 56/4/495

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Genesys LF. DWI – LF – IFU / 5 8th October 2018

Approval expiry date: 12 November 2023

**Genesys LF60** DWI 56/4/783

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: DWI-LF60-IFU/4 Dated 26/07/2019

Approval expiry date: 5 October 2024

**Genesys LS** DWI 56/4/781

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: DWI-LS-IFU/4 dated: 26/07/2019

Approval expiry date: 5 October 2024

**Genesys SI** DWI 56/4/593

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Genesys SI. DWI – SI – IFU/4 Issued 29th April 2019

Approval expiry date: 23 June 2024

**Genesys SW** DWI 56/4/524

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Genesys SW. DWI – SW – IFU / 5 8th October 2018

Approval expiry date: 12 November 2023

**Industrial Chemicals Ltd**

**ICL - Citric Acid Solution** DWI 56/4/1342

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ICL Citric Acid Solution, Issue No.1, 4th December 2018  
Only to be used off-line

Approval expiry date: 14 February 2024

**Kobell Fluid Technology Ltd**

**Guardsman GT190 Antiscalant for Membrane Systems** DWI 56/4/1123

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Guardsman Anti-scalant Guidance Rev. 20130111

Guardsman GT190 Anti-scalant Dosing Calculations Rev. 20130111

Approval expiry date: 9 April 2024

**SUEZ Water Technologies & Solutions**

**BioMate MBC2881** DWI 56/4/1276

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BioMate MBC2881 IFU Issue Date: May 2018

Approval expiry date: 2 November 2022

<b>Hypersperse MDC 704i</b>	DWI 56/4/1302
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse* MDC 704i IFU. Issue No: Version 2; Issue date: December 2017	
Approval expiry date: 22 January 2023	
<b>Hypersperse MDC 711</b>	DWI 56/4/1300
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse* MDC711 IFU (Instruction for Use)	
Issue date: December 2017; Issue number: Version 2	
Approval expiry date: 21 June 2023	
<b>Hypersperse MDC 714</b>	DWI 56/4/1301
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse* MDC714 IFU	
Issue date: December 2017; Issue number: Version 2	
Approval expiry date: 20 December 2022	
<b>Hypersperse MSI310</b>	DWI 56/4/1311
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hypersperse MSI310 IFU Issue: December 2018, Version 2	
Approval expiry date: 25 June 2023	
<b>KLEEN MCT515E</b>	DWI 56/4/1273
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Kleen MCT515E Version 2 May 2018	
Approval expiry date: 29 August 2022	
<b>Kleen MTC405</b>	DWI 56/4/1289
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen MTC405 IFU Version 2 January 2018	
Approval expiry date: 17 September 2023	
<b>Kleen* MCT103</b>	DWI 56/4/1008
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Kleen MCT103. Version 2: May 2018	
Approval expiry date: 29 August 2022	
<b>Kleen* MCT524</b>	DWI 56/4/1007
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen* MCT524. IFU Version 2 : May 2018	
Approval expiry date: 29 August 2022	
<b>Kleen* MCT882</b>	DWI 56/4/1010
Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kleen* MCT882. Version 2 May 2018	
Approval expiry date: 29 August 2022	

### **Water Treatment Products Limited**

#### **WTP RO 411**

DWI 56/4/821

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Water Treatment Products Ltd WTP RO411 reverse osmosis antiscalant. Issue 3. Dated: 15 January 2020

Approval expiry date: 5 July 2025

#### **WTP RO 413**

DWI 56/4/822

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use: Water Treatment Products Ltd WTP RO 413 reverse osmosis antiscalant. Issue 3 Dated 15 January 2020

Approval expiry date: 5 July 2025

## **A.6 Disinfectants for Emergency Use**

Disinfectants for emergency use are no longer approved and listed under the requirements of relevant regulations. Guidance upon the choice and use of disinfectants in an emergency is provided in Advice Sheet 9 (<http://www.dwi.gov.uk/drinking-water-products/advice-and-approval/Advicesheet9.pdf>).

Approvals of previously listed disinfectants for emergency use have been revoked – see Information Letter 08/2008 ([http://www.dwi.gov.uk/stakeholders/information-letters/2008/08\\_2008.pdf](http://www.dwi.gov.uk/stakeholders/information-letters/2008/08_2008.pdf))

**This section contains no products**

## **A.7 Products Based on Traditional Chemicals**

### **A.7.1 Traditional Chemicals**

The following traditional chemicals (not currently covered by a specific appropriate BS EN) are considered by DWI to meet the requirements of the relevant regulations subject to the following condition:

The method of use and the purity of these products shall be such that, when used in the treatment of water intended for human consumption, the water so treated shall meet the appropriate requirements of the Water Supply (Water Quality) Regulations. See Reg 31 letter on the "Review of arrangements for approval of Traditional Chemicals" issued 6 August 2018 ([http://www.dwi.gov.uk/drinking-water-products/faqs/Reg31Let\\_060818.pdf](http://www.dwi.gov.uk/drinking-water-products/faqs/Reg31Let_060818.pdf))

#### **Traditional Chemical**

##### **Citric acid (food grade)**

DWI 56/1/106

Conditions of Approval:

For use only in cleaning of membranes

##### **Magnesium sulphate**

DWI 56/1/106

Use only for re-mineralisation with RO membrane systems

## A.7.2 On-site electrolytic generation of chlorine

Products in this section are not fully covered by EN 901 (sodium hypochlorite) and must conform to the following conditions of use:

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and
- (ii) the treated water must not contain more than 700 µg/l chlorate.

### Danish Clean Water A/S

#### **Sodium Hypochlorite generated by Neuthox**

DWI 56/4/1298

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: T00 ECA-Generators Machine: Series 02; Dated: 28-11-2017

(i) the method of use and the purity of the output shall be such that, in the case of water supply, the water so treated meets the requirements of the relevant regulations; and (ii) the water treated must not contain more than 700µg/l chlorate

Approval expiry date: 19 December 2022

#### **Sodium Hypochlorite generated by Neuthox T10/15**

DWI 56/4/1315

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: T10 ECA-Generators

Machine: Series 02; Dated: 20-01-2018

(i) the method of use and the purity of the output shall be such that, in the case of water supply, the water so treated meets the requirements of the relevant regulations; and (ii) the water treated must not contain more than 700µg/l chlorate

Approval expiry date: 29 July 2023

#### **Sodium Hypochlorite generated by Neuthox T20**

DWI 56/4/1318

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: T20 ECA-Generators

Machine: Series 00012; Dated: 15-02-2018

(i) the method of use and the purity of the output shall be such that, in the case of water supply, the water so treated meets the requirements of the relevant regulations; and (ii) the water treated must not contain more than 700µg/l chlorate

Approval expiry date: 26 July 2023

### De Nora Water Technologies UK Services Ltd

#### **Clortec cell**

DWI 56/4/549

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Revision 3.3; 25 September 2019

Approval expiry date: 15 June 2025

### Evoqua Water Technologies Ltd

#### **Wallace and Tiernan OSEC®**

DWI 56/4/775

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wallace & Tiernan® Instruction Manual OSEC®

Approval expiry date: 24 July 2022

**Gaffey Technical Services Ltd**

**Sodium Hypochlorite generated by Hyprolyser Electrochlorination System**

DWI 56/4/1341

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Hyprolyser 280, 560, 110, 2200 Electrolysis system for on-site hypochlorite generation. IFU Issue Date: Nov 2018; Issue No. IFUv1.1

(i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and (ii) the treated water must not contain more than 700 µg/l chlorate.

Approval expiry date: 20 February 2024

**Grundfos Holdings A/S**

**Sodium Hypochlorite generated by Selcoperm**

DWI 56/4/864

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU v003

Approval expiry date: 23 March 2021

**Lutz-Jesco GmbH**

**Easychlorgen 280 – 2200 Electrolysis system for on-site hypochlorite generation**

DWI 56/4/1369

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Easychlorgen 280 – 2200 Electrolysis system for on-site hypochlorite generation - IFUv1.1 Issued: 11/2018

(i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and (ii) the treated water must not contain more than 700 µg/l chlorate.

Approval expiry date: 20 February 2024

### **A.7.3 On-site generation of chlorine dioxide**

Products in this section are not fully covered by EN 12671 (chlorine dioxide). The following products must conform to the following conditions of use:

- (i) the method of use and the purity of the output of these products shall be such that, in the case of water for public supply, the water so treated meets the requirements of the relevant Regulations; and
- (ii) the combined concentration of chlorine dioxide, chlorite and chlorate shall not exceed 0.5 mg/l as chlorine dioxide in the water entering supply.

#### **Grundfos Holdings A/S**

##### **Oxiperm ISIA (with U-type reactor)**

DWI 56/4/1236

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Version 1, 2016

Approval expiry date: 30 November 2021

#### **International Water Solutions Ltd**

##### **Chlorine Dioxide generated by Xziox**

DWI 56/4/998

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1.8 Dated 27/01/16

Approval expiry date: 30 January 2026

### **A.9 Other Chemicals**

#### **Airedale Chemical Company Ltd**

##### **Airopfos 750PWG**

DWI 56/4/960

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 dated 23/1/14

Approval expiry date: 19 March 2025

#### **Aqua Smart Inc.**

##### **SEAQUEST**

DWI 56/4/202

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Seaquest V1

Approval expiry date: 23 October 2025

#### **Arch Chemicals Ltd**

##### **Constant Chlor Plus Briquettes**

DWI 56/4/1241

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use – Constant Chlor Plus Briquettes. Issue no: 1.1. Issue date: 30 Sept 2016

Approval expiry date: 12 December 2021

#### **B&V Water treatment**

##### **Ultralox 40**

DWI 56/4/1074

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Ultralox 40 Official Instructions for Use, Issue 3, March 2015

Approval expiry date: 29 November 2023

**BioBullets Ltd**

**Silver Bullets 1000**

DWI 56/4/852

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use document for Silver Bullets 1000. Issue No 2. Dated 5th October 2017

This product can only be used for raw water treatment.

Approval expiry date: 20 December 2022

**Silver Bullets 2000**

DWI 56/4/1000

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use for Silver Bullets 2000, Issue No: 2 Issue Date 5th October 2017

This product can only be used for raw water treatment.

Approval expiry date: 16 July 2023

**Brenntag UK & Ireland**

**Magnesium Sulphate Heptahydrate 40%**

DWI 56/4/1334

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Magnesium Sulphate Heptahydrate 40%:- Instructions for Use

Issue Date: 27/09/2018: Issue No: Version 1

Approval expiry date: 20 June 2024

**TP Chlor**

DWI 56/4/979

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 dated 19/6/15

The method of use and purity of this product shall be such that in the case of water for public supply the water so treated meets the requirements of the relevant regulations.

Approval expiry date: 21 October 2025

**TP Chlor plus**

DWI 56/4/1190

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 dated 19/6/15

The method of use and purity of this product shall be such that in the case of water for public supply the water so treated meets the requirements of the relevant regulations.

Approval expiry date: 21 October 2025

**Clinty Chemicals Limited**

**Purafloc TM 001**

DWI 56/4/1378

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Purafloc TM 001 Issue Date: 12th August 2019; Issue No:1

Approval expiry date: 18 August 2024

### **Industrial Chemicals Ltd**

#### **Thycal**

DWI 56/4/1025

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use :THYCAL. Issue No: Version 2. Issue Date: 14th June 2016

Approval expiry date: 1 September 2021

### **JFI Limited**

#### **Purafloc TM 001**

DWI 56/4/1355

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Purafloc TM 001 Issue Date: 12/02/19; Issue No 1.0

Approval expiry date: 10 June 2024

### **Lhoist UK Ltd**

#### **Akdolit® SLS45**

DWI 56/4/1392

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Akdolit® SLS45 IFU Issue Date: 17/04/2020; Version 1.1

Approval expiry date: 14 June 2025

### **Tarmac Cement and Lime Limited**

#### **Puresol**

DWI 56/4/1147

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Puresol for pH Control and Water Softening in Drinking Water Processes

Issue 001, Issue Date: 21st Oct 2019

Approval expiry date: 9 October 2024

### **Tarmac Lime & Cement**

#### **Kalic HSD**

DWI 56/4/1206

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Kalic HSD for pH Control and water softening in Drinking water treatment processes. Issue 002 05/04/2016

Approval expiry date: 27 April 2025

## **A.10 Filter Media**

### **Dryden Aqua Ltd**

#### **AFM Activated Filter Media**

DWI 56/4/382

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: AFM Activated Filter media. 6th November 2014. Issue no 2

Approval expiry date: 20 February 2025



## **PART B PRODUCTS FOR CONVEYANCE OF WATER**

### **B.1 Pipes**

#### **B.1.1 Polyethylene (PE) pipes**

##### **Asset International Ltd**

###### **Weholite Pipe and Panels**

DWI 56/4/513a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Weholite HDPE Pipes - Issue 5 September 2018

Approval expiry date: 2 February 2024

##### **Centraltubi SPA**

###### **Safe 10**

DWI 56/4/1366

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Safe 10 - Manual of Use - 2nd Revision Jan 2017

Approval expiry date: 23 July 2024

##### **Cork Plastics**

###### **CP Polytec 100**

DWI 56/4/1351

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE OF CP POLYTEC 100 EXTERNAL BLUE & INTERNAL BLACK PE100 POLYETHYLENE PIPE FOR SUPPLY OF DRINKING WATER UNDER PRESSURE Issue No.1  
Date: October 2018

Approval expiry date: 19 March 2025

###### **CP Polytec PE80E**

DWI 56/4/1187

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU CP Polytec PE80E 3doc Dec15

Approval expiry date: 1 June 2021

##### **EBERO Pipe Systems Ltd**

###### **Gerotherm PE100 Polyethylene Pipes**

DWI 56/4/1115

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Document No. 065 Revision 2 Dated: 25.05.2019

Approval expiry date: 22 September 2024

##### **Egeplast International GmbH**

###### **egeclean (+)**

DWI 56/4/1157

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use. egeclean plus pipes . Issue 1 dated 03/07/2014

Approval expiry date: 31 October 2023

**egeclean 9010**

DWI 56/4/1158

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use. egeclean PE100/egeclean 9010. Issue 1 dated 14 February 2018

Approval expiry date: 19 April 2023

**egeclean PE100**

DWI 56/4/1156

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use. egeclean PE100/egeclean 9010. Rev No 3 Date: 30 January 2019

Approval expiry date: 12 October 2024

**egelen PE 100 Blue**

DWI 56/4/436

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE-HD PE100 in black and blue Version 11 dated 30th January 2019

Approval expiry date: 12 October 2024

**egelen PE100 Black**

DWI 56/4/436

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE-HD PE100 in black and blue Version 11 dated 30th January 2019

Approval expiry date: 12 October 2024

**egeplast 9010**

DWI 56/4/1065

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU\_egelen\_9010\_Drinkwater Rev11

Version 11 dated 30th January 2019

PE grades as specified to approval holder and Cold potable water applications only.

Approval expiry date: 19 April 2023

**egeplast egelen (+) Plus Pipe**

DWI 56/4/1111

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use Peelable layer pipes. IFU-UK Rev 11 5th July 2018

Approval restricted to a single grade of Polyethylene (Eltex TUB 125N3000)

Approval expiry date: 31 October 2023

**George Fischer Sales Ltd**

**GF PE100 Black Pipe**

DWI 56/4/957

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 15/HLET 15920/15. Dated 23 January 2015

Approval expiry date: 29 March 2025

**Gerodur MPM Kunststoffverarbeitung GmbH & Co. KG**

**GEROthen® COEX**

DWI 56/4/1370

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Gerodur, GEROthen® Pipes - products and design No 01 Issue No: 01; Issue Date: 13.08.2019

Approval expiry date: 2 April 2025

**GPS**

**Excel White**

DWI 56/4/1269

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: EXCEL WHITE POLYETHYLENE PIPES MADE FROM WHITE AND BLACK PE100 MATERIAL

Issue Number 1; Issue Date: 21/03/2017

Approval expiry date: 31 May 2023

**GPS B Light Blue Polyethylene Pipe**

DWI 56/4/242

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue: Instructions for Use . Issue No: 3. Issue Date: 16 Jan 2017

Approval expiry date: 10 June 2022

**GPS Excel (Black)**

DWI 56/4/851

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue No. 2

Approval expiry date: 6 November 2021

**GPS Excel (Blue)**

DWI 56/4/850

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue Number 2

Approval expiry date: 6 November 2021

**GPS Excel (Black) Type F**

DWI 56/4/961

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Excel. Issue No: 6. Issue Date: 16/3/2015

Approval expiry date: 1 September 2021

**GPS Excel 3c (Black)**

DWI 56/4/871

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Excel 3 c PE Pipe Coils Made From Blue PE100 Or Black PE100 Materials. Issue No. 4. Dated: 14.6.2013

Approval expiry date: 1 September 2021

**GPS Excel 3c (Blue)**

DWI 56/4/853

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Excel 3 c PE Pipe Coils Made From Blue PE100 Or Black PE100 Materials. Issue No. 4. Dated: 14.6.2013

Approval expiry date: 1 September 2021

**GPS Excel CR**

DWI 56/4/946

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: 2 Issue Date: 16/3/2015

Approval expiry date: 1 September 2021

**GPS Excel NB**

DWI 56/4/1026

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue: Excel NB. Issue No: 1. Issue Date: 1/7/2011

Approval expiry date: 1 September 2021

**GPS Excel NB Type V**

DWI 56/4/1050

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU, Issue Number 3, 24/05/2017

Approval expiry date: 6 September 2022

**GPS N Black Polyethylene Pipe**

DWI 56/4/1260

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU, Issue Number 1, dated 7/2/2017

Approval expiry date: 22 May 2022

**GPS N Blue PE80 Pipe**

DWI 56/4/651

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date 26/4/19 Issue no 3

Approval expiry date: 14 September 2024

**Idrotherm 2000 spa**

**RENO 100**

DWI 56/4/1168

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use Issue: PFSSP Rev 3, Issue Date: 22/10/2019

Approval expiry date: 5 May 2025

**Peak Pipe Systems**

**Peak Pipe Systems**

DWI 56/4/548

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PSIFU01– Issue 09 Dated: 03/03/2020

Approval expiry date: 20 May 2025

**Pipelife Ireland Limited**

**Qual-plast HDPE Pipe**

DWI 56/4/997

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Qual-PLAST PE Pipe Systems Instructions for Use. Date of Issue: 27.09.10. Issue number: 2

Approval expiry date: 21 August 2021

**Qual-plast MDPE Pipe**

DWI 56/4/240

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Qual-PLAST MDPE pipe systems - Instructions for Use. Issue No: 2. Issue date: 16/01/17

Approval expiry date: 24 July 2022

**QualPLAST Polyethylene MDPE co-extruded pipe**

DWI 56/4/1282

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU 01 2017

Approval expiry date: 23 August 2022

## **Polypipe Building Products**

### **Black PE80 Polyethylene Pipes**

DWI 56/4/968

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document for Polypipe Building products' PE80 Black polyethylene Pressure pipes to BS EN 12201-2 made from Ineos Eltex Tub 171 Black Polyethylene Compound Doc Reference: PS 157. Issue No: 02 Date: 29 May 2020  
Suitable for use above ground only.

Approval expiry date: 29 July 2025

### **Black PE80 Polyethylene Pipes (ME3440)**

DWI 56/4/986

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue 1, 7 July 2016

Approval expiry date: 30 November 2021

### **Blue PE80 Polyethylene Pipes**

DWI 56/4/970

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PSNR001 issue 2 dated 29/05/2020

Approval expiry date: 29 June 2025

### **Blue PE80 Polyethylene Pipes (PC002 50R698)**

DWI 56/4/1120

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PS 161 Issue 1 26 September 2013

Approval expiry date: 17 October 2023

### **Polypipe Blue PE100 Polyethylene Pipes (TUB124N 2025)**

DWI 56/4/1296

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use document for Polypipe Building Products' PE 100 Blue Polyethylene pressure pipes to BS EN 12201-2 made from Etex TUB124N 2025 polyethylene compound. Issue Number: 01; Issue date: 28 Sept 2017

Approval expiry date: 15 March 2023

## **Polypipe Ltd**

### **Polypipe Black PE100 Polyethylene Pipes (TUB121N3000)**

DWI 56/4/1343

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR POLYPIPE BUILDING PRODUCTS' PE 100 BLACK POLYETHYLENE PRESSURE PIPES TO BS EN 12201-2 MADE FROM ELTEX TUB121N 3000 POLYETHYLENE COMPOUND - Version: 01 Issued: 7 December 2018  
Pipes for above ground use only

Approval expiry date: 6 February 2024

## **Radius Subterra – a part of RadiusPlus Ltd**

### **Subcoil**

DWI 56/4/461

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 6.

Approval expiry date: 1 October 2025

### **Radius Systems Ltd**

**High Performance SC100 Dark Blue Pipe PE100 pipe including Clean Pipe** DWI 56/4/939

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: High Performance SC100 Dark Blue PE100 pipe including Clean Pipe, Issue No' 4: Jan 2016

Approval expiry date: 11 July 2022

**PE100 High Performance Profuse Pipe including Factory Sealed** DWI 56/4/943

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PE100 High Performance Profuse Pipe including Clean Pipe, Issue No' 3: Jan 2016

Approval expiry date: 11 July 2022

**SC100 (PE100) XL large diameter / heavy wall dark blue potable water pipe** DWI 56/4/1146

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 01, dated 02/09/2015

Approval expiry date: 8 September 2025

**SC80 Service Pipe** DWI 56/4/941

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SC 80 Service Pipe. Issue No 02, dated 23/01/2015

Approval expiry date: 3 February 2025

### **Simona UK Ltd**

**Simona PE100 Pressure Pipe Black** DWI 56/4/875

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Simona ® PE100 Pressure pipes manufactured using either Hostalen CPR100Black/Blue or Eltex tub 121 N3000. Issue number 11/14. Dated November 2014

Approval expiry date: 4 December 2024

## **B.1.2 Polyethylene Barrier pipes**

### **Egeplast International GmbH**

**Egeplast SLA Barrier Pipes** DWI 56/4/1109

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU – UK. Rev.-Nr.: 11. 17th July 2020

Approval expiry date: 20 August 2025

### **GPS**

**GPS Protecta-Line** DWI 56/4/872

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 8. Dated 26 April 2019

Approval expiry date: 23 November 2024

**GPS Protecta-Line 3c** DWI 56/4/873

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue 8. 26 April 2019

Approval expiry date: 23 November 2024

### **Polypipe Building Products**

#### **Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes**

DWI 56/4/857

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use Document For Polypipe Building Products' Polyguard PE/Al/PE Pressure Pipe to WIS 4-32-19 Made From Ineos Eltex PC-002-50 R568 Blue Polyethylene/Novelis Aluminium.  
Document Reference: PSNR003. Issue No. 2. Dated 29/05/2020

Approval expiry date: 20 September 2025

#### **Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes (ME3444)**

DWI 56/4/1076

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use document. Document reference :PS160.  
Issue no: 1. Date: 28 September 2012

Approval expiry date: 21 January 2023

### **Radius Systems Ltd**

#### **Puriton Pipe**

DWI 56/4/1112

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Puriton Barrier Pipe. Issue 4 dated 04/11/2016

Approval expiry date: 29 October 2024

## **B.1.3 Polyvinylchloride (PVC) pipes**

Please note that all approved PVC pipes are made with non-lead stabilisers.

### **Adequa WS S.L.U**

#### **Uratop PVC-O Adequa**

DWI 56/4/1266

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: URATOP PVC-O ADEQUA

Issue Date: May 2017; Issue No.: Version 2

Approval expiry date: 19 June 2023

### **Durapipe UK**

#### **Durapipe Grey PVC-U Pipe NGS**

DWI 56/4/937

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Date of Issue: 03/05/16. Issue Number: 1

Approval expiry date: 4 October 2021

#### **Durapipe PREMIUM PVC-U pipe**

DWI 56/4/1226

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Durapipe PREMIUM PVC-U Pipes Issue Date: 03/05/2016, Issue No: 1

Approval expiry date: 5 October 2021

**Dyka B.V.**

**Dyka Grey PVC-U Pipe NGS**

DWI 56/4/637

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Dyka - PVC-u Technical Specification. Date of Issue 17/11/2006. Issue Number 1.

Approval expiry date: 4 October 2021

**Dyka S.A.S.**

**Bi-OROC**

DWI 56/4/1207

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: BI-OROC PN16 PVC-O Technical Specifications Dated: 14/05/2018; Issue Number: V0

Approval expiry date: 13 October 2021

**George Fischer Sales Ltd**

**GF DEKADUR PVC-U pressure pipe**

DWI 56/4/1231

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 2, 13 June 2016

Approval expiry date: 26 April 2022

**GF PVC-U Inch Pipe**

DWI 56/4/1235

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No. 1, 27 July 2016

Approval expiry date: 31 January 2023

**Molecor Tecnología SL**

**TOM PVC-O Pipe**

DWI 56/4/1057

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: TOM PVC Orientated Pipe (PVC-O) Information for Use Document. Edition: 1 January-14/ Revision 1

Approval expiry date: 12 June 2024

**Wavin Ireland Ltd**

**Aquaforce (with non-lead stabiliser)**

DWI 56/4/600

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Wavin Aquaforce Instructions for Use. Issue number 04 April 2004

Approval expiry date: 13 February 2022



## **B.1.4 Acrylonitrile-butadiene-styrene copolymer (ABS)**

### **Durapipe UK**

#### **Durapipe ABS Pipe Type S**

DWI 56/4/660

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ABS Pipes And Fittings Made From Durapipe ABS Type S, GRET ABS Material Issue 7 Date 24/6/2011

Approval expiry date: 8 August 2021

### **George Fischer Sales Ltd**

#### **GF ABS pressure pipe**

DWI 56/4/753

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) - GF ABS Pressure Pipe, Issue date:08 January 2015; Issue No:1

Approval expiry date: 29 January 2025

## **B.1.5 Polyethylene terephthalate (PET)**

**This section contains no products**

## **B.1.6 Glass reinforced plastic (GRP) pipes**

### **Future Pipe Industries B.V**

#### **Wavistrong Series**

DWI 56/4/656

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Wavistrong Glassfibre Reinforced Epoxy (GRE) Pipe Systems. Issue No: IFU DW FPI BV Version no: 2. Date of Issue 22/2/2011

Approval expiry date: 26 February 2022

## **B.1.7 Cement mortar lined pipes**

For Products in this section, the following conditions applies:

Before connection to the supply, the water undertaker or their appointed agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations.

### **B.1.7.1 Cement mortar lined pipes without seal coat**

#### **Electrosteel Castings Ltd**

##### **Electrofresh Ductile Iron Pipe**

DWI 56/4/992

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use for Electrofresh Pipes at Site

Work Instruction: WC-04-02

Issue No: 03 Rev. C Issue Date: 25.02.2016

Before connection to supply, the water undertaker or their approved agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant regulations.

Approval expiry date: 1 August 2021

#### **Erciyas Celik Boru Sanayi A.S**

##### **Erciyas Steel Water Pipe – Cement Lined**

DWI 56/4/1047

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction For Use. Erciyas Pipeline Systems Steel Water Pipes lined with CEMENT. Document number: TA-04-13, Revision: 2. Date of Issue: 1/02/12

Approval expiry date: 11 December 2021

**JINDAL SAW GULF LLC**

**JSGL-JAL-1A**

DWI 56/4/1122

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for use document (JSAW-JAL-1A) Ductile iron pipes to convey raw water, water during treatment, treated and potable water with or without pressure' Issue No.: 1 Issue Date: 15/09/2013

Approval expiry date: 20 February 2025

**Jindal Saw Ltd**

**JSAW-JAL-11A**

DWI 56/4/935

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document JSAW-IFU-DI-DWI-OPC-SC-001 Rev. 02, 15/11/16

Approval expiry date: 12 March 2022

**JSAW-JAL-1A**

DWI 56/4/933

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document, JSAW-IFU-DI-DWI-OPC-001 Rev. 02, 15/11/16

Approval expiry date: 12 March 2022

**Saint-Gobain PAM UK Ltd**

**System CL**

DWI 56/4/283

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SAINT GOBAIN PAM UK. Instructions for Use Document for System CL Pipes. Issue Number 9. Date: 25th May 2009

Approval expiry date: 5 May 2023

**Stanton Bonna Concrete Limited**

**Stanton Bonna Concrete Pressure Pipe**

DWI 56/4/1375

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Version 1 Dated 22/07/2019

Approval expiry date: 10 September 2024

**Superior Pipeline Products Ltd**

**System Cement Mortar Lined Ductile Iron Pipe**

DWI 56/4/990

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use System Cement Mortar lined Ductile Iron Pipe Issue no: 4 March 2017

Approval expiry date: 8 November 2022

**European Pipeline Group**

**European Pipeline Group Svobodny Sokol Ductile Iron Pipe**

DWI 56/4/1114

Use of the product must be in accordance with the Instructions for Use: Edition 2 dated 1/7/2013

Approval expiry date: 15 August 2023

## **B.1.7.2 Cement mortar lined pipes with seal coat**

### **Electrosteel Castings Ltd**

#### **Electrofresh Plus Pipes**

DWI 56/4/537

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU (instructions for use) for Electrofresh plus pipes at site .  
Issue No: 04 Rev. 0 Issue Date 01.04.2017

Approval expiry date: 2 August 2021

### **Jindal Saw Ltd**

#### **JSAW-JAL-11B**

DWI 56/4/936

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document JSAW-IFU--DI-DWI-BFSC-SC-001 Rev. 02, 15/11/16

Approval expiry date: 12 March 2022

#### **JSAW-JAL-1B**

DWI 56/4/934

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document JSAW-IFU-DI-DWI-OPC-SC-001 Rev. 02, 15/11/16

Approval expiry date: 12 February 2022

### **Saint-Gobain PAM UK Ltd**

#### **System XL**

DWI 56/4/1317

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SAINT GOBAIN PAM UK. Instructions for Use Document for System XL. Issue number 8. Dated: 1st January 2013

Approval expiry date: 5 May 2023

## **B.1.8 Pipes coated with factory applied nylon resins**

### **Leyfos Plastics Limited**

#### **Rilsan Nylon Green Coated Pipes and Fittings**

DWI 56/4/615

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Creation Date: 1/10/13 Document number: LEYDWI01.. Issue Number 02

Approval expiry date: 26 November 2023

## **B.1.9 Pipes coated with factory applied epoxy resin**

### **BAIKA Steel Tubular Systems SL**

#### **Steel pipe coated with Eurokote 468 Thixo**

DWI 56/4/1203

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Eurokote 468 Thixo, Issue No2 - 21 March 2019

Approval expiry date: 2 March 2021

### **BSR Pipeline Services Ltd**

#### **BSR/EPW/004 - Copon Hycote PWX**

DWI 56/4/772

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue 8 Nov 2010

Approval expiry date: 6 April 2022

### **Erciyas Celik Boru Sanayi A.S**

#### **Steel Water Pipes line with epoxy coating Eurokote 468 Thixo**

DWI 56/4/1001

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Date of Issue: 05.07.18TA-04-30 Revision 1

Approval expiry date: 4 September 2024

### **Freeflow Pipesystems Ltd**

#### **Pipes Lined with Resicoat R4-FB HKC71R**

DWI 56/4/817

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 8 Dated 17.02.20

Approval expiry date: 4 May 2025

### **Noksel Steel Pipe Co Inc**

#### **Noksel Steel Water Pipe – Coated with Thixo 468**

DWI 56/4/1192

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: NOK-DJM-INT-0001 18/08/2020, Issue 1

Approval expiry date: 4 October 2025

**Northpoint Ltd**

**Pipes and fittings lined with Eurokote 468 Thixo** DWI 56/4/1209

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions of Use of pipes lined with Eurokote 468 Thixo Coating System. Issue No 2 26/1/16

Approval expiry date: 13 June 2021

**Pipes and Fittings lined with Jotaguard VA 5001** DWI 56/4/1304

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: J-Guard VA 5001 IFU 201711101343.00 Issue Date: 2017-11-10; Issue number: 00

Approval expiry date: 3 December 2022

**Pipes, Fittings and Steelwork coated with Resicoat R4-FB HKC71R** DWI 56/4/659

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU.RESICOTE R4-FB.201911010915 08 Issued 14-08-2019

Approval expiry date: 17 November 2024

**Orrmac Coatings Limited**

**Pipes and Fittings lined with Resicoat R4-FB HKC71R** DWI 56/4/771

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue no 5 dated April 2015

Approval expiry date: 31 May 2025

**Pipes lined with Scotchkote 162PWX** DWI 56/4/985

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU, Issue 8, Nov 2010

Approval expiry date: 5 March 2022

**Saint-Gobain PAM UK Ltd**

**PaM Natural Pipeline Components** DWI 56/4/618

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Number 6. Dated 19th November 2019

Approval expiry date: 20 February 2025

**UTS Engineering Ltd**

**Fabricated mild steel pipework coated with Jotaguard VA5001** DWI 56/4/1324

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pipes coated with Jotaguard VA5001 IFU Issue Date 1st February 2019; Issue No: 1.

Approval expiry date: 11 June 2024

**Fabricated mild steel pipework coated with Scotchkote 162pwx** DWI 56/4/1085

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pipes lined with Scotchkote 162 PWX Instructions for use Document. Issue 1. Date 5th March 2013

Approval expiry date: 26 April 2023

## **B.1.10          Stainless steel pipes**

### **ABC Stainless Steel Ltd**

#### **Q Pipe System**

DWI 56/4/542a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use : 1. Stainless Steel "Q" pipe system . 2. Stainless steel storage, Process Tanks and Vessels . Issue no: 2  
Date: 20th October 2003

Approval expiry date: 4 January 2023

### **AJ Engineering and Construction Services Ltd**

#### **Stainless Steel Pipework and Fabrications**

DWI 56/4/1220a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework and Fabrications for water use. Issue No: WP 41, Issue date: 04/08/2016

Approval expiry date: 19 September 2021

### **Alpha Plus Ltd**

#### **Stainless Steel Pipework**

DWI 56/4/692

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No. 2 Issue Date 13-09-19 (Document ref: IFU-02)

Approval expiry date: 9 October 2024

### **Amari Metals Ltd**

#### **Stainless Steel Tube, Stainless Steel pipe**

DWI 56/4/738

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU/DWI/Amari/TP: Issue No 3

Approval expiry date: 19 July 2021

### **Berry & Escott Engineering**

#### **Stainless Steel Pipework and Fabrications**

DWI 56/4/1362

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU - Stainless Steel Fabricated Pipework

Approval expiry date: 1 May 2024

### **Blackburns Metal Ltd**

#### **Stainless Steel ANSI Metric ISO Pipe, Stainless Steel ANSI Metric ISO Tube, Stainless Steel ANSI Metric ISO Fittings**

DWI 56/4/1224

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Number 1, Issue date 26th May 2016

Approval expiry date: 26 June 2021

**Bridges Electrical Engineering Ltd**

**Bridges in-house fabricated stainless steel pipe spools and products** DWI 56/4/1268a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Bridges in-house fabricated stainless steel pipe spools and products , Issue 1 22/03/17

Approval expiry date: 14 May 2022

**BSS Industrial**

**Stainless Steel Tubings and Fittings** DWI 56/4/1017

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: BSS\_Industrial\_IFU\_24.04.17v1

Approval expiry date: 4 June 2022

**DH Stainless Ltd**

**Stainless Steel Metric ISO & ANSI welded pipe and fittings** DWI 56/4/773

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1 dated 13 March 2020

Approval expiry date: 13 May 2025

**Dustacco Engineering Ltd**

**DE Stainless Steel Systems** DWI 56/4/647

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: F011 (Issue date 12/8/13) in accordance with BSSA Code of Practice

Approval expiry date: 15 August 2024

**Equipdata Trading**

**IPSSSPW01 Stainless Steel Pipework and Fabrications** DWI 56/4/1316

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use of IPS Product Number IPSSSPW01 – Issue 4; Dated 06/03/2018

Approval expiry date: 10 March 2023

**Filtec Water Services Ltd**

**Filtec "Selkie" Stainless Steel Products** DWI 56/4/1396a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HANDLING, INSTALLATION AND COMMISSIONING INSTRUCTIONS FOR THE FILTEC SELKIE RANGE OF STAINLESS-STEEL PRODUCTS FOR USE IN CONTACT WITH TREATED OR PARTIALLY TREATED POTABLE WATER

Dated: 29/04/2020; Issue No: 01; Rev02

Approval expiry date: 17 May 2025



**George Green (Keighley) Ltd**

**Stainless Steel Pipework & Fittings - Flanged/Screwed - All diameters & Grades**

DWI 56/4/699

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 4. Date 3 May 2019

Approval expiry date: 16 September 2024

**Homer Burgess Ltd**

**Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water**

DWI 56/4/1107a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Title: Homer Burgess Ltd., Manufacturer's official use instructions for Stainless Steel Products in contact with Drinking Water.. Issue Number Rev. 1 26/01/2016

Approval expiry date: 22 May 2023

**Neumo UK Ltd**

**Neumo Stainless Steel Tube and Fittings**

DWI 56/4/1167

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1: 27/11/2019

Approval expiry date: 29 March 2025

**Ocean Kinetics Ltd**

**Unlined 316 & 316L Stainless Steel Tanks and Pipework**

DWI 56/4/1395a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: OK-IFU-2020-001 Rev 1; Issue date: 16/04/20

Approval expiry date: 22 April 2025

**OSTP**

**OSTP Stainless Steel pipe and fittings of 12mm bore or greater.**

DWI 56/4/516

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Drinking Water Supply – Stainless steel welded tubular products IFU Issue 1 Issue Date: 06/08/2019

Approval expiry date: 10 October 2024

**Powerrun Pipe-Mech Ltd**

**Powerrun fabricated stainless steel pipework**

DWI 56/4/769

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PFSSP Rev3 dated 22/10/2019

Approval expiry date: 27 January 2025

**Righton and Blackburns Ltd**

**Stainless Steel Pipe | Stainless Steel Tube | Stainless Steel Fittings | Material grades 304/304L, 316/316L, 1.4301/1.4307, 1.4401/1.4404**

DWI 56/4/1221

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU - RB-QA-LS-IFU-DW - Issue 02 17-05-2019

Approval expiry date: 22 June 2021

**Stainless Steel pipes, Stainless Steel Tube, Stainless Steel Fittings**

DWI 56/4/1221

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Number 1, Issue date 26th May 2016

Approval expiry date: 22 June 2021

**Ross-shire Engineering Ltd**

**Stainless steel process pipework systems**

DWI 56/4/1034

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue: Information for Use Drinking Water Stainless Steel Process Pipework Systems. Issue No: 2 Issue Date: 23-06-16

Approval expiry date: 1 September 2021

**Specialist Welding Services Ltd**

**Stainless Steel Tanks and Pipework**

DWI 56/4/1367

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Version 1.0 Revision C (Dated: 09 August 2019)

Approval expiry date: 15 August 2024

**Staptina Engineering Services Ltd**

**Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems**

DWI 56/4/567a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 24838IFU 12 June 2013

Approval expiry date: 31 March 2024

**Tema Engineering Limited**

**Stainless Steel Pipework, Tanks and Vessels for Water Use**

DWI 56/4/1376a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No:01; Issue Date:25/07/2019

Approval expiry date: 6 October 2024

**Vessco Engineering Ltd**

**Fabricator of Bespoke Stainless Steel Products: Pressur Vessels, Tanks and Pipes**

DWI 56/4/1345a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1, Rev 1: 24 January 2019

Approval expiry date: 20 February 2024

**Yorkshire Stainless Ltd**

**Stainless Steel Pipes, Tubes, Fittings and Flanges**

DWI 56/4/1368

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipes, Tubes, Fittings and Flanges. Issue 1 Date: 06/06/2019

Approval expiry date: 17 July 2024

## **B.1.11 Coated pipes suitable for total immersion in water**

### **Saint-Gobain PAM UK Ltd**

#### **System CL**

DWI 56/4/283

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SAINT GOBAIN PAM UK. Instructions for Use Document for System CL Pipes. Issue Number 9. Date: 25th May 2009

Before connection to the supply, the water undertaker or their appointed agent must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations.

Approval expiry date: 5 May 2023

#### **System XL**

DWI 56/4/1317

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SAINT GOBAIN PAM UK. Instructions for Use Document for System XL. Issue number 8. Dated: 1st January 2013

Before connection to the supply, the water undertaker or their appointed agent must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations.

Approval expiry date: 5 May 2023

## **B.1.12 Pipes coated with a factory applied polyolefin**

### **Saint-Gobain PAM UK Ltd**

#### **Blutop**

DWI 56/4/823

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Number 2. Date: 1st January 2009

Approval expiry date: 20 February 2025

## **B.2 Well Casings, Screens and Rising Mains**

### **Angus Flexible Pipelines**

#### **Angus Wellmaster Flexible Rising Main**

DWI 56/4/1020

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE (IFU) DOCUMENT ANGUS/IFU/WM. Wellmaster The Flexible Rising Main. Document: ANGUS/IFU/WM. Issue: 004. Dated: September 2016

Prior to use the water supplier carries out a risk assessment to provide for a suitable flushing regime validated, where appropriate, by monitoring when the product has been out of supply for a period of time.

Approval expiry date: 9 October 2021

### **Aqseptence Group SAS**

#### **Johnson Screen, Casing & Johnson Riser Pipe and Accessories**

DWI 56/4/653

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aqseptence Group SAS – Johnson Screen, Casing and Johnson Riser Pipes Issue 2 Dated 17th April 2019

Approval expiry date: 22 June 2024

### **Boode UK Ltd**

#### **Boode Waterwell Systems PVC Screen and Casing**

DWI 56/4/958

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Boode Waterwell Systems PVC Screen and Casing. Instructions for Use . Issue 2 - 1.1.2018

Approval expiry date: 9 July 2023

### **GOLAN Plastic Products Ltd**

#### **PEXGOL**

DWU 56/4/1259

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No. 1. Dec 2016

Approval expiry date: 17 February 2023

**Stuwa-Konrad Stuckerjürgen GmbH**

**PVC Screens, Casings, Fittings and Accessories**

DWI 56/4/1061

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU approval STÜWA – Konrad Stuckerjürgen GmbH. PVC screens and casings. Issue date = 07/19/2012. Issue number = 3

Approval expiry date: 13 December 2023

**Stainless Steel Screens, Casings, Fittings and Accessories**

DWI 56/4/1060

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU approval STÜWA – Konrad Stuckerjürgen GmbH. Stainless steel screens and casings. Issue date = 07/19/2012. Issue number = 3

Approval expiry date: 23 July 2022

**STUWA Stainless Steel Riser Pipes**

DWI 56/4/1077

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Approval STÜWA – Konrad Stuckerjürgen GmbH. Stainless Steel Riser Pipes. Issue 2 Dated 29/11/2012

Approval expiry date: 11 September 2022

## **B.3 Products for Conveyance of Water -Emergency Use**

For products in this section the following condition applies:

These products are primarily intended for emergency use and are approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

NOTE: some of these products may be suitable for limited use during planned maintenance. In this case it is the responsibility of the water supplier to undertake a thorough risk assessment of the proposed use, including fitness-for-purpose and why other products, already fully approved under the relevant regulations cannot be used. Use of any of these products during planned maintenance shall be in accordance with the condition set out above.

### **B.3.1 Hoses**

#### **AAH Europe Hose Company Ltd (T/A Snap-tite)**

##### **Snap-Tite TE Range – Blue Hose**

DWI 56/4/62

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU LAYFLAT POTABLE WATER HOSE FOR EMERGENCY USE – “SNAP-TITE TE HOSE RANGE’ Rev.2 Date: 26/06/20

Approval expiry date: 6 July 2024

#### **Angus Flexible Pipelines**

##### **Super Aquaduct**

DWI 56/4/1005

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE (IFU) DOCUMENT. ANGUS SUPER AQUADUCT. Document: ANGUS/IFU/SA. Issue: 006. Dated: September 2016

(i) after disinfection the product is flushed for its entire length before being brought into service; (ii) when in use the main is kept continually in flow; (iii) the product is primarily intended for emergency use and is approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from DWI should be sought before installation and use.

Approval expiry date: 9 October 2021

## **B.3.2 Bowers/tanks**

### **Enduramaxx Ltd**

#### **Enduratank**

DWI 56/4/1242

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Enduratank Potable Water Storage Tanks, Issue number: 1  
Issue date 27/10/16

The product is approved for emergency use only and may not be permanently installed in any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 9 April 2022

### **JFC Manufacturing Co. Ltd**

#### **AquaCube Emergency Water Tank**

DWI 56/4/765

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Revision 001, May 2016

Approval expiry date: 3 October 2021

### **Trailer Engineering Ltd**

#### **Emergency Drinking Water Bowers**

DWI 56/4/707

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Drinking Water Bowser Operating Manual, Vol. 8, dated October 2004

Approval expiry date: 28 October 2024

### **Whale Tankers Ltd**

#### **Whale Drinking Water Bowser**

DWI 56/4/662

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date 30/07/2013

Approval expiry date: 10 December 2023

## **B.3.3 Liner bags**

### **Arlington Packaging (Rental) Ltd**

#### **Arlington 1000 Litre Bag-in-Box Combo Liner**

DWI 56/4/796

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Arlington 1000 Litre Water Tank

Issue: 4.2 Date of Issue: June 2020

This product is primarily intended for emergency use and is approved for limited use only and may not be permanently installed in, or used in conjunction with any system for treating or distributing public water supplies. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use.

Approval expiry date: 5 August 2025

## **PART C LINING, COATINGS, SEALANT AND REPAIR MATERIALS**

### **C.1 In-situ Installed (tubular) pipe linings**

#### **Aqualiner Ltd**

##### **Water Pipe Lining**

DWI 56/4/910

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Water Pipe Lining. Version No 5 Issue Date: 21 October 2010

Approval expiry date: 6 November 2021

### **C.2 In-situ applied Pipe Coatings**

In-situ applied lining products approved for use by the Authorities for the relining of existing water mains/pipes must be applied in accordance with strict operational requirements as documented in the Water Industry Information & Guidance Note IGN 4-02-02 <http://www.water.org.uk/home/member-services/wis-and-ign/archived-documents/ign-4-02-02.pdf> "Code of Practice: In-situ resin lining of water mains" and the Water Industry Specification WIS 4-02-01 <http://www.water.org.uk/home/member-services/wis-and-ign/archived-documents/wis-4-02-01-v2.1---march-2009.pdf> "Operational Requirements: In situ resin lining of water mains".

The coatings listed in this section have been subject to review by DWI (including testing), on the basis of their proposed use with inert substrates such as metallic or cement based structures (or as specified in the manufacturer's Instructions for Use (IFU)), and upon the detailed application and curing requirements set out in the IFU. They have not been evaluated for any other aspect, such as fitness for purpose.

For use with other non-metallic non-cementitious materials, such as plastics, other coatings/linings, and rubbers, a specific application for approval would be required for use of the coating with a specific substrate.

#### **C.2.1 Coatings based on epoxy resins**

These products must be applied by a certified contractor.

#### **Radius Subterra – a part of RadiusPlus Ltd**

##### **Subcote 173/90**

WS 34/1/124a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Subterra Subcote 173/90 Issue 10. Date 22 Sept 2017

Approval expiry date: 4 October 2022



## C.2.2 Coatings based on polyurethane

These products must be applied by a certified contractor.

### 3M United Kingdom

#### **3M Scotchkote Pipe Protection Liner 2100**

DWI 56/4/1037

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU 29P-2100

In-situ rapid setting polymeric lining of potable water mains. Coating system 3M Scotchkote Pipe Protection Liner 2100

Issue 7 – January 2018

Approval expiry date: 15 March 2023

#### **3M Scotchkote Pipe Renewal Liner 2400**

DWI 56/4/1031

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 3M Scotchkote Pipe Renewal Liner 2400 Instructions for Use Document 29P-2400 June 2017 Issue number 6

Approval expiry date: 2 October 2022

### Radius Subterra – a part of RadiusPlus Ltd

#### **Subcote FLP II**

DWI 56/4/1286

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue date 16 August 2019, Issue No. 6

The minimum cure time is one hour at a minimum temperature of 3°C

Approval expiry date: 30 March 2025

## C.2.3 Coatings for small diameter pipes

This section covers pipes up to 75 mm internal diameter. The products listed in this section shall be applied by certified contractors in accordance with strict operational requirements as documented in the Water Industry Specification WIS 4-02-03 "Operational Requirements : In-situ polymeric lining of service pipes" (document is available from <https://www.water.org.uk/publications/WIS-IGN>)

### 3M United Kingdom

#### **3M Scotchkote Rapid Setting Polymeric Lining 166L**

DWI 56/4/1032

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 29P-SP. Issue No: 7. Issue Date: March 2017

Approval expiry date: 29 July 2022

### Pipe Restoration Technologies LLC

#### **ePipe UK**

DWI 56/4/995

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IN-SITU HYDROPHOBIC POLYMERIC LINING OF POTABLE WATER SERVICE LINES. Internal Coating System ePIPE® UK

Issue Date: July 6, 2017 Issue No: 010

Approval expiry date: 1 October 2022

## **C.3 Site applied coatings for water retaining structures**

The products listed below in this section, in addition to being approved for site applied coatings for water retaining structures, are suitable for use in large diameter mains where they can be applied by hand e.g. brush or spray.

The coatings listed in this section have been subject to review by DWI (including testing), on the basis of their proposed use with inert substrates such as metallic or cement based structures (or as specified in the manufacturer's Instructions for Use (IFU)), and upon the detailed application and curing requirements set out in the IFU. They have not been evaluated for any other aspect, such as fitness for purpose.

For use with other non-metallic non-cementitious materials, such as plastics, other coatings/linings, and rubbers, a specific application for approval would be required for use of the coating with a specific substrate.

### **C.3.1 Coatings based on epoxy resins**

The following conditions apply unless otherwise indicated:

- (i) the minimum cure time is 16 hours; and
- (ii) the minimum cure temperature is 3°C.

#### **Radius Subterra – a part of RadiusPlus Ltd**

##### **Subcote 173/90**

WS 34/1/124b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Subterra Subcote 173/90 Issue 4. Date 22 September 2017

Approval expiry date: 4 October 2022

#### **Sherwin-Williams Protective and Marine Coatings**

##### **Macropoxy P300**

DWI 56/4/253

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 9; Issue date: June 2020

Approval expiry date: 1 September 2021

#### **Sika Ltd**

##### **Sikagard 62**

DWI 56/4/197

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Sikagard 62 -2 part Epoxy protective coating Issue No :002 Issue Date: May 2012

The product must be cured in accordance with the cure curves provided in the Instructions for Use. The required cure time can be calculated by the user from the minimum daily temperature at the site of application. If the temperature cannot be measured and recorded then a minimum cure period of 21 days must be used.

Approval expiry date: 3 September 2022

## C.3.2 Coatings based on polyurethane

### Axalta Coating Systems

#### **Acothane DW Blue**

DWI 56/4/1059

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use Document - Acothane DW. Issue 8 dated November 2019

The product must be cured for a minimum period of 7 days at a minimum temperature of 3°C.

Approval expiry date: 24 November 2024

#### **Acothane DW Cream**

DWI 56/4/1052

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use Document - Acothane DW. Issue 8, dated November 2019

The product must be cured for a minimum period of 7 days at a minimum temperature of 3°C.

Approval expiry date: 24 November 2024

#### **Acothane LV Sealer**

DWI 56/4/1058

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use Document - Acothane DW. Issue 8, dated November 2019

The product must be cured for a minimum period of 3 hours at a minimum temperature of 3°C, this product must then be overcoated with Acothane DW.

Approval expiry date: 24 November 2024

### BASF plc Construction Chemicals (UK) Ltd

#### **Masterseal M 808**

DWI 56/4/1080a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal M808 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 5 22052018

Approval expiry date: 29 November 2024

#### **Masterseal M 808 additional light grey colour**

DWI 56/4/1080b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal M808 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 5 22052018

Approval expiry date: 29 November 2024

### **Line-X Protective coatings**

#### **Aquaurethane Extreme**

DWI 56/4/874

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU). LINE-X Aquaurethane Extreme. Issue number 7, August 2016

- i) The product must be cured for a minimum of 5 days at a minimum substrate temperature of 3°C and
- ii) this product is for use on water retaining structures only.

Approval expiry date: 18 September 2021

### **Radius Subterra – a part of RadiusPlus Ltd**

#### **Subcote FLP II**

DWI 56/4/1286b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Subcote FLP II Product Description and Manufacturer's IFU: Issue date 1 April 2020, Issue No 2

The minimum cure time is one hour at a minimum temperature of 3°C

Approval expiry date: 31 March 2025

## **C.4 Flexible covers and linings for water retaining structures**

Note: Laminated flexible covers and linings for water retaining structures may not necessarily have been assessed for uses totally immersed in water, e.g. as baffles. For information on use see individual product Instructions for Use (IFU) document.

### **Flag S.p.a**

#### **Flagon Geo P/AT**

DWI 56/4/856

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MANUFACTURER'S OFFICIAL INSTRUCTIONS FOR USE (IFU). ISSUE NUMBER: 3. 18.02.2014. PRODUCT: FLAGON GEO P/AT

Approval expiry date: 4 October 2022

### **Power Plastics Ltd**

#### **PowerPlas® TL850 Tank Liner**

DWI 56/4/1385

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Date: Dec 2019; Issue No. 1.0

Approval expiry date: 26 January 2025

### **Sensor (UK) Ltd**

#### **Sensorline**

DWI 56/4/1066a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SENSORLINE – PE GEOMEMBRANES (IFU VERSION 4.9)

Issue date 9 November 2015

Approval expiry date: 19 March 2023

## C.5 Cementitious coatings

### **BASF plc Construction Chemicals (UK) Ltd**

#### **MasterSeal 581**

DWI 56/4/1227

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 581 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 2 22052018

This product must be cured for a minimum of 3 days at a minimum temperature of 3°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 30 June 2021

#### **MasterSeal 581 with MasterSeal 600**

DWI 56/4/1103

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 581 with MasterSeal 600 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 2 22052018

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 28 April 2024

#### **MasterSeal 586 with MasterSeal 600**

DWI 56/4/86

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 586/MasterSeal 600 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 3 22052018

Approval expiry date: 30 March 2025

#### **MasterSeal 588**

DWI 56/4/1128

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 588 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 3 22052018

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 28 April 2024

### **FIS Products**

#### **Premcrete Hydroseal FX**

DWI 56/4/1356

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: UXHP 1017 Revision date: 11/03/2019

The product must be cured in accordance with the cure curves provided in the Instructions for Use. The required cure time can be calculated by the user from the minimum daily temperature at the site of application. If the temperature cannot be measured and recorded then a minimum cure period of 21 days must be used. The minimum temperature for application is 7°C

Approval expiry date: 17 May 2022

**Premcrete Teknolevel FS**

DWI 56/4/1359

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 01587 Revision, Date 19/06/2019

Approval expiry date: 5 November 2025

**Flexcrete Technologies Ltd**

**Cementitious Coating 851 Grey**

DWI 56/4/1159

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Cementitious Coating 851 Grey

Issue: 851/031/011 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Cementitious Coating 851 White**

DWI 56/4/1160

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Cementitious Coating 851 White

Issue: 851/031/011 | Issue Date: July 2020

This product must be cured for a minimum of 7 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Cemprotec 851F**

DWI 56/4/1340

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE IN PUBLIC SUPPLY CEMPROTEC 851F

Issue date: October 2018; Issue No: 851F/031/001

Approval expiry date: 16 June 2024

**Monolevel 844SP**

DWI 56/4/1161

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Monolevel 844SP Issue: ML844SP/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**International Paint Ltd**

**Intercrete 4820**

DWI 56/4/1054

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4820 Issue: 4820/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 17 May 2022

**Intercrete 4841**

DWI 56/4/1053

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4841 Issue: 4841/031/011 | Issue Date: July 2020  
 The Grey product must be cured for a minimum of 21 days at a minimum temperature of 7°C and the White product must be cured for a minimum of 7 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU  
 Approval expiry date: 27 October 2025

**Vandex International Ltd**

**CEMLINE UM1**

DWI 56/4/1099

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VXI IFU UK CEMLINE UM1, 12.2015 / 1  
 Approval expiry date: 2 December 2023

**CEMLINE BB-W**

DWI 56/4/1093

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VXI IFU UK CEMLINE BB-W, 12.2015 / 1  
 Approval expiry date: 2 December 2023

**CEMLINE CG**

DWI 56/4/1094

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VXI IFU UK CEMLINE CG, 12.2015 / 1  
 Approval expiry date: 2 December 2023

**VANDEX BB 75**

DWI 56/4/1092

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 2 Date: 04/11/2020  
 Approval expiry date: 2 December 2023

**VANDEX PREMIX**

DWI 56/4/1097

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 1.12.2013/1st issue  
 Approval expiry date: 2 December 2023

**VANDEX SUPER**

DWI 56/4/1098

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 1/12/2013/1st issue  
 Approval expiry date: 2 December 2023

**Xypex (UK) LLP**

**Xypex Concentrate**

DWI 56/4/1261

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ISSUE NO: 0921C: 3rd April 2019 (221019-C): XDS: Rev-04-16  
 Approval expiry date: 16 February 2022

**Xypex Modified**

DWI 56/4/1262

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE. XYPEX MODIFIED. ISSUE NO: 1210M – 12th October 2016  
 Approval expiry date: 16 February 2022

## C.6 Sealant & Repair Materials

### **BASF plc Construction Chemicals (UK) Ltd**

#### **MasterEmaco S420 with MasterSeal 600**

DWI 56/4/1064

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterEmaco S420 with MasterSeal 600 - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 2 22052018

Before connection to the supply, the water undertaker or their appointed agent, must carry out tests to establish that migration from the cement mortar lining will not cause a contravention of the upper prescribed concentration for hydrogen ion in the relevant Regulations . This product must be cured for a minimum of 3 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 25 February 2023

#### **MasterSeal 930 and MasterSeal 933**

DWI 56/4/144

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MasterSeal 930 joint bandage with MasterSeal 933 adhesive - APPLICATION TO POTABLE WATER CONTACT AREAS INSTRUCTIONS FOR USE Ref Rev 2 22052018

This product must be cured for a minimum of 10 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturer's instruction for use document

Approval expiry date: 28 April 2024

### **FIS Products**

#### **Premcrete Teknocem HB50**

DWI 56/4/1357

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 01553 Revision, Date 18/06/2019

Approval expiry date: 27 October 2025

#### **Premcrete Teknocem Rapid**

DWI 56/4/1358

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CODE: UXHP 1076 REVISION DATE: 11.03.19

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 5 October 2021

#### **Premcrete Teknoprime 841**

DWI 56/4/1360

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CODE: UXHP 1091 REVISION DATE: 11.03.19

Approval expiry date: 16 May 2022



**Premcrete Tie Hole Sealer**

DWI 56/4/1361

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: CODE: UXHP 1305 REVISION DATE: 18.12.2015

Approval expiry date: 1 October 2022

**Flexcrete Technologies Ltd**

**Fastfill**

DWI 56/4/1162

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Fastfill Issue: FFILL/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Monomix**

DWI 56/4/1163

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply MONOMIX Issue: MMIX/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Monomix WS**

DWI 56/4/397

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply MONOMIX WS

Issue: MMIXWS/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Steel Reinforcement Protector 841**

DWI 56/4/1164

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Steel Reinforcement Protector 841 Issue: 841/031/009 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Tiefill**

DWI 56/4/1287

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Tiefill Issue: TFILL/031/003 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Fosroc Ltd**

**Conbextra Bedding Mortar**

DWI 56/4/1271

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Conbextra Bedding Mortar IFU Issue date: Apr 2017; Issue number BM1

Approval expiry date: 28 November 2022

**Renderoc Plug 20**

DWI 56/4/297

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Renderoc Plug 20. Instructions for use. Ref: RRP20 IFU v3; Apr 13

Approval expiry date: 26 April 2023

**International Paint Ltd**

**Intercrete 4800**

DWI 56/4/1403

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4800 Issue: 4800/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Intercrete 4800WS**

DWI 56/4/1408

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4800WS Issue: 4800WS/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Intercrete 4802**

DWI 56/4/1055

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4802 Issue: 4802/031/010 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 17 October 2025

**Intercrete 4807**

DWI 56/4/1404

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4807 Issue: 4807/031/003 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**Intercrete 4871**

DWI 56/4/1056

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use in Public Water Supply Intercrete 4871 Issue: 4871/031/009 | Issue Date: July 2020

This product must be cured for a minimum of 21 days at a minimum temperature of 7°C or in accordance with the cure curve provided in the manufacturers IFU

Approval expiry date: 27 October 2025

**MG Solutions (UK) Ltd**

**Aquron 2000**

DWI 56/4/1291

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Aquron 2000 Colloidal Silicate for waterproofing of concrete IFU. Issue Date 21/08/2017; Issue Number 1.1

Approval expiry date: 2 November 2022

**Natural Cement Distribution Ltd**

**NATCEM 35**

DWI 56/4/1090

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Product Information: NATCEM 35 Fast Setting and Fast Curing Mortar . Issue date 26/06/2017 issue number 01

Approval expiry date: 10 March 2023

**NATCEM AC**

DWI 56/4/840

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Natcem AC 10 January 2020 Issue 3

Approval expiry date: 5 May 2025

**NATCEM D**

DWI 56/4/1216

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DRY PRE-BLENDED GROUT NATCEM D

Issue Date: 23/03/16, Issue Number 1

Approval expiry date: 27 December 2021

**NATCEM DW**

DWI 56/4/1049

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Natcem DW- Fast Setting Mortar. Issue date: 2013-03020; Issue number: 01

Approval expiry date: 10 March 2023

**Shotcrete 513**

DWI 56/4/1089

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Shotcrete 513 - Fast Setting Dry Spray Concrete. Issue date: 2017-06-26; Issue number: 01

Approval expiry date: 10 March 2023

**Waterstop**

DWI 56/4/1217

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: FAST SETTING NATURAL CEMENT WATERSTOP

Issue: 2, Date: 20/10/2016

Approval expiry date: 27 December 2021

### **Penetron UK Ltd**

#### **Penecrete Mortar**

DWI 56/4/1130

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use PENECRETE MORTAR CRYSTALLINE WATERPROOF MORTAR. Issue No:2, (Dated: 12/02/2014, Re-issued: 05/03/2017)

Approval expiry date: 1 October 2024

#### **Penectron Crystalline Waterproof Coating**

DWI 56/4/1137

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instruction for Use PENETRON CRYSTALLINE WATERPROOF COATING. Issue I / 2, (Issue date: 19/05/2014, Revision date: 09/02/2017)

Approval expiry date: 1 October 2024

### **Sika Ltd**

#### **Sika Monotop 610/615 Concrete Repair System**

DWI 56/4/834

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sika Mono Top – 615 Cementitious High Build Concrete Repair Mortar. Issue No: 001. September 2007

The product must be cured in accordance with the cure curves provided in the IFU. The required cure time can be calculated by the user from the minimum daily temperature at site of application. If the temperature cannot be measured and recorded then a minimum cure period of 21 days at a minimum substrate temperature for application is 5°C.

Approval expiry date: 12 March 2022

#### **Sikadur Combiflex SG jointing system using Sikadur 31 DW**

DWI 56/4/94

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sikadur Combiflex SG Jointing system Issue No:006 October 2011

The minimum cure temperature is 7°C for a minimum cure time of 21 days. At temperatures greater than 7°C the product must be cured in accordance with the cure curve provided in the Instructions For Use. The required cure time can be calculated by the user from the minimum daily temperature which must be recorded at site.

Approval expiry date: 3 October 2021

#### **Sikadur Combiflex SG jointing system, using Sikadur 31 DW Rapid**

DWI 56/4/1124

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Sikadur Combiflex SG Jointing System, using Sikadur 31 DW Rapid. Issue No: 01, September 2013

Approval expiry date: 4 February 2025

### **Vandex International Ltd**

#### **CEMLINE STON**

DWI 56/4/1095

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: VXI IFU UK CEMLINE STON, 12.2015 / 1

Approval expiry date: 2 December 2023

**Vandex Plug**

DWI 56/4/1096

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 7.11.2018 / 3rd issue

Approval expiry date: 2 December 2023

**Xypex (UK) LLP**

**Xypex Admix C-1000 NF**

DWI 56/4/1263

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No 1210A1 - 12th October 2016

Approval expiry date: 16 February 2022

**Xypex Admix C-500 NF**

DWI 56/4/1244

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: XYPEX(UK) LLP IFU - XYPEX ADMIX C-500 NF. Issue date: 4th December 2018; Issue number : 0920A5

Approval expiry date: 28 January 2024

**Xypex Patch'n Plug**

DWI 56/4/1100

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ISSUE NO: 1623P: 16TH April 2019 (310719-C): XDS: Rev-06-16

Approval expiry date: 5 June 2024

## PART D MEMBRANE AND FILTRATION SYSTEMS

For products in this section the following general condition applies:

Products must be installed upstream of any final point of disinfection.

### D.1 Membrane and Filtration Elements/Systems

#### Amazon Filters Ltd

##### **Amazon SupaGard Cartridge Filters**

DWI 56/4/702

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE. AMAZON SUPAGARD AND SUPASPUN II FILTER CARTRIDGES. ISSUE NUMBER: 9. DATE: 25th February 2010

Approval expiry date: 11 August 2025

##### **Amazon SupaSpun II Cartridge Filters**

DWI 56/4/702

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE. AMAZON SUPAGARD AND SUPASPUN II FILTER CARTRIDGES. ISSUE NUMBER: 9. DATE: 25th February 2010

Approval expiry date: 11 August 2025

#### DuPont Water Solutions

##### **Memcor CMF- S S10V Range of Microfiltration submodules (submerged PVDF Membranes)**

DWI 56/4/973

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF-S S10V MICROFILTRATION SUBMODULES (SUBMERGED PVDF MEMBRANES). Issue:- M Date:- 03/03/2020

Approval expiry date: 19 January 2022

##### **Memcor CMF-L L10N**

DWI 56/4/1254

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MEMCOR CMF-L L10N RANGE OF MICROFILTRATION SUBMODULES (PVDF MEMBRANES)

Issue date: 03/03/2020 Issue No: OM-12596C

Approval expiry date: 5 March 2022

##### **Memcor CMF-L L10V Range of Microfiltration Submodules (PVDF Membranes)**

DWI 56/4/977

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF-L L10V MICROFILTRATION SUBMODULES (PVDF MEMBRANES). Issue:-J Date:- 03/03/2020

Approval expiry date: 19 January 2022

**Memcor CMF-L L20N**

DWI 56/4/1255

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MEMCOR CMF-L L20N RANGE OF MICROFILTRATION SUBMODULES (PVDF MEMBRANES)

Issue date: 03/03/2020 Issue No: OM-12597C

Approval expiry date: 5 March 2022

**Memcor CMF-L L20V Range of Microfiltration Submodules (PVDF Membranes)**

DWI 56/4/978

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF-L L20V MICROFILTRATION SUBMODULES (PVDF MEMBRANES). Issue:-E Date:- 03/03/2020

Approval expiry date: 19 January 2022

**Memcor CMF-L L40N**

DWI 56/4/1305

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use document for the MEMCOR CP2 L40N ULTRAFILTRATION SUBMODULE (PVDF MEMBRANE)

Issue date: 03/03/2020; Issue No: OM-13807 B

Products must be installed upstream of any final point of disinfection

Approval expiry date: 22 January 2023

**Memcor CMF-M10C Continuous Microfiltration Module (Polypropylene Membranes)**

DWI 56/4/975

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF M10C CONTINUOUS MICROFILTRATION MODULE (POLYPROPYLENE MEMBRANES). Issue:- G Date:- 03/03/2020

Approval expiry date: 19 January 2022

**Memcor CMF-S S10N**

DWI 56/4/1256

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: MEMCOR CMF-S S10N RANGE OF MICROFILTRATION SUBMODULES (SUBMERGED PVDF MEMBRANES)

Issue date: 03/03/20 Issue No: OM-13219B

Approval expiry date: 5 March 2022

**Memcor CMF-S S10T Microfiltration Submodule (submerged Polypropylene Membranes)**

DWI 56/4/976

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT FOR THE MEMCOR CMF-S S10T MICROFILTRATION SUBMODULE (SUBMERGED POLYPROPYLENE MEMBRANES). Issue:-H Date:- 03/03/2020

Approval expiry date: 19 January 2022

**Envirogen Group**

**Deltapor MW and MWA Filter Cartridges**

DWI 56/4/1274

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Envirogen Deltapor MW and MWA Filter Cartridges, Issue Date; 26/09/2017; Issue Number 2

Approval expiry date: 3 April 2023

### **Hydranautics**

#### **HYDRAcap**

DWI 56/4/689

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HYDRAcap Membrane Ultrafiltration Module Instructions for Use, Issue 7 dated 23/1/2013

Approval expiry date: 1 March 2022

### **Mecana Umwilttechnik GmbH**

#### **Pile Cloth Media Filter (PCMF) DW2/10 - DW27/135**

DWI 56/4/1215

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Document. Application for a pile cloth filtration system in drinking water scope. Filter types DW2/10 - DW27/135 Issue Number: Rev. 5; Issue Date 24th May 2019

Approval expiry date: 28 November 2022

### **Microdyn-Nadir US Inc**

#### **8040-SBNF-DWI Membrane Elements**

DWI 56/4/1218

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use 8040-SBNF-DWI Membrane Elements Version 1.1; Issue date: 22 February 2017

Products must be installed upstream of any final point of disinfection

Approval expiry date: 21 December 2022

#### **8040-SBUF-DWI**

DWI 56/4/1030

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use. 8040-SBUF-DWI Membrane Elements. Version 1.1 Issued 22 February 2017

Approval expiry date: 15 November 2023

### **Pall Corporation**

#### **Pall GF Plus Filter Units, Type MWH27**

Dwi 56/4/1336

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU for Pall® 'GF Plus' filter units Type 'MWH27'. Issue 9 17/01/2019

Products must be installed upstream of any final point of disinfection

Approval expiry date: 30 January 2025

### **Pall International Sarl**

#### **Pall Microza UNA-620C microfiltration module**

DWI 56/4/795

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use for membrane products in water supply - Instructions for use document for Pall Microza UNA-620C Micro-filtration modules, Issue number 3, Date of issue: 26 July 2006

Approval expiry date: 16 August 2025



### **PCI Membranes**

#### **C10 Module**

DWI 56/4/234

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue J, 1 Nov 2017

Approval expiry date: 11 December 2021

#### **CA202 membrane**

DWI 56/4/76

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue No K, 1 Nov 2017

Approval expiry date: 12 December 2021

#### **ES404 membrane**

DWI 56/4/215

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue No N, 1 Nov 2017

Approval expiry date: 12 December 2021

### **PWN Technologies**

#### **CeraMac® Technology**

DWI 56/4/1179

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Dated: 11/02/2016 Issue No: 1.1 Rev 1.3

Approval expiry date: 17 January 2022

### **SUEZ Water Technologies & Solutions**

#### **Absolute.Za\*DWI**

DWI 56/4/1325

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: ABSOLUTE.ZA DWI® Issue Date 30/07/2019; Issue No. Rev 1 Products must be installed upstream of any final point of disinfection

Approval expiry date: 5 March 2024

#### **Ultrafiltration element ZW700B-8060/UF10/7B/R/0.8/40**

DWI 56/4/1125

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: UKDWI/ZW700B-8060/Version 1. Date of issue: 08 January 2018

Approval expiry date: 19 January 2021

#### **Ultrafiltration element ZW700B-8060/UF10/7B/X/0.8/40**

DWI 56/4/1126

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: UKDWI/ZW700B-8060/Version 1, Date of issue: 08 January 2018

Approval expiry date: 19 January 2021

#### **ZeeWeed 500c, Membrane Filtration Module**

DWI 56/4/628

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed 500c Membrane Filtration Module. Document number: UKDWI/500c Revision 7. Date of Issue: 08 January 2018.

Approval expiry date: 8 February 2022

**ZeeWeed 500d (340) Membrane Filtration Module**

DWI 56/4/835

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 500d (340),500d (440), 500ds (350) Membrane Filtration Modules

Document number: UKDWI/500d Revision 8

Date of Issue: 12th May 2020

Approval expiry date: 21 February 2021

**ZeeWeed 500d (440) Membrane Filtration Module**

DWI 56/4/835

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 500d (340),500d (440), 500ds (350) Membrane Filtration Modules

Document number: UKDWI/500d Revision 8

Date of Issue: 12th May 2020

Approval expiry date: 21 February 2021

**ZeeWeed 500ds (350) Membrane Filtration Module**

DWI 56/4/835

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 500d (340),500d (440), 500ds (350) Membrane Filtration Modules

Document number: UKDWI/500d Revision 8

Date of Issue: 12th May 2020

Approval expiry date: 21 February 2021

**SUEZ Water Technologies and Solutions Hungary Kft**

**ZeeWeed® 700B-9060 Membrane Module**

DWI 56/4/1349

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document For element ZW700B-9060/UF10/7B/XA/0.8/55

Issue date: 8 May 2019; Issue No: UKDWI/ZW700B-9060-v4

Products must be installed upstream of any final point of disinfection

Approval expiry date: 11 June 2024

**ZeeWeed 1000 V4**

DWI 56/4/1177

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 1000 V4 module. Document number: UKDWI/1000V4/R1. Date of Issue: 23 January 2018

Approval expiry date: 27 April 2025

**ZeeWeed 1500 Series**

DWI 56/4/1013

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the ZeeWeed® 1500 Series. Document number: UKDWI/1500/Revision 8. Date of Issue: 20 November 2018

Products must be installed upstream of any final point of disinfection

Approval expiry date: 10 June 2024

**X-FLOW B.V.**

**Aquaflex**

DWI 56/4/324

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: X-Flow Membrane Filtration Elements Version 7.0 26 May 2015

Approval expiry date: 18 August 2025

**Aquaflex HP**

DWI 56/4/967

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use for X-Flow Membrane Filtration Elements Version 7 26/05/2016

Approval expiry date: 21 November 2021

**HFW 1000**

DWI 56/4/1139

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU for HFW 1000, Version 1.2, Issue date: 15-10-2014  
Products must be installed upstream of any final point of disinfection.

Approval expiry date: 29 September 2021

**XIGA HP**

DWI 56/4/1023

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions For Use for X-Flow Membrane Filtration Elements Version 7 26/05/2016

This product must be installed upstream of any final point of disinfection.

Approval expiry date: 19 March 2023

## **D.2 Vessels and Containers for Membrane and Filtration Elements**

**Amazon Filters Ltd**

**Single and Multiple Cartridge & Bag Filter Housings and Interconnecting pipework**

DWI 56/4/879

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Amazon Single and Multiple Cartridge & Bag Filter Housings and Interconnecting Pipework: INSTRUCTIONS FOR USE IN DRINKING WATER SYSTEMS. Issue 2 November 2016

Approval expiry date: 11 August 2025

**Eliquo Hydrok**

**Eliquo Hydrok Filter Housing Tank**

DWI 56/4/1386

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Version 1 Dated: 20/11/2019

Approval expiry date: 21 January 2025

**Envirogen Group**

**Envirogen CF Filter Housing**

DWI 56/4/1257

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: INSTRUCTIONS FOR USE ENVIROGEN CF FILTER HOUSING

Issue date: 01/12/2016 Issue number: 1

Approval expiry date: 12 March 2022

**Evoqua Water Technologies Ltd**

**SFH PFH SSS Filter housing**

DWI 56/4/1191

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: SPECTRUM\_PFH-SPC1\_INSTALLATION –  
INSTRUCTIONS\_0615v1 and SPECTRUM\_SFH-  
SPC1\_INSTALLATION –INSTRUCTIONS\_0615v1

Approval expiry date: 30 November 2021

**Fileder Filter Systems**

**EFH/SFH/PFH (Cartridge Housings)**

DWI 56/4/848

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: Range of 316 Stainless Steel Filter and Bags Housing . Version  
2 . Issue date 18/10/11

Approval expiry date: 30 November 2021

**SBH and PBF Stainless Steel Bag Housing**

DWI 56/4/848

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: Range of 316 Stainless Steel Filter and Bags Housing . Version  
2 . Issue date 18/10/11

Approval expiry date: 30 November 2021

**SFH and PFH Stainless Steel Filter Housing**

DWI 56/4/848

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: Range of 316 Stainless Steel Filter and Bags Housing . Version  
2 . Issue date 18/10/11

Approval expiry date: 30 November 2021

**Filertec Systems Ltd**

**CF-DW Series cartridge filter housings**

DWI 56/4/1331

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: FILTERTEC CF-DW FILTER HOUSING Issue date: 19/08/2018;  
Issue No: 2

Approval expiry date: 13 September 2023

**Pentair Water India Pvt Ltd**

**Codeline RO Membrane Housing Codeline 80S Series (Coded Vessels)**

DWI 56/4/288

Conditions of Approval: Use of the product must be in accordance with the Instructions for  
Use: No 94566-NC, Issue No 3, Date Aug13

The product may only be used upstream of reverse osmosis filtration

Approval expiry date: 29 June 2021

**Codeline RO Membrane Housing Codeline 80S Series (Non-coded Vessels)**

DWI 56/4/288

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: No 94566- NC, Issue No 3, Date Aug 13

The product may only be used upstream of reverse osmosis filtration

Approval expiry date: 29 June 2021

## **D.3 Electrolysis Water Treatment Units**

**Suez Water Technologies & Solutions (USA Inc)**

**MK IV EDR Water Treatment System**

DWI 56/4/480

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: System: MK IV EDR Water Treatment Systems, Revision 1, February 2018

Approval expiry date: 10 September 2024

## **D.4 Filter Media Containing Systems**

**Amiad Water Systems UK Ltd**

**DVF Media Filters**

DWI 56/4/1249

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Amiad Water Systems Automatic Filters DVF Media Filters, Issue No: 16 Rev.1 Issue Date: 10.10.2016

Approval expiry date: 11 May 2022

**DYNAMIK FILTR Nocoń iWspólnicy Spółka Jawna**

**PRESSURE FILTRATION KIT DF FP/FDN 800÷3 500**

DWI 56/4/1272

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue Number: FP/FDN 800÷3 500/001/017 IFU; Issue Date:

01:02:2017

Approval expiry date: 20 December 2022

**Hydro-Gen Engineering Ltd**

**Velocitek OVF Filter Vessel**

DWI 56/4/1400

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for use Velocitek OVF Filter Vessel. Issue Date: 14.04.2020; Version No. 2

Approval expiry date: 28 July 2025

## **PART E OTHER WATER TREATMENT WORKS INSTALLATIONS**

### **E.1 Tanks**

#### **ABC Stainless Steel Ltd**

##### **Storage, process tanks and vessels**

DWI 56/4/542b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use : Stainless steel storage, Process Tanks and Vessels . Issue no: 2 Date: 20th October 2003

Approval expiry date: 4 January 2023

#### **Allied Storage Tank Ltd**

##### **Stainless Steel Tanks and Launderers**

DWI 56/4/1258

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date: 30/01/2017 Issue No.1

Approval expiry date: 26 February 2022

#### **Asset International Ltd**

##### **Weholite Pipe and Panels**

DWI 56/4/513b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Weholite HDPE Pipes and Panels - Issue 5 September 2018

Approval expiry date: 2 February 2024

#### **Barr + Wray Ltd**

##### **Barr + Wray Stainless Steel Media Filter**

DWI 56/4/1234a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue No: 1, 20 July 2016

Approval expiry date: 21 November 2021

#### **Berry & Escott Engineering**

##### **Stainless Steel Pipework and Fabrications**

DWI 56/4/1362a

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Stainless Steel Fabricated Pipework

Approval expiry date: 1 May 2024

#### **CST Industries Ltd**

##### **Aquastore Vitrium EN**

DWI 56/4/621

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: AQUASTORE STORAGE TANKS INSTRUCTIONS FOR USE (IFU). Version 7 20 June 2017

Approval expiry date: 15 July 2022

**EPS Group**

**Stainless Steel Tanks & Pipework**

DWI 56/4/1267

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: EPS Group - Stainless Steel Tanks & Pipework, Issue 1  
10/03/17

Approval expiry date: 27 March 2022

**Filtec Water Services Ltd**

**Filtec "Selkie" Stainless Steel Products**

DWI 56/4/1396b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HANDLING, INSTALLATION AND COMMISSIONING INSTRUCTIONS FOR THE FILTEC SELKIE RANGE OF STAINLESS STEEL PRODUCTS FOR USE IN CONTACT WITH TREATED OR PARTIALLY TREATED POTABLE WATER. Dated: 29/04/2020; Issue No: 01; Rev 02

Approval expiry date: 17 May 2025

**Forbes Technology Ltd**

**Cheetah range of Tanks & Towers**

DWI 56/4/1292

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Handling, Installation and Commissioning Instructions for the Forbes 'Cheetah' range of storage & process tanks & towers to comply with Regulation 31 Issue no: QA379 Rev 05

Approval expiry date: 19 October 2022

**Jaguar Range of Storage & Process Tanks & Towers**

DWI 56/4/1210

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HANDLING, INSTALLATION AND COMMISSIONING INSTRUCTIONS FOR THE FORBES JAGUAR RANGE OF STORAGE & PROCESS TANKS & TOWERS

Issue Date: 10-10-2016 Issue No: QA427 Rev 02 Issue 1

Approval expiry date: 19 October 2021

**Lion Range of Tanks & Towers**

DWI 56/4/1293

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Handling, Installation and Commissioning Instructions for the Forbes 'Lion' range of storage & process tanks & towers to comply with Regulation 31 Issue no:QA378 Rev 05

Approval expiry date: 19 October 2022

**Homer Burgess Ltd**

**Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water**

DWI 56/4/1107b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Title: Homer Burgess Ltd., Manufacturer's official use instructions for Stainless Steel Products in contact with Drinking Water.. Issue Number Rev. 1 26/01/2016

Approval expiry date: 22 May 2023

**J.K Fabrications Limited**

**JKF 304 and 316 Stainless Steel Tanks**

DWI 56/4/732

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 3 Dated 10 December 2019

Approval expiry date: 21 January 2025

**Monostore Ltd**

**Monostore SST - Recognised Grade Tanks**

DWI 56/4/1374

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 01/08/2019 Version 2.0

Approval expiry date: 31 July 2024

**Ocean Kinetics Ltd**

**Unlined 316 & 316L Stainless Steel Tanks and Pipework**

DWI 56/4/1395b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: OK-IFU-2020-001 Rev 1; Issue date: 16/04/20

Approval expiry date: 22 April 2025

**Permastore Ltd**

**Fusion ® V1100**

DWI 56/4/1214

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date 01/03/16, Issue number: P238 Rev 1

Approval expiry date: 19 December 2021

**Isofusion (vitreous enamelled tank)**

DWI 56/4/594

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU P236 Rev 2 - IFU and Installation of ISOFUSION V700 Tanks for the storage of water (issued 18/03/16)

Approval expiry date: 31 March 2021

**Trifusion ®**

DWI 56/4/1213

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue date 01/03/16, Issue Number: P285 Rev 1

Approval expiry date: 19 December 2021

**Powerrun Pipe-Mech Ltd**

**Stainless Steel Grade 316L Potable Water Reservoir Tanks**

DWI 56/4/611

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PWRT (PP-ML) Rev0 (First Issue) 16 April 2018

Approval expiry date: 11 September 2023

**Ross-shire Engineering Ltd**

**Stainless Steel Water Tanks**

DWI 56/4/1381

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: TECHNICAL SPECIFICATION No. TS/SW/002 Date 18/10/19

Approval expiry date: 9 January 2025



**Sayers Road Tankers Ltd**

**Stainless Steel Water Tanks**

DWI 56/4/1028

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use: Stainless Steel Water Tanks. Issue No: 2.  
Issue Date: 15th August 2011

Approval expiry date: 8 August 2021

**Silotank (Digestors, Silos & Tanks) Ltd**

**Leinster Range of Thermoplastic Tanks**

DWI 56/4/498

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Installation and Maintenance Manual For Leinster Range Of Thermoplastic Tanks For Drinking Water and Raw Water to be Treated for Drinking Water

Issue No. 7 Date: 14th August 2019

Approval expiry date: 9 March 2025

**Leinster Range of Towers**

DWI 56/4/498

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Installation and Maintenance Manual For Leinster Range Of Thermoplastic Tanks For Drinking Water and Raw Water to be Treated for Drinking Water

Issue No. 7 Date: 14th August 2019

Approval expiry date: 9 March 2025

**Staptina Engineering Services Ltd**

**Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems**

DWI 56/4/567b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 24838IFU 12 June 2013

Approval expiry date: 31 March 2024

## **E.2 Underdrains**

For some products, including underdrains, Section 3.4 of Advice Sheet 7 indicates that products constructed from clay can be used without approval subject to the water supplier carrying out a risk assessment for suitability of the product and its possible impact on drinking water quality

### **Black & Veatch**

#### **K Filter Floor**

DWI 56/4/833

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Installation & Test Procedure for K-Type Filter Floors Document  
Ref: SSD 019 - Issue: L - Issue Date: 01/09/2020

Approval expiry date: 3 November 2025

### **De Nora Water Technologies UK Services Ltd**

#### **Tetra LP Block System**

DWI 56/4/522

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: INSTRUCTIONS FOR USE DOCUMENT. LP Block Underdrain System. Issue number: 4 Date: 22 September 2020

Approval expiry date: 10 October 2025

### **Plasmor Ltd**

#### **Plasmor E and U Blocks**

DWI 56/4/988

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Plasmor E Blocks Instructions for Use . Issue 2. Issue Date: 22/12/2010

Approval expiry date: 5 March 2022

### **WesTech Engineering Inc**

#### **MULTIBLOCK® Media Retaining Gravity Filter Underdrain**

DWI 56/4/1312

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Manufacturers Instructions for Use (IFU) MULTIBLOCK Gravity Filter Underdrains Version 1.2, Issue 2 Dated October 2018

Approval expiry date: 30 July 2025

### **Xylem Water Solutions Zellenople LLC**

#### **Leopold Type S Underdrain and I.M.S. 1000 Media Retainer**

DWI 56/4/1079

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type S Underdrain and I.M.S. 200 Media Retainer**

DWI 56/4/1078

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type S Underdrain and I.M.S. Cap**

DWI 56/4/371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type SL Underdrain and I.M.S. 1000 Media Retainer**

DWI 56/4/1079

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type SL Underdrain and I.M.S. 200 Media Retainer**

DWI 56/4/1078

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type SL Underdrain and I.M.S. Cap**

DWI 56/4/371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Flume Installation:

Type S®/SL® Universal Flume Instruction for Use Document  
TSLU-IFU-03

Date of Issue: 09 June 2020, Issue No: R03

Wall Installation:

Type S®/SL® Universal Wall Installation, Instruction for Use  
TSLU-WALL-IFU-R01

Date of Issue: 09 June 2020, Issue No: R01

Approval expiry date: 14 June 2025

**Leopold Type XA Underdrain and I.M.S. 1000 Media Retainer**

DWI 56/4/1105

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type XA (TM) Underdrain Flume Installation, Operation and Maintenance Manual

Date: 8th Aug 2017 Issue No: 2

Approval expiry date: 16 June 2024

**Leopold Type XA Underdrain and I.M.S. 200 Media Retainer**

DWI 56/4/1105

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type XA™ Underdrain Flume Installation, Operation and Maintenance Manual

Date: 8th Aug 2017 Issue No: 2

Approval expiry date: 16 June 2024

**Leopold Type XA Underdrain and I.M.S. Cap**

DWI 56/4/1105

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Type XA™ Underdrain Flume Installation, Operation and Maintenance Manual

Date: 8th Aug 2017 Issue No: 2

Approval expiry date: 16 June 2024

## E.3 Pressure vessels

### A J Metal Products Ltd

**Pressure Vessels**

DWI 56/4/1383

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU-1 A J METALS VESSELS FOR DRINKING WATER. Issue date: 29/11/19, Issue No: 1 Document No: AJMP IFU 001

Approval expiry date: 10 December 2024

### Barr + Wray Ltd

**Barr + Wray Stainless Steel Media Filter**

DWI 56/4/1234b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Issue No: 1, 20 July 2016

Approval expiry date: 21 November 2021

### **Charlatte Reservoirs**

#### **Hydrochoc Butyl Bladder Surge Vessel**

DWI 56/4/1016

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Commissioning General Instructions for Hydrochoc Butyl Bladder Surge Vessel for Clear Water. . Issue No: 2 Date of Issue: 2nd Nov 2016

Approval expiry date: 6 April 2022

### **CPE Pressure Vessels**

#### **CPE Pressure Vessels-304L and 316L Stainless Steel**

DWI 56/4/1135

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU-01 Rev 3 06/03/2013

Approval expiry date: 25 March 2024

### **Quantum Engineering Developments Ltd**

#### **Quantum Pressure Vessels- 304L**

DWI 56/4/1132

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU – 01, Rev D Issue date 31/01/2019

Approval expiry date: 30 March 2024

#### **Quantum Pressure Vessels- 316L**

DWI 56/4/1133

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU – 01, Rev D Issue date 31/01/2019

Approval expiry date: 30 March 2024

## **E.4 Other Products used for the treatment of water**

### **AJ Engineering and Construction Services Ltd**

#### **Stainless Steel Pipework and Fabrications**

DWI 56/4/1220b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Pipework and Fabrications for water use. Issue Number: WO41, Issue date: 04/08/2016

Approval expiry date: 19 September 2021

### **AMCON Europe s.r.o**

#### **Volute Dewatering Screw Press**

DWI 56/4/1144

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Volute Dewatering Press ES-CE-DW series Instruction Manual <Operation> (Ver.DW1.01) 15.06.2019

Volute Dewatering Press ES-CE-DW series Instruction Manual <Transportation and Installation> (Ver.DWT1.00) 15.06.2019

Supernatant from the press should either be returned to the head of the works or run to waste.

Approval expiry date: 15 October 2024

**Bridges Electrical Engineering Ltd**

**Bridges in-house fabricated stainless steel pipe spools and products** DWI 56/4/1268b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Bridges in-house fabricated stainless steel pipe spools and products, Issue 1 22/03/17

Approval expiry date: 14 May 2022

**Colloide Engineering Systems Ltd**

**Lamella Separator Package (LSF)** DWI 56/4/1172

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 90002-1502 B Date of Issue 10/02/2015

Approval expiry date: 23 February 2025

**Craley Group Ltd**

**Atlantis Hydrotec - T&M Series** DWI 56/4/1346

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Atlantis HYDROTEC M-Series Instructions for Use – UK

Issue Date: Jan. 2019; Revision No. 007

Atlantis HYDROTEC T-Series Instructions for Use – UK

Issue Date: Jan. 2019; Revision No. 005

Approval expiry date: 29 May 2024

**ENEXIO 2H Water Technologies Ltd**

**TUBEdek FS41.50/84 PP** DWI 56/4/878

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Information for Use Document. TUBEdek Lamella Separators Type FS41.50PP & FS41.84PP. Version 1.5 April 2017

Approval expiry date: 4 July 2022

**Filtec Water Services Ltd**

**Filtec "Selkie" Stainless Steel Products** DWI 56/4/1396c

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: HANDLING, INSTALLATION AND COMMISSIONING INSTRUCTIONS FOR THE FILTEC SELKIE RANGE OF STAINLESS STEEL PRODUCTS FOR USE IN CONTACT WITH TREATED OR PARTIALLY TREATED POTABLE WATER. Dated: 29/04/2020; Issue No: 01; Rev 02

Approval expiry date: 17 May 2025

**Flex EJ Ltd**

**Expansion Joint** DWI 56/4/1382

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Stainless Steel Expansion Joints, Drinking Water Expansion Joints, Instructions for Use, Revision A, Issue 1, Date of issue: 10.10.2019

Approval expiry date: 28 November 2024

**Forbes Technology Ltd**

**Cheetah Tower Packings**

DWI 56/4/711

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: QA412 – Cheetah Pall Rings – Instructions for Use Manual. Issue No. 6 Dated 07/03/2019

Approval expiry date: 28 October 2024

**Homer Burgess Ltd**

**Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water**

DWI 56/4/1107c

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Homer Burgess Ltd., Manufacturer's official use instructions for Stainless Steel Products in contact with Drinking Water.. Issue Number Rev. 1 26/01/2016

Approval expiry date: 22 May 2023

**Jacopa Ltd**

**Jacopa Ltd / Nordic Water Lamella Plate Separators**

DWI 56/4/622

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Jacopa Ltd / Nordic Water Products Lamella Plate Separators Issue No.01 Date of issue: 3rd January 2020

Approval expiry date: 30 July 2023

**Nijhuis Water Technology B.V.**

**IPF and NPF model of Dissolved Air Flotation units**

DWI 56/4/620

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: May 2019 rev0 EJ

Approval expiry date: 19 August 2024

**PAX Water Technologies Inc**

**PAX Water Monopod Mixers (PWM 100/150/250) and PAX Water Mixer (PWM400/500/600)**

DWI 56/4/1335

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use PAX Water Monopod Mixer (PWM100/150/250) and PAX Water Mixer (PWM400/500/600)

Issue Date: May 26th 2020; Issue No.: Revision 3

Approval expiry date: 27 October 2024

**Pontoon Work Ltd**

**Modular Pontoon**

DWI 56/4/1309

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Pontoonworks: Pontoon solutions for working on clean water sites

Issue Date: 2nd January 2018; Issue Number: 03

This product is approved for limited use during planned maintenance and may not be permanently installed. If the proposed use will extend beyond a 90 day period of use on any one occasion, then advice from the DWI should be sought before installation and use. NOTE: It is the responsibility of the water supplier to undertake a thorough risk assessment of the proposed use, including fitness-for-purpose. Use of this product during planned maintenance shall be in accordance with the condition set out above.

Approval expiry date: 26 July 2023

**Power Plastics Ltd**

**Power Plas® BC850 Baffle Curtain**

DWI 56/4/1350

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: PowerPlas BC850 Baffle Curtain - For use in water for human consumption

Issue No.: 1.0; Issue Date: February 2019

Approval expiry date: 9 October 2024

**PWN Technologies**

**Suspended Ion Exchange (SIX)**

DWI 56/4/1171

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) for the SIX® Technology by PWN Technologies , Revision 1.4 Date of Issue: 05 October 2020

This approval does not include any ion exchange resins.

Approval expiry date: 13 October 2025

**Sensor (UK) Ltd**

**Sensorline (Stainless steel)**

DWI 56/4/1066b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: SENSORLINE – PE GEOMEMBRANES (IFU VERSION 4.9)

Issue date 9 November 2015

Approval expiry date: 19 March 2023

**Staptina Engineering Services Ltd**

**Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems**

DWI 56/4/567c

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: 24838IFU 12 June 2013

Approval expiry date: 31 March 2024



**SUEZ Water Technologies and Solutions Hungary Kft**

**Stainless Steel Products**

DWI 56/4/1371

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use Document for the Supply of Stainless Steel Piping, Tanks and other Equipment for use in the Public Water Supply in the UK

Issue Date: 24 June 2019; Issue No. UKDWI/SSP/Revision 0

Approval expiry date: 17 July 2024

**Tema Engineering Limited**

**Stainless Steel Pipework, Tanks and Vessels for Water Use**

DWI 56/4/1376b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue No: 01; Issue Date: 25/07/2019

Approval expiry date: 6 October 2024

**Veolia Water Technologies UK**

**Greca Lamella Plates**

DWI 56/4/309

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU Rev A

Approval expiry date: 14 March 2022

**Package Actiflo and Multiflo**

DWI 56/4/770

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: IFU, VWT/ASMS/S4, Issue 1, Jan 2017

Approval expiry date: 26 April 2022

**Vessco Engineering Ltd**

**Fabricator of Bespoke Stainless Steel Products: Pressure Vessels, Tanks and Pipes**

DWI 56/4/1345b

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Issue 1, Rev 1: 24 January 2019

Approval expiry date: 20 February 2024

**WEARS Australia**

**ResMix Vital**

DWI 56/4/1131

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Operation and maintenance Manual Resmix Vital Surface Mounted Destratification System Version 2.1 Issue date 24 September 2019

Approval expiry date: 9 April 2024

**Western Carbons**

**Stainless Steel Floor Plates, weirs, pipework and tanks**

DWI 56/4/1303

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Western Carbons Stainless Steel Products. Issue date: November 2017; Issue number: Version 1.0

Approval expiry date: 18 February 2023

**Wester Carbons Porous Block**

DWI 56/4/1297

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Instructions for Use (IFU) - Western Carbons Porous Block Issue Date: August 2017, Issue No: Version 1.0

Approval expiry date: 25 March 2023

**Xylem Water Solutions Zellenople LLC**

**Leopold Ari Scour System**

DWI 56/4/1250

Conditions of Approval: Use of the product must be in accordance with the Instructions for Use: Air Scour System AHP-IFU-00 Issue date: 12/13/16 Issue number:R01

Approval expiry date: 5 March 2022

## INDEX BY PRODUCT NAME

Volute Dewatering Screw Press	AMCON Europe s.r.o	E.4	DWI 56/4/1144
3M Scotchkote Pipe Protection Liner 2100	3M United Kingdom	C.2.2	DWI 56/4/1037
3M Scotchkote Pipe Renewal Liner 2400	3M United Kingdom	C.2.2	DWI 56/4/1031
3M Scotchkote Rapid Setting Polymeric Lining 166L	3M United Kingdom	C.2.3	DWI 56/4/1032
8040-SBNF-DWI Membrane Elements	Microdyn-Nadir US Inc	D.1	DWI 56/4/1218
8040-SBUF-DWI	Microdyn-Nadir US Inc	D.1	DWI 56/4/1030
Absolute.Za*DWI	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/1325
Acothane DW Blue	Axalta Coating Systems	C.3.2	DWI 56/4/1059
Acothane DW Cream	Axalta Coating Systems	C.3.2	DWI 56/4/1052
Acothane LV Sealer	Axalta Coating Systems	C.3.2	DWI 56/4/1058
AFM Activated Filter Media	Dryden Aqua Ltd	A.10	DWI 56/4/382
Airophos 750PWG	Airedale Chemical Company Ltd	A.9	DWI 56/4/960
Akdolit® SLS45	Lhoist UK Ltd	A.9	DWI 56/4/1392
Amazon SupaGard Cartridge Filters	Amazon Filters Ltd	D.1	DWI 56/4/702
Amazon SupaSpun II Cartridge Filters	Amazon Filters Ltd	D.1	DWI 56/4/702
Angus Wellmaster Flexible Rising Main	Angus Flexible Pipelines	B.2	DWI 56/4/1020
AquaCube Emergency Water Tank	JFC Manufacturing Co. Ltd	B.3.2	DWI 56/4/765
Aquaflex	X-FLOW B.V.	D.1	DWI 56/4/324
Aquaflex HP	X-FLOW B.V.	D.1	DWI 56/4/967
Aquaforce (with non-lead stabiliser)	Wavin Ireland Ltd	B.1.3	DWI 56/4/600
Aquastore Vitrium EN	CST Industries Ltd	E.1	DWI 56/4/621
Aquaurethane Extreme	Line-X Protective coatings	C.3.2	DWI 56/4/874
Aquron 2000	MG Solutions (UK) Ltd	C.6	DWI 56/4/1291
Arlington 1000 Litre Bag-in-Box Combo Liner	Arlington Packaging (Rental) Ltd	B.3.3	DWI 56/4/796
Atlantis Hydrotec - T&M Series	Craley Group Ltd	E.4	DWI 56/4/1346
Avista 505	Avista Technologies (UK) Ltd	A.5	DWI 56/4/1321
AvistaClean MF 1000a	Avista Technologies (UK) Ltd	A.5	DWI 56/4/1327
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 141204	Barr + Wray Ltd	A.3.1	DWI 56/4/1238
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 200613	Barr + Wray Ltd	A.3.1	DWI 56/4/1239
Barr + Wray Colour/Organics Removal Ion Exchange Resin BW 341817	Barr + Wray Ltd	A.3.1	DWI 56/4/1237

List of approved products for use in public water supply in the United Kingdom

Barr + Wray Stainless Steel Media Filter	Barr + Wray Ltd	E.3	DWI 56/4/1234b
Barr + Wray Stainless Steel Media Filter	Barr + Wray Ltd	E.1	DWI 56/4/1234a
BioMate MBC2881	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1276
Bi-OROC	Dyka S.A.S.	B.1.3	DWI 56/4/1207
Black PE80 Polyethylene Pipes	Polypipe Building Products	B.1.1	DWI 56/4/968
Black PE80 Polyethylene Pipes (ME3440)	Polypipe Building Products	B.1.1	DWI 56/4/986
Blue PE80 Polyethylene Pipes	Polypipe Building Products	B.1.1	DWI 56/4/970
Blue PE80 Polyethylene Pipes (PC002 50R698)	Polypipe Building Products	B.1.1	DWI 56/4/1120
Blutop	Saint-Gobain PAM UK Ltd	B.1.12	DWI 56/4/823
Boode Waterwell Systems PVC Screen and Casing	Boode UK Ltd	B.2	DWI 56/4/958
Bridges in-house fabricated stainless steel pipe spools and products	Bridges Electrical Engineering Ltd	E.4	DWI 56/4/1268b
Bridges in-house fabricated stainless steel pipe spools and products	Bridges Electrical Engineering Ltd	B.1.10	DWI 56/4/1268a
BSR/EPW/004 - Copon Hycote PWX	BSR Pipeline Services Ltd	B.1.9	DWI 56/4/772
C10 Module	PCI Membranes	D.1	DWI 56/4/234
CA202 membrane	PCI Membranes	D.1	DWI 56/4/76
Cementitious Coating 851 Grey	Flexcrete Technologies Ltd	C.5	DWI 56/4/1159
Cementitious Coating 851 White	Flexcrete Technologies Ltd	C.5	DWI 56/4/1160
CEMLINE STON	Vandex International Ltd	C.6	DWI 56/4/1095
CEMLINE UM1	Vandex International Ltd	C.5	DWI 56/4/1099
CEMLINE BB-W	Vandex International Ltd	C.5	DWI 56/4/1093
CEMLINE CG	Vandex International Ltd	C.5	DWI 56/4/1094
Cemprotec 851F	Flexcrete Technologies Ltd	C.5	DWI 56/4/1340
CeraMac® Technology	PWN Technologies	D.1	DWI 56/4/1179
CF-DW Series cartridge filter housings	Filtertec Systems Ltd	D.2	DWI 56/4/1331
Cheetah range of Tanks & Towers	Forbes Technology Ltd	E.1	DWI 56/4/1292
Cheetah Tower Packings	Forbes Technology Ltd	E.4	DWI 56/4/711
Chlorine Dioxide generated by Xziox	International Water Solutions Ltd	A.7.3	DWI 56/4/998
Citric acid (food grade)	Traditional Chemical	A.7.1	DWI 56/1/106
Citric Acid 50% Solution	Brenntag UK & Ireland	A.5	DWI 56/4/1333
Clortec cell	De Nora Water Technologies UK Services Ltd	A.7.2	DWI 56/4/549
Codeline RO Membrane Housing Codeline 80S Series (Coded Vessels)	Pentair Water India Pvt Ltd	D.2	DWI 56/4/288

List of approved products for use in public water supply in the United Kingdom

Codeline RO Membrane Housing Codeline 80S Series (Non-coded Vessels)	Pentair Water India Pvt Ltd	D.2	DWI 56/4/288
Conbextra Bedding Mortar	Fosroc Ltd	C.6	DWI 56/4/1271
Constant Chlor Plus Briquettes	Arch Chemicals Ltd	A.9	DWI 56/4/1241
CP Polytec 100	Cork Plastics	B.1.1	DWI 56/4/1351
CP Polytec PE80E	Cork Plastics	B.1.1	DWI 56/4/1187
CPE Pressure Vessels-304L and 316L Stainless Steel	CPE Pressure Vessels	E.3	DWI 56/4/1135
DE Stainless Steel Systems	Dustacco Engineering Ltd	B.1.10	DWI 56/4/647
Deltapor MW and MWA Filter Cartridges	Envirogen Group	D.1	DWI 56/4/1274
Durapipe ABS Pipe Type S	Durapipe UK	B.1.4	DWI 56/4/660
Durapipe Grey PVC-U Pipe NGS	Durapipe UK	B.1.3	DWI 56/4/937
Durapipe PREMIUM PVC-U pipe	Durapipe UK	B.1.3	DWI 56/4/1226
DVF Media Filters	Amiad Water Systems UK Ltd	D.4	DWI 56/4/1249
Dyka Grey PVC-U Pipe NGS	Dyka B.V.	B.1.3	DWI 56/4/637
Easychlorgen 280 – 2200 Electrolysis system for on-site hypochlorite generation	Lutz-Jesco GmbH	A.7.2	DWI 56/4/1369
EFH/SFH/PFH (Cartridge Housings)	Fileder Filter Systems	D.2	DWI 56/4/848
egeclean (+)	Egeplast International GmbH	B.1.1	DWI 56/4/1157
egeclean 9010	Egeplast International GmbH	B.1.1	DWI 56/4/1158
egeclean PE100	Egeplast International GmbH	B.1.1	DWI 56/4/1156
egelen PE 100 Blue	Egeplast International GmbH	B.1.1	DWI 56/4/436
egelen PE100 Black	Egeplast International GmbH	B.1.1	DWI 56/4/436
egeplast 9010	Egeplast International GmbH	B.1.1	DWI 56/4/1065
egeplast egelen (+) Plus Pipe	Egeplast International GmbH	B.1.1	DWI 56/4/1111
Egeplast SLA Barrier Pipes	Egeplast International GmbH	B.1.2	DWI 56/4/1109
Electrofresh Ductile Iron Pipe	Electrosteel Castings Ltd	B.1.7.1	DWI 56/4/992
Electrofresh Plus Pipes	Electrosteel Castings Ltd	B.1.7.2	DWI 56/4/537
Eliquo Hydrok Filter Housing Tank	Eliquo Hydrok	D.2	DWI 56/4/1386
Emergency Drinking Water Bowsers	Trailer Engineering Ltd	B.3.2	DWI 56/4/707
Enduratank	Enduramaxx Ltd	B.3.2	DWI 56/4/1242
Envirogen CF Filter Housing	Envirogen Group	D.2	DWI 56/4/1257
ePipe UK	Pipe Restoration Technologies LLC	C.2.3	DWI 56/4/995
Erciyas Steel Water Pipe – Cement Lined	Erciyas Celik Boru Sanayi A.S	B.1.7.1	DWI 56/4/1047
ES404 membrane	PCI Membranes	D.1	DWI 56/4/215
European Pipeline Group Svobodny Sokol Ductile Iron Pipe	European Pipeline Group	B.1.7.1	DWI 56/4/1114

List of approved products for use in public water supply in the United Kingdom

Excel White	GPS	B.1.1	DWI 56/4/1269
Expansion Joint	Flex EJ Ltd	E.4	DWI 56/4/1382
Fabricated mild steel pipework coated with Jotaguard VA5001	UTS Engineering Ltd	B.1.9	DWI 56/4/1324
Fabricated mild steel pipework coated with Scotchkote 162pwx	UTS Engineering Ltd	B.1.9	DWI 56/4/1085
Fabricator of Bespoke Stainless Steel Products: Pressur Vessels, Tanks and Pipes	Vessco Engineering Ltd	B.1.10	DWU 56/4/1345a
Fabricator of Bespoke Stainless Steel Products: Pressure Vessels, Tanks and Pipes	Vessco Engineering Ltd	E.4	DWI 56/4/1345b
Fastfill	Flexcrete Technologies Ltd	C.6	DWI 56/4/1162
Filtec "Selkie" Stainless Steel Products	Filtec Water Services Ltd	E.4	DWI 56/4/1396c
Filtec "Selkie" Stainless Steel Products	Filtec Water Services Ltd	E.1	DWI 56/4/1396b
Filtec "Selkie" Stainless Steel Products	Filtec Water Services Ltd	B.1.10	DWI 56/4/1396a
Flagon Geo P/AT	Flag S.p.a	C.4	DWI 56/4/856
Flocon 135	BWA Water Additives UK Ltd	A.5	DWI 56/4/839
Fusion® V1100	Permastore Ltd	E.1	DWI 56/4/1214
Genesol 38	Genesys International Ltd	A.5	DWI 56/4/664
Genesol 40	Genesys International Ltd	A.5	DWI 56/4/665
Genesol 61	Genesys International Ltd	A.5	DWI 56/4/1205
Genesol 704	Genesys International Ltd	A.5	DWI 56/4/1319
Genesys CAS	Genesys International Ltd	A.5	DWI 56/4/1253
Genesys LF	Genesys International Ltd	A.5	DWI 56/4/495
Genesys LF60	Genesys International Ltd	A.5	DWI 56/4/783
Genesys LS	Genesys International Ltd	A.5	DWI 56/4/781
Genesys SI	Genesys International Ltd	A.5	DWI 56/4/593
Genesys SW	Genesys International Ltd	A.5	DWI 56/4/524
GEROther® COEX	Gerodur MPM Kunststoffverarbeitung GmbH & Co. KG	B.1.1	DWI 56/4/1370
Gerothern PE100 Polyethylene Pipes	EBERO Pipe Systems Ltd	B.1.1	DWI 56/4/1115
GF ABS pressure pipe	George Fischer Sales Ltd	B.1.4	DWI 56/4/753
GF DEKADUR PVC-U pressure pipe	George Fischer Sales Ltd	B.1.3	DWI 56/4/1231
GF PE100 Black Pipe	George Fischer Sales Ltd	B.1.1	DWI 56/4/957
GF PVC-U Inch Pipe	George Fischer Sales Ltd	B.1.3	DWI 56/4/1235
GPS B Light Blue Polyethylene Pipe	GPS	B.1.1	DWI 56/4/242

List of approved products for use in public water supply in the United Kingdom

GPS Excel (Black)	GPS	B.1.1	DWI 56/4/851
GPS Excel (Blue)	GPS	B.1.1	DWI 56/4/850
GPS Excel (Black) Type F	GPS	B.1.1	DWI 56/4/961
GPS Excel 3c (Black)	GPS	B.1.1	DWI 56/4/871
GPS Excel 3c (Blue)	GPS	B.1.1	DWI 56/4/853
GPS Excel CR	GPS	B.1.1	DWI 56/4/946
GPS Excel NB	GPS	B.1.1	DWI 56/4/1026
GPS Excel NB Type V	GPS	B.1.1	DWI 56/4/1050
GPS N Black Polyethylene Pipe	GPS	B.1.1	DWI 56/4/1260
GPS N Blue PE80 Pipe	GPS	B.1.1	DWI 56/4/651
GPS Protecta-Line	GPS	B.1.2	DWI 56/4/872
GPS Protecta-Line 3c	GPS	B.1.2	DWI 56/4/873
Greca Lamella Plates	Veolia Water Technologies UK	E.4	DWI 56/4/309
Guardsman GT190 Antiscalant for Membrane Systems	Kobell Fluid Technology Ltd	A.5	DWI 56/4/1123
HFW 1000	X-FLOW B.V.	D.1	DWI 56/4/1139
High Performance SC100 Dark Blue Pipe PE100 pipe including Clean Pipe	Radius Systems Ltd	B.1.1	DWI 56/4/939
HYDRAcap	Hydranautics	D.1	DWI 56/4/689
Hydrochoc Butyl Bladder Surge Vessel	Charlatte Reservoirs	E.3	DWI 56/4/1016
Hypersperse MDC 704i	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1302
Hypersperse MDC 711	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1300
Hypersperse MDC 714	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1301
Hypersperse MSI310	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1311
ICL - Citric Acid Solution	Industrial Chemicals Ltd	A.5	DWI 56/4/1342
Intercrete 4800	International Paint Ltd	C.6	DWI 56/4/1403
Intercrete 4800WS	International Paint Ltd	C.6	DWI 56/4/1408
Intercrete 4802	International Paint Ltd	C.6	DWI 56/4/1055
Intercrete 4807	International Paint Ltd	C.6	DWI 56/4/1404
Intercrete 4820	International Paint Ltd	C.5	DWI 56/4/1054
Intercrete 4841	International Paint Ltd	C.5	DWI 56/4/1053
Intercrete 4871	International Paint Ltd	C.6	DWI 56/4/1056
Ion exchange colour removal system	Barr + Wray Ltd	A.3.2	DWI 56/4/1176
IPF and NPF model of Dissolved Air Flotation units	Nijhuis Water Technology B.V.	E.4	DWI 56/4/620

List of approved products for use in public water supply in the United Kingdom

IPSSSPW01 Stainless Steel Pipework and Fabrications	Equipdata Trading	B.1.10	DWI 56/4/1316
Isofusion (vitreous enamelled tank)	Permastore Ltd	E.1	DWI 56/4/594
IXL Process	Ionex SG Ltd	A.3.2	DWI 56/4/467
Jacopa Ltd / Nordic Water Lamella Plate Separators	Jacopa Ltd	E.4	DWI 56/4/622
Jaguar Range of Storage & Process Tanks & Towers	Forbes Technology Ltd	E.1	DWI 56/4/1210
JKF 304 and 316 Stainless Steel Tanks	J.K Fabrications Limited	E.1	DWI 56/4/732
Johnson Screen, Casing & Johnson Riser Pipe and Accessories	Aqseptence Group SAS	B.2	DWI 56/4/653
JSAW-JAL-11A	Jindal Saw Ltd	B.1.7.1	DWI 56/4/935
JSAW-JAL-11B	Jindal Saw Ltd	B.1.7.2	DWI 56/4/936
JSAW-JAL-1A	Jindal Saw Ltd	B.1.7.1	DWI 56/4/933
JSAW-JAL-1B	Jindal Saw Ltd	B.1.7.2	DWI 56/4/934
JSGL-JAL-1A	JINDAL SAW GULF LLC	B.1.7.1	DWI 56/4/1122
K Filter Floor	Black & Veatch	E.2	DWI 56/4/833
Kalic HSD	Tarmac Lime & Cement	A.9	DWI 56/4/1206
KLEEN MCT515E	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1273
Kleen MTC405	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1289
Kleen* MCT103	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1008
Kleen* MCT524	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1007
Kleen* MCT882	SUEZ Water Technologies & Solutions	A.5	DWI 56/4/1010
Lamella Separator Package (LSF)	Colloide Engineering Systems Ltd	E.4	DWI 56/4/1172
Leinster Range of Thermoplastic Tanks	Silotank (Digestors, Silos & Tanks) Ltd	E.1	DWI 56/4/498
Leinster Range of Towers	Silotank (Digestors, Silos & Tanks) Ltd	E.1	DWI 56/4/498
Leopold Ari Scour System	Xylem Water Solutions Zelienople LLC	E.4	DWI 56/4/1250
Leopold Type S Underdrain and I.M.S. 1000 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1079
Leopold Type S Underdrain and I.M.S. 200 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1078
Leopold Type S Underdrain and I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/371



List of approved products for use in public water supply in the United Kingdom

Leopold Type SL Underdrain and I.M.S. 1000 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1079
Leopold Type SL Underdrain and I.M.S. 200 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1078
Leopold Type SL Underdrain and I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/371
Leopold Type XA Underdrain and I.M.S. 1000 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1105
Leopold Type XA Underdrain and I.M.S. 200 Media Retainer	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1105
Leopold Type XA Underdrain and I.M.S. Cap	Xylem Water Solutions Zelienople LLC	E.2	DWI 56/4/1105
Lewatit S 5128	Lanxess Deutschland GmbH	A.3.1	DWI 56/4/1193
Lion Range of Tanks & Towers	Forbes Technology Ltd	E.1	DWI 56/4/1293
Lorem ipsum dolor sit amet, consectetur adipiscing elit. Aenean commodo ligula eget dolor. Aenean massa. Cum sociis natoque penatibus et magnis dis parturient montes, nascetur ridiculus mus. Donec quam felis, ultrices nec, pellentesque eu, pretium quis,	Traditional Chemical	).99.99.99	DWI 56/4/0000
Macropoxy P300	Sherwin-Williams Protective and Marine Coatings	C.3.1	DWI 56/4/253
Magnafloc LT20	Solenis UK Industries Ltd	A.1.2	DWI 56/4/885
Magnafloc LT22S-DWI	Solenis UK Industries Ltd	A.1.2	DWI 56/4/884
Magnafloc LT25	Solenis UK Industries Ltd	A.1.2	DWI 56/4/886
Magnafloc LT27	Solenis UK Industries Ltd	A.1.2	DWI 56/4/887
Magnesium sulphate	Traditional Chemical	A.7.1	DWI 56/1/106
Magnesium Sulphate Heptahydrate 40%	Brenntag UK & Ireland	A.9	DWI 56/4/1334
MasterEmaco S420 with MasterSeal 600	BASF plc Construction Chemicals (UK) Ltd	C.6	DWI 56/4/1064
MasterSeal 581	BASF plc Construction Chemicals (UK) Ltd	C.5	DWI 56/4/1227
MasterSeal 581 with MasterSeal 600	BASF plc Construction Chemicals (UK) Ltd	C.5	DWI 56/4/1103
MasterSeal 586 with MasterSeal 600	BASF plc Construction Chemicals (UK) Ltd	C.5	DWI 56/4/86
MasterSeal 588	BASF plc Construction Chemicals (UK) Ltd	C.5	DWI 56/4/1128
MasterSeal 930 and MasterSeal 933	BASF plc Construction Chemicals (UK) Ltd	C.6	DWI 56/4/144
Masterseal M 808	BASF plc Construction Chemicals (UK) Ltd	C.3.2	DWI 56/4/1080a

List of approved products for use in public water supply in the United Kingdom

Masterseal M 808 additional light grey colour	BASF plc Construction Chemicals (UK) Ltd	C.3.2	DWI 56/4/1080b
Memcor CMF- S S10V Range of Microfiltration submodules (submerged PVDF Membranes)	DuPont Water Solutions	D.1	DWI 56/4/973
Memcor CMF-L L10N	DuPont Water Solutions	D.1	DWI 56/4/1254
Memcor CMF-L L10V Range of Microfiltration Submodules (PVDF Membranes)	DuPont Water Solutions	D.1	DWI 56/4/977
Memcor CMF-L L20N	DuPont Water Solutions	D.1	DWI 56/4/1255
Memcor CMF-L L20V Range of Microfiltration Submodules (PVDF Membranes)	DuPont Water Solutions	D.1	DWI 56/4/978
Memcor CMF-L L40N	DuPont Water Solutions	D.1	DWI 56/4/1305
Memcor CMF-M10C Continuous Microfiltration Module (Polypropylene Membranes)	DuPont Water Solutions	D.1	DWI 56/4/975
Memcor CMF-S S10N	DuPont Water Solutions	D.1	DWI 56/4/1256
Memcor CMF-S S10T Microfiltration Submodule (submerged Polypropylene Membranes)	DuPont Water Solutions	D.1	DWI 56/4/976
MIEX DOC Resin	Ixom Operations Pty Ltd	A.3.1	DWI 56/4/550
MIEX Gold	Ixom Operations Pty Ltd	A.3.1	DWI 56/4/1140
MK IV EDR Water Treatment System	Suez Water Technologies & Solutions (USA Inc)	D.3	DWI 56/4/480
Modular Pontoon	Pontoon Work Ltd	E.4	DWI 56/4/1309
Monolevel 844SP	Flexcrete Technologies Ltd	C.5	DWI 56/4/1161
Monomix	Flexcrete Technologies Ltd	C.6	DWI 56/4/1163
Monomix WS	Flexcrete Technologies Ltd	C.6	DWI 56/4/397
Monostore SST - Recognised Grade Tanks	Monostore Ltd	E.1	DWI 56/4/1374
MULTIBLOCK® Media Retaining Gravity Filter Underdrain	WesTech Engineering Inc	E.2	DWI 56/4/1312
NATCEM 35	Natural Cement Distribution Ltd	C.6	DWI 56/4/1090
NATCEM AC	Natural Cement Distribution Ltd	C.6	DWI 56/4/840
NATCEM D	Natural Cement Distribution Ltd	C.6	DWI 56/4/1216
NATCEM DW	Natural Cement Distribution Ltd	C.6	DWI 56/4/1049
Neumo Stainless Steel Tube and Fittings	Neumo UK Ltd	B.1.10	DWI 56/4/1167
Noksel Steel Water Pipe – Coated with Thixo 468	Noksel Steel Pipe Co Inc	B.1.9	DWI 56/4/1192
OSTP Stainless Steel pipe and fittings of 12mm bore or greater.	OSTP	B.1.10	DWI 56/4/516

List of approved products for use in public water supply in the United Kingdom

Oxiperm ISIA (with U-type reactor)	Grundfos Holdings A/S	A.7.3	DWI 56/4/1236
Package Actiflo and Multiflo	Veolia Water Technologies UK	E.4	DWI 56/4/770
Pall GF Plus Filter Units, Type MWH27	Pall Corporation	D.1	Dwi 56/4/1336
Pall Microza UNA-620C microfiltration module	Pall International Sarl	D.1	DWI 56/4/795
PaM Natural Pipeline Components	Saint-Gobain PAM UK Ltd	B.1.9	DWI 56/4/618
PAXWater Monopod Mixers (PWM 100/150/250) and PAXWater Mixer (PWM400/500/600)	PAXWater Technologies Inc	E.4	DWI 56/4/1335
PE100 High Performance Profuse Pipe including Factory Sealed	Radius Systems Ltd	B.1.1	DWI 56/4/943
Peak Pipe Systems	Peak Pipe Systems	B.1.1	DWI 56/4/548
Penecrete Mortar	Penetron UK Ltd	C.6	DWI 56/4/1130
Penectron Crystalline Waterproof Coating	Penetron UK Ltd	C.6	DWI 56/4/1137
PEXGOL	GOLAN Plastic Products Ltd	B.2	DWU 56/4/1259
Pile Cloth Media Filter (PCMF) DW2/10 - DW27/135	Mecana Umwilttechnik GmbH	D.1	DWI 56/4/1215
Pipes and fittings lined with Eurokote 468 Thixo	Northpoint Ltd	B.1.9	DWI 56/4/1209
Pipes and Fittings lined with Jotaguard VA 5001	Northpoint Ltd	B.1.9	DWI 56/4/1304
Pipes and Fittings lined with Resicoat R4-FB HKC71R	Orrmac Coatings Limited	B.1.9	DWI 56/4/771
Pipes Lined with Resicoat R4-FB HKC71R	Freeflow Pipesystems Ltd	B.1.9	DWI 56/4/817
Pipes lined with Scotchkote 162PWX	Orrmac Coatings Limited	B.1.9	DWI 56/4/985
Pipes, Fittings and Steelwork coated with Resicoat R4-FB HKC71R	Northpoint Ltd	B.1.9	DWI 56/4/659
Plasmor E and U Blocks	Plasmor Ltd	E.2	DWI 56/4/988
Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes	Polypipe Building Products	B.1.2	DWI 56/4/857
Polyguard: Polyethylene/Aluminium/Polyethylene barrier pipes (ME3444)	Polypipe Building Products	B.1.2	DWI 56/4/1076
Polypipe Black PE100 Polyethylene Pipes (TUB121N3000)	Polypipe Ltd	B.1.1	DWI 56/4/1343
Polypipe Blue PE100 Polyethylene Pipes (TUB124N 2025)	Polypipe Building Products	B.1.1	DWI 56/4/1296
Power Plas ® BC850 Baffle Curtain	Power Plastics Ltd	E.4	DWI 56/4/1350
PowerPlas ® TL850 Tank Liner	Power Plastics Ltd	C.4	DWI 56/4/1385
Powerrun fabricated stainless steel pipework	Powerrun Pipe-Mech Ltd	B.1.10	DWI 56/4/769

List of approved products for use in public water supply in the United Kingdom

Premcrete Hydroseal FX	FIS Products	C.5	DWI 56/4/1356
Premcrete Teknocem HB50	FIS Products	C.6	DWI 56/4/1357
Premcrete Teknocem Rapid	FIS Products	C.6	DWI 56/4/1358
Premcrete Teknolevel FS	FIS Products	C.5	DWI 56/4/1359
Premcrete Teknoprime 841	FIS Products	C.6	DWI 56/4/1360
Premcrete Tie Hole Sealer	FIS Products	C.6	DWI 56/4/1361
PRESSURE FILTRATION KIT DF FP/FDN 800-3 500	DYNAMIK FILTR Nocoń iWspólnicy Spółka Jawna	D.4	DWI 56/4/1272
Pressure Vessels	A J Metal Products Ltd	E.3	DWI 56/4/1383
Purafloc TM 001	JFI Limited	A.9	DWI 56/4/1355
Purafloc TM 001	Clinty Chemicals Limited	A.9	DWI 56/4/1378
Puresol	Tarmac Cement and Lime Limited	A.9	DWI 56/4/1147
Puriton Pipe	Radius Systems Ltd	B.1.2	DWI 56/4/1112
Purolite A520E nitrate selective anion exchange resin	Purolite International Ltd	A.3.1	DWI 56/4/11
PVC Screens, Casings, Fittings and Accessories	Stuwa-Konrad Stukerjurg GmbH	B.2	DWI 56/4/1061
Q Pipe System	ABC Stainless Steel Ltd	B.1.10	DWI 56/4/542a
Qual-plast HDPE Pipe	Pipelife Ireland Limited	B.1.1	DWI 56/4/997
Qual-plast MDPE Pipe	Pipelife Ireland Limited	B.1.1	DWI 56/4/240
QualPLAST Polyethylene MDPE co- extruded pipe	Pipelife Ireland Limited	B.1.1	DWI 56/4/1282
Quantum Pressure Vessels- 304L	Quantum Engineering Developments Ltd	E.3	DWI 56/4/1132
Quantum Pressure Vessels- 316L	Quantum Engineering Developments Ltd	E.3	DWI 56/4/1133
Renderoc Plug 20	Fosroc Ltd	C.6	DWI 56/4/297
RENO 100	Idrotherm 2000 spa	B.1.1	DWI 56/4/1168
Resinex KW-H	Jacobi Carbons	A.3.1	DWI 56/4/1151
ResMix Vital	WEARS Australia	E.4	DWI 56/4/1131
Rilsan Nylon Green Coated Pipes and Fittings	Leyfos Plastics Limited	B.1.8	DWI 56/4/615
RoCide DB20	Avista Technologies (UK) Ltd	A.5	DWI 56/4/964
RoClean L403	Avista Technologies (UK) Ltd	A.5	DWI 56/4/855
RoClean P111	Avista Technologies (UK) Ltd	A.5	DWI 56/4/737
RoClean P303	Avista Technologies (UK) Ltd	A.5	DWI 56/4/746
Safe 10	Centraltubi SPA	B.1.1	DWI 56/4/1366
SBH and PBF Stainless Steel Bag Housing	Fileder Filter Systems	D.2	DWI 56/4/848

List of approved products for use in public water supply in the United Kingdom

SC100 (PE100) XL large diameter / heavy wall dark blue potable water pipe	Radius Systems Ltd	B.1.1	DWI 56/4/1146
SC80 Service Pipe	Radius Systems Ltd	B.1.1	DWI 56/4/941
SEAQUEST	Aqua Smart Inc.	A.9	DWI 56/4/202
Sensorline	Sensor (UK) Ltd	C.4	DWI 56/4/1066a
Sensorline (Stainless steel)	Sensor (UK) Ltd	E.4	DWI 56/4/1066b
SFH and PFH Stainless Steel Filter Housing	Fileder Filter Systems	D.2	DWI 56/4/848
SFH PFH SSS Filter housing	Evoqua Water Technologies Ltd	D.2	DWI 56/4/1191
Shotcrete 513	Natural Cement Distribution Ltd	C.6	DWI 56/4/1089
Sika Monotop 610/615 Concrete Repair System	Sika Ltd	C.6	DWI 56/4/834
Sikadur Combiflex SG jointing system using Sikadur 31 DW	Sika Ltd	C.6	DWI 56/4/94
Sikadur Combiflex SG jointing system, using Sikadur 31 DW Rapid	Sika Ltd	C.6	DWI 56/4/1124
Sikagard 62	Sika Ltd	C.3.1	DWI 56/4/197
Silver Bullets 1000	BioBullets Ltd	A.9	DWI 56/4/852
Silver Bullets 2000	BioBullets Ltd	A.9	DWI 56/4/1000
Simona PE100 Pressure Pipe Black	Simona UK Ltd	B.1.1	DWI 56/4/875
Single and Multiple Cartridge & Bag Filter Housings and Interconnecting pipework	Amazon Filters Ltd	D.2	DWI 56/4/879
Sirofloc Magnetite TM M-10	Northern Ireland Water	A.1.3	DWI 56/4/1338
Snap-Tite TE Range – Blue Hose	AAH Europe Hose Company Ltd (T/A Snap-tite)	B.3.1	DWI 56/4/62
Sodium Hypochlorite generated by Hydrolyser Electrochlorination System	Gaffey Technical Services Ltd	A.7.2	DWI 56/4/1341
Sodium Hypochlorite generated by Neuthox	Danish Clean Water A/S	A.7.2	DWI 56/4/1298
Sodium Hypochlorite generated by Neuthox T10/15	Danish Clean Water A/S	A.7.2	DWI 56/4/1315
Sodium Hypochlorite generated by Neuthox T20	Danish Clean Water A/S	A.7.2	DWI 56/4/1318
Sodium Hypochlorite generated by Selcoperm	Grundfos Holdings A/S	A.7.2	DWI 56/4/864
Stainless Steel ANSI Metric ISO Pipe, Stainless Steel ANSI Metric ISO Tube, Stainless Steel ANSI Metric ISO Fittings	Blackburns Metal Ltd	B.1.10	DWI 56/4/1224

List of approved products for use in public water supply in the United Kingdom

Stainless Steel Floor Plates, weirs, pipework and tanks	Western Carbons	E.4	DWI 56/4/1303
Stainless Steel Grade 316L Potable Water Reservoir Tanks	Powerrun Pipe-Mech Ltd	E.1	DWI 56/4/611
Stainless Steel Metric ISO & ANSI welded pipe and fittings	DH Stainless Ltd	B.1.10	DWI 56/4/773
Stainless Steel Pipe   Stainless Steel Tube   Stainless Steel Fittings   Material grades 304/304L, 316/316L, 1.4301/1.4307, 1.4401/1.4404	Righton and Blackburns Ltd	B.1.10	DWI 56/4/1221
Stainless Steel pipes, Stainless Steel Tube, Stainless Steel Fittings	Righton and Blackburns Ltd	B.1.10	DWI 56/4/1221
Stainless Steel Pipes, Tubes, Fittings and Flanges	Yorkshire Stainless Ltd	B.1.10	DWI 56/4/1368
Stainless Steel Pipework	Alpha Plus Ltd	B.1.10	DWI 56/4/692
Stainless Steel Pipework & Fittings - Flanged/Screwed - All diameters & Grades	George Green (Keighley) Ltd	B.1.10	DWI 56/4/699
Stainless Steel Pipework and Fabrications	AJ Engineering and Construction Services Ltd	E.4	DWI 56/4/1220b
Stainless Steel Pipework and Fabrications	AJ Engineering and Construction Services Ltd	B.1.10	DWI 56/4/1220a
Stainless Steel Pipework and Fabrications	Berry & Escott Engineering	E.1	DWI 56/4/1362a
Stainless Steel Pipework and Fabrications	Berry & Escott Engineering	B.1.10	DWI 56/4/1362
Stainless Steel Pipework, Tanks and Vessels for Water Use	Tema Engineering Limited	E.4	DWI 56/4/1376b
Stainless Steel Pipework, Tanks and Vessels for Water Use	Tema Engineering Limited	B.1.10	DWI 56/4/1376a
Stainless steel process pipework systems	Ross-shire Engineering Ltd	B.1.10	DWI 56/4/1034
Stainless Steel Products	SUEZ Water Technologies and Solutions Hungary Kft	E.4	DWI 56/4/1371
Stainless Steel Screens, Casings, Fittings and Accessories	Stuwa-Konrad Stukerjurgan GmbH	B.2	DWI 56/4/1060
Stainless Steel Tanks & Pipework	EPS Group	E.1	DWI 56/4/1267
Stainless Steel Tanks and Launderers	Allied Storage Tank Ltd	E.1	DWI 56/4/1258
Stainless Steel Tanks and Pipework	Specialist Welding Services Ltd	B.1.10	DWI 56/4/1367
Stainless Steel Tube, Stainless Steel pipe	Amari Metals Ltd	B.1.10	DWI 56/4/738
Stainless Steel Tubings and Fittings	BSS Industrial	B.1.10	DWI 56/4/1017
Stainless Steel Water Tanks	Sayers Road Tankers Ltd	E.1	DWI 56/4/1028
Stainless Steel Water Tanks	Ross-shire Engineering Ltd	E.1	DWI 56/4/1381
Stanton Bonna Concrete Pressure Pipe	Stanton Bonna Concrete Limited	B.1.7.1	DWI 56/4/1375

List of approved products for use in public water supply in the United Kingdom

Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	B.1.10	DWI 56/4/567a
Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	E.1	DWI 56/4/567b
Staptina Bespoke stainless steel fabrications: Pipework, Baffles, Troughs, Tanks, Support and Access systems	Staptina Engineering Services Ltd	E.4	DWI 56/4/567c
Steel pipe coated with Eurokote 468 Thixo	BAIKA Steel Tubular Systems SL	B.1.9	DWI 56/4/1203
Steel Reinforcement Protector 841	Flexcrete Technologies Ltd	C.6	DWI 56/4/1164
Storage, process tanks and vessels	ABC Stainless Steel Ltd	E.1	DWI 56/4/542b
STUWA Stainless Steel Riser Pipes	Stuwa-Konrad Stukerjurgan GmbH	B.2	DWI 56/4/1077
Subcoil	Radius Subterra – a part of RadiusPlus Ltd	B.1.1	DWI 56/4/461
Subcote 173/90	Radius Subterra – a part of RadiusPlus Ltd	C.2.1	WS 34/1/124a
Subcote 173/90	Radius Subterra – a part of RadiusPlus Ltd	C.3.1	WS 34/1/124b
Subcote FLP II	Radius Subterra – a part of RadiusPlus Ltd	C.3.2	DWI 56/4/1286b
Subcote FLP II	Radius Subterra – a part of RadiusPlus Ltd	C.2.2	DWI 56/4/1286
Super Aquaduct	Angus Flexible Pipelines	B.3.1	DWI 56/4/1005
Suspended Ion Exchange (SIX)	PWN Technologies	E.4	DWI 56/4/1171
System Cement Mortar Lined Ductile Iron Pipe	Superior Pipeline Products Ltd	B.1.7.1	DWI 56/4/990
System CL	Saint-Gobain PAM UK Ltd	B.1.7.1	DWI 56/4/283
System CL	Saint-Gobain PAM UK Ltd	B.1.11	DWI 56/4/283
System XL	Saint-Gobain PAM UK Ltd	B.1.7.2	DWI 56/4/1317
System XL	Saint-Gobain PAM UK Ltd	B.1.11	DWI 56/4/1317
Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	E.4	DWI 56/4/1107c
Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	E.1	DWI 56/4/1107b

List of approved products for use in public water supply in the United Kingdom

Tanks and associated Pipework, Weir Plates and Baffle Plates manufactured from Stainless steel suitable for use with drinking water	Homer Burgess Ltd	B.1.10	DWI 56/4/1107a
Tetra LP Block System	De Nora Water Technologies UK Services Ltd	E.2	DWI 56/4/522
Thycal	Industrial Chemicals Ltd	A.9	DWI 56/4/1025
Tiefill	Flexcrete Technologies Ltd	C.6	DWI 56/4/1287
TOM PVC-O Pipe	Molecor Tecnología SL	B.1.3	DWI 56/4/1057
TP Chlor	Brenntag UK & Ireland	A.9	DWI 56/4/979
TP Chlor plus	Brenntag UK & Ireland	A.9	DWI 56/4/1190
Trifusion ®	Permastore Ltd	E.1	DWI 56/4/1213
TUBEdek FS41.50/84 PP	ENEXIO 2H Water Technologies Ltd	E.4	DWI 56/4/878
Ultrafiltration element ZW700B-8060/UF10/7B/R/0.8/40	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/1125
Ultrafiltration element ZW700B-8060/UF10/7B/X/0.8/40	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/1126
Ultralox 40	B&V Water treatment	A.9	DWI 56/4/1074
Unlined 316 & 316L Stainless Steel Tanks and Pipework	Ocean Kinetics Ltd	E.1	DWI 56/4/1395b
Unlined 316 & 316L Stainless Steel Tanks and Pipework	Ocean Kinetics Ltd	B.1.10	DWI 56/4/1395a
Uratop PVC-O Adequa	Adequa WS S.L.U	B.1.3	DWI 56/4/1266
VANDEXBB 75	Vandex International Ltd	C.5	DWI 56/4/1092
Vandex Plug	Vandex International Ltd	C.6	DWI 56/4/1096
VANDEXPREMIX	Vandex International Ltd	C.5	DWI 56/4/1097
VANDEXSUPER	Vandex International Ltd	C.5	DWI 56/4/1098
Velocitek OVF Filter Vessel	Hydro-Gen Engineering Ltd	D.4	DWI 56/4/1400
Vitec 3000	Avista Technologies (UK) Ltd	A.5	DWI 56/4/457
Vitec 4000	Avista Technologies (UK) Ltd	A.5	DWI 56/4/582
Vitec 5000	Avista Technologies (UK) Ltd	A.5	DWI 56/4/458
Vitec 7000	Avista Technologies (UK) Ltd	A.5	DWI 56/4/801
Vitec 7000a	Avista Technologies (UK) Ltd	A.5	DWI 56/4/869
Wallace and Tiernan OSEC ®	Evoqua Water Technologies Ltd	A.7.2	DWI 56/4/775
Water Pipe Lining	Aqualiner Ltd	C.1	DWI 56/4/910
Waterstop	Natural Cement Distribution Ltd	C.6	DWI 56/4/1217
Wavistrong Series	Future Pipe Industries B.V	B.1.6	DWI 56/4/656
Weholite Pipe and Panels	Asset International Ltd	B.1.1	DWI 56/4/513a
Weholite Pipe and Panels	Asset International Ltd	E.1	DWI 56/4/513b



List of approved products for use in public water supply in the United Kingdom

Wester Carbons Porous Block	Western Carbons	E.4	DWI 56/4/1297
Whale Drinking Water Bowser	Whale Tankers Ltd	B.3.2	DWI 56/4/662
WTP RO 411	Water Treatment Products Limited	A.5	DWI 56/4/821
WTP RO 413	Water Treatment Products Limited	A.5	DWI 56/4/822
XIGA HP	X-FLOW B.V.	D.1	DWI 56/4/1023
Xypex Admix C-1000 NF	Xypex (UK) LLP	C.6	DWI 56/4/1263
Xypex Admix C-500 NF	Xypex (UK) LLP	C.6	DWI 56/4/1244
Xypex Concentrate	Xypex (UK) LLP	C.5	DWI 56/4/1261
Xypex Modified	Xypex (UK) LLP	C.5	DWI 56/4/1262
Xypex Patch'n Plug	Xypex (UK) LLP	C.6	DWI 56/4/1100
ZeeWeed® 700B-9060 Membrane Module	SUEZ Water Technologies and Solutions Hungary Kft	D.1	DWI 56/4/1349
ZeeWeed 1000 V4	SUEZ Water Technologies and Solutions Hungary Kft	D.1	DWI 56/4/1177
ZeeWeed 1500 Series	SUEZ Water Technologies and Solutions Hungary Kft	D.1	DWI 56/4/1013
ZeeWeed 500c, Membrane Filtration Module	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/628
ZeeWeed 500d (340) Membrane Filtration Module	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/835
ZeeWeed 500d (440) Membrane Filtration Module	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/835
ZeeWeed 500ds (350) Membrane Filtration Module	SUEZ Water Technologies & Solutions	D.1	DWI 56/4/835