

Typical flouride levels in zones during 2020

Key

- 1.0 to 1.5 mg/l
- 0 to 0.49 mg/l
- 0.5 to 0.99 mg/l

The current standard for Flouride is 1.5 mg/l

